

1. SITC of copper refrigerant piping of various sizes with 20 SWG hard drawn copper piping along with necessary supports, fittings and clamps, insulation with 9mm thk class nitrile rubber insulation.
2. Copper piping shall be of current testing. (SECTION AND DISCHARGE PIPE'S 1/4 to 5/8 sizes)