

T A B L E

NOTE

1 FOR PLAN, SECTION, DETAILS AND NOTES REF SHEET NO. 1/2 OF THIS DRAWING.

SL NO	DIAMETER OF SOAK WELL IN METER MARKED AS 'd'	EFFECTIVE DEPTH	THICKNESS OF WALL FROM INLET			THICKNESS OF RCC SLAB		REINFORCEMENT IN SLAB BOTH WAYS BOTTOM	REINFORCEMENT AT PERIPHERY IN SLAB	RADIAL BARS AT TOP (SPACING MEASURED AT OUTER END)
			FROM INLET TO 4.5 M	FROM 4.5 TO 7.5 M		AT CENTRE	AT END			
1.	1.20 M	3.00 M 4.50 M 6.00 M 7.50 M	1 BK 1 BK 1 BK 1 BK	- - 1 BK 1 BK	- - - -	150	100	10 MM # @ 180 C/C	3 NOS 10 MM#	10 MM # @ 180 C/C
2.	1.80 M	3.00 M 4.50 M 6.00 M 7.50 M	1 1/2 BK 1 1/2 BK 1 1/2 BK 1 1/2 BK	- - 2 BK 2 BK	- - - -	150	100	10 MM # @ 180 C/C	3 NOS 10 MM#	10 MM # @ 180 C/C
3.	2.40 M	3.00 M 4.50 M 6.00 M 7.50 M	1 1/2 BK 1 1/2 BK 1 1/2 BK 1 1/2 BK	- - 2 BK 2 BK	- - - -	150	100	10 MM # @ 180 C/C	3 NOS 10 MM#	10 MM # @ 180 C/C
4.	3.00 M	3.00 M 4.50 M 6.00 M 7.50 M	1 1/2 BK 1 1/2 BK 1 1/2 BK 1 1/2 BK	- - 2 BK 2 BK	- - - -	160	100	10 MM # @ 140 C/C	3 NOS 10 MM#	10 MM # @ 140 C/C
5.	3.60 M	3.00 M 4.50 M 6.00 M 7.50 M	1 1/2 BK 1 1/2 BK 1 1/2 BK 1 1/2 BK	- - 2 BK 2 BK	- - - -	160	100	10 MM # @ 140 C/C	3 NOS 10 MM#	10 MM # @ 140 C/C
6.	5.00 M	3.00 M 4.50 M 6.00 M 7.50 M	1 1/2 BK 1 1/2 BK 1 1/2 BK 1 1/2 BK	- - 2 BK 2 BK	- - - -	180	130	10 MM # @ 180 C/C	3 NOS 10 MM#	10 MM # @ 180 C/C

TYPICAL SOAK WELL

TABLE - SOAK WELLS

DATE	30 APR 2019	CHIEF ENGINEER PUNE ZONE PUNE	SHEET NO 2/2
DRAWN			
TCD			
CKD			
SCALE	AS SHOWN	DRG NO : CEPZ/2019/TD/03	

AAD(ARCH)

DIR/JT DIR ARCH
FOR CHIEF ENGINEER