




ELEVATION (INSIDE)








ELEVATION (INSIDE)



ELEVATION (INSIDE)



SECTION



- NOTES**
- CONTRACTOR TO CHECK & VERIFY ALL THE DIMENSIONS BEFORE EXECUTION OF THE WORK.
 - FIGURED DIMENSIONS SHALL BE FOLLOWED.
 - ALL DIMENSIONS GIVEN IN THIS DRG ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.
 - SIZE OF WINDOW MENTIONED HERE IN IS CLEAR SIZE OF MASONRY OPENING. TOLERANCE OF 10 mm ON EITHER SIDE SHALL BE ALLOWED WHEN THE WINDOWS ARE FITTED IN TO BUILT IN OPENING.
 - WIRE GAUGE SHUTTERS IN FLY PROOF WINDOW (F) SHALL BE MADE OPENABLE INSIDE UNLESS OTHERWISE MENTIONED.
 - 5.5mm TH PLAIN SHEET GLASS PANES SHALL BE PROVIDED TO ALL WINDOWS UNLESS OTHERWISE SPECIFIED.
 - F STANDS FOR MOSQUITO PROOF WIRE GAUGE WINDOW (HAVING GLAZED AND WIRE GAUGE SHUTTER) A, B, C & K, L AND N HEIGHT AS 1250, 1200, 1000, & 1650, 1600, 1400 RESPECTIVELY.
 - ALL WINDOWS OF TOILETS, BATH & W.C SHALL HAVE PIN HEAD GLASS.
 - IN CASE OF R.C.C COL/R.C.C WALL THE WINDOWS FRAME SHALL BE FIXED WITH DASH THRU BOLTS OF STANDARD QUALITY AND SIZE AT 300MM C/C. ONE HANDLE & 2 NOS TOWER BOLTS 150 mm LONG SHALL BE PROVIDED TO EACH SHUTTER.
 - THE HOLDFASTS FOR DOORS, WINDOWS AND VENTILATORS SHALL BE EMBEDDED IN PCC 1:3:6 OF SIZE 150X 150XTH OF WALL.
 - BOX STEEL SECTION USED IN FRAME, SHUTTER FRAME AND CENTRE FRM.
 - IN MAIN PLANS THE SUFFIX OF THE W REPRESENTS THE NUMBER OF PANELS OF WIDTH SAME AS 3, 5 & 4 x 100 mm.
 - PIN HOLE @ 300 C/C TO BE PROVIDED FOR SUPPORTING GLASS WITH G.I CLIPS/WIRE IN CASE OF GLAZED SHUTTERS.
 - 2 NOS OF PINTOL HINGES 75mm LONG 12 mm dia WITH ONE PART OF THE HINGE SPOT WELDED WITH FRAME & OTHER VTH SHUTTER FOR EACH OPENABLE SHUTTER.
 - 4 NOS FLAT IRON HOLD FAST SHALL BE WELDED WITH EACH WINDOW.
 - MODULE 6, 5, 4 DENOTES 100, 500 & 400MM WIDE SIZE OF EACH SHUTTER.

S NO	DATE	DESCRIPTION	INITIAL
REVISION			
TYPICAL DETAIL OF BOX WINDOW (STEEL) WITH FLY PROOF SHUTTER			
DATE	01/05/08	CHIEF ENGINEER	SIGNO
DRN		JALANDHAR ZONE	1/3
TCD			
CHD			
SCALE	AS SHOWN	DRG. NO. CEJZ/TD-1020/08	