

CORRIGENDUM NO.-2 TO SPEC. NO. EDTS 200 REV. 'NIL' AM-1, Corr.1.

This corrigendum is issued to specification no. EDTS 200 Rev 'NIL' AM-1, corr.1 "SPECIFICATION FOR TUBULAR CRIMPING SOCKETS FOR E-BEAM CABLES to modify the TABLE-1; complying AM-1 & Corr.1 in a single table below. Items at s.no 18-19 & 22 added. Following is modified.

ITEM	SIZE OF CABLE mm ²	STUD SIZE	Ø E	Ø A	Ø C	D	F	B	H	G	J	INSPECTION HOLE (Ø K)
1	150	M16	17	17.4	26.0	36.4	8.6	29	21	18	76	Ø 4
2	150	M12	13.0	17.4	26.0	36.4	8.6	29	21	18	76	Ø 4
3	120	M12	13.0	15.4	23	32.0	7.6	29	18	17	71	Ø 4
4	95	M12	13.0	13.5	20	27.8	6.5	24	17	15	62	Ø 4
5	95	M10	10.2	13.5	20	27.8	6.5	24	17	15	62	Ø 4
6	95	M8	8.2	13.5	20	27.8	6.5	24	17	15	62	Ø 4
7	70	M12	13	12	17.8	25	5.8	24	15	13	58	Ø 3
8	70	M10	10.2	12	17.8	25	5.8	24	15	13	58	Ø 3
9	50	M12	13	10	15.5	21.6	5.5	24	15	11	56	Ø 3
10	50	M10	10.2	10	15.5	21.6	5.5	24	15	11	56	Ø 3
11	50	M8	8.2	10	15.5	21.6	5.5	24	15	11	56	Ø 3
12	35	M10	10.2	8.2	13	17.9	4.8	18	10	10	43	Ø 3
13	25	M10	10.2	7.2	11.5	19.6	3.4	18	14	11	47	Ø 3
14	25	M8	8.2	7.2	11.5	16	4.3	18	11	8	41	Ø 3
15	16	M10	10.2	5.8	8.5	16	1.9	14	11	9	37	Ø 3
16	16	M8	8.2	5.8	8.5	16	1.9	14	11	9	37	Ø 3
17	16	M6	6.5	5.8	8.5	11.9	2.7	14	10	6	33	Ø 3
18	70	M16	17	12	17.8	26	5	24	15	15	62	Ø 3
19	95	M16	17	13.5	20	28	6.5	24	17	15	64	Ø 4
20	120	M16	17	15.4	23	32.0	7.6	29	18	17	71	Ø 4
21	185	M16	17	19	28	38.5	9	32	21	19	82	Ø 4
22	50	M16	17	10	15.5	25	4	24	15	15	62	Ø 3

Signature Not Verified

Digitally signed by




BAL RAVI

Date: 2025.12.15

12:25:31 +05'

Reason: IREPS-CRIS

Location: New Delhi

EDTS 200	2	15.12.2011				1 of 1
Rev 'NIL' AM-1, cor.1	Corr.	Date	SSEE/D	SSEE/D	DY.CEE/D & D	Page