

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	20-05-2026 19:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	20-05-2026 19:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	180 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Uttar Pradesh
विभाग का नाम/Department Name	Energy Department Uttar Pradesh
संगठन का नाम/Organisation Name	Uttar Pradesh Rajya Vidyut Utpadan Nigam Limited (uprvunl) Lucknow
कार्यालय का नाम/Office Name	Lucknow
कुल मात्रा/Total Quantity	6300
वस्तु श्रेणी /Item Category	PVC Insulated Aluminium Cable Single Core and Multi Core Circular Sheathed with Rigid Conductor ISI Marked To IS 694 (Q2) , PVC Insulated Copper Cable Single Core and Multi Core Circular Sheathed with Flexible Conductor (V2) ISI Marked To IS 694 (Q2) , XLPE Cable for Working Voltage up to and Including 1.1 KV Marked To IS 7098 (Part 1) (Q2)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)	5 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	2 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

बिड विवरण/Bid Details	
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	5
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	3
विगत प्रदर्शन /Past Performance	30 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	PVC Insulated Aluminium Cable Single Core and Multi Core Circular Sheathed with Rigid Conductor ISI Marked To IS 694
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	3 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य / Estimated Bid Value	1081728
मूल्यांकन पद्धति/Evaluation Method	Item wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
Schedule 1 ईएमडी राशि/EMD Amount (In INR)	500
Schedule 2 ईएमडी राशि/EMD Amount (In INR)	1500
Schedule 3 ईएमडी राशि/EMD Amount (In INR)	500

Schedule 4 ईएमडी राशि/EMD Amount (In INR)	300
Schedule 5 ईएमडी राशि/EMD Amount (In INR)	1500
Schedule 6 ईएमडी राशि/EMD Amount (In INR)	1000
Schedule 7 ईएमडी राशि/EMD Amount (In INR)	3000
Schedule 8 ईएमडी राशि/EMD Amount (In INR)	2000
Schedule 9 ईएमडी राशि/EMD Amount (In INR)	3500
Schedule 10 ईएमडी राशि/EMD Amount (In INR)	2500
Schedule 11 ईएमडी राशि/EMD Amount (In INR)	1800
Schedule 12 ईएमडी राशि/EMD Amount (In INR)	1200
Schedule 13 ईएमडी राशि/EMD Amount (In INR)	700

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). The EMD Amount will be applicable for each schedule/group selected during Bid creation.

(c). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

Dy CAO
PARICHHA THERMAL POWER PROJECT, PARICHHA, JHANSI (UP)-284305.
(Dy Cao Cfabo Ptp Parichha)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	No
---	----

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

3. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

4. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 30% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

5. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

मूल्यांकन विधि(मदवार मूल्यांकन विधि) / Evaluation Method (Item Wise Evaluation Method)

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

मूल्यांकन अनुसूचियां / Evaluation Schedules	अनुमानित मूल्य / Estimated Value	वस्तु/श्रेणी / Item/Category	मात्रा / Quant ity
Schedule 1	24000	Pvc Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor Isi Marked To Is 694	400
Schedule 2	83736	Pvc Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor Isi Marked To Is 694	200
Schedule 3	45900	Pvc Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Flexible Conductor (v2) Isi Marked To Is 694	900

Schedule 4	12492	Pvc Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Flexible Conductor (v2) Isi Marked To Is 694	900
Schedule 5	90000	Pvc Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor Isi Marked To Is 694	900
Schedule 6	90000	Xlpe Cable For Working Voltage Up To And Including 1.1 Kv Marked To Is 7098 (part 1)	900
Schedule 7	188700	Xlpe Cable For Working Voltage Up To And Including 1.1 Kv Marked To Is 7098 (part 1)	200
Schedule 8	115000	Xlpe Cable For Working Voltage Up To And Including 1.1 Kv Marked To Is 7098 (part 1)	200
Schedule 9	138600	Xlpe Cable For Working Voltage Up To And Including 1.1 Kv Marked To Is 7098 (part 1)	300
Schedule 10	96600	Xlpe Cable For Working Voltage Up To And Including 1.1 Kv Marked To Is 7098 (part 1)	300
Schedule 11	71700	Xlpe Cable For Working Voltage Up To And Including 1.1 Kv Marked To Is 7098 (part 1)	300
Schedule 12	55500	Xlpe Cable For Working Voltage Up To And Including 1.1 Kv Marked To Is 7098 (part 1)	300
Schedule 13	69500	Pvc Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor Isi Marked To Is 694	500

PVC Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor ISI Marked To IS 694 (400 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ / Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR
	Type of Insulation	Type A
	Number of Core	2
	Sheath Type	Type ST1, Type ST2 (HR)
	Shape of Conductor	Solid, Stranded
	Nominal Cross Sectional Area of Conductor (in Sq. mm)	4.0

Additional Specification Parameters - PVC Insulated Aluminium Cable Single Core And Multi Core

Circular Sheathed With Rigid Conductor ISI Marked To IS 694 (400 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	LT ALUMINIUM CABLE 2CORE 4SQMM

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	400	90

PVC Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor ISI Marked To IS 694 (200 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	01
	Type of Insulation	Type A, Type C (HR)
	Number of Core	4
	Sheath Type	Type ST1, Type ST2 (HR)
	Shape of Conductor	Solid, Stranded
	Nominal Cross Sectional Area of Conductor (in Sq. mm)	25.0

Additional Specification Parameters - PVC Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor ISI Marked To IS 694 (200 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPPECIFICATION	25010109 CABLE LT AL 3.5C 25SQMM

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	200	90

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Flexible Conductor (V2) ISI Marked To IS 694 (900 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of cable	FR, FR-LSH
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C (HR), Type D
	Cable Construction Type	Single Core Cable
	No of core	1.0
	Nominal Cross Sectional Area of Conductor (in Sq mm)	4.0
	Sheath type	Type ST2 (HR), Type ST3
	Colour of sheath	Any other colour as agreed between the purchaser and the supplier
	Conductor material (Complying with IS:8130:1984 latest)	Annealed bare copper

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Flexible Conductor (V2) ISI Marked To IS 694 (900 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	PVC insulated highly flexible bare Copper single core unsheathed 1100V grade wire of size 2.5 Sqmm and colour GREY, Construction 50/0.25, Specification: IS 694-1977

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	900	90

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Flexible Conductor (V2) ISI Marked To IS 694 (900 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of cable	FR, FR-LSH
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C (HR), Type D
	Cable Construction Type	Single Core Cable
	No of core	1.0
	Nominal Cross Sectional Area of Conductor (in Sq mm)	4.0
	Sheath type	Type ST2 (HR), Type ST3
	Colour of sheath	Black, Any other colour as agreed between the purchaser and the supplier
	Conductor material (Complying with IS:8130:1984 latest)	Annealed bare copper

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Flexible Conductor (V2) ISI Marked To IS 694 (900 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	PVC insulated highly flexible bare Copper single core unsheathed 1100V grade wire of size 1.5Sqmm and colour GREY, Construction 85/0.25, Specification: IS 694-1977

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	900	90

PVC Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor ISI Marked To IS 694 (900 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	01, FR
	Type of Insulation	Type A
	Number of Core	2
	Sheath Type	Type ST1
	Shape of Conductor	Solid
	Nominal Cross Sectional Area of Conductor (in Sq. mm)	2.5

Additional Specification Parameters - PVC Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor ISI Marked To IS 694 (900 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	CABLE 0.4KV AL 2COREX2.5MM2 UNARMoured

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	900	90

XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part

1) (900 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes, No
GENERIC	Classification of cables for improved fire performance category	01, C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	1.5
	Number of Cores	2
CONSTRUCTION	Material of Conductor	Plain Copper
	Construction of the conductor	Stranded, Stranded and shaped
	Colour of XLPE Insulation	Red, Black
	Type of Inner Sheath	Thermoplastic
ARMOURING	Type of Cable	Un-armoured cable
	Material of Armouring	Not applicable for Un-armoured cable
	Type of Armouring	Not applicable for Un-armoured cable
OUTER SHEATH	Outer Sheath Standard	Conforming to IS:5831:1984 latest
	Type of Outer Sheath	PVC-ST2
	Colour of Outer Sheath	Black
IDENTIFICATION ON CABLE	Manufacturer's Identification on Cable	as per Cl.17.1 of IS:7098 Part 1: latest
	Cable Identification	as per Cl.17.2 of IS:7098 Part 1: latest

Additional Specification Parameters - XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (900 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	Copper CONTROL CABLE SIZE 2Cx1.5 MM2 UMARMOURED MULTISTRAND

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	900	90

XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (200 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C1 - FR, C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	120
	Number of Cores	3.5
CONSTRUCTION	Material of Conductor	Aluminium
	Construction of the conductor	Stranded
	Colour of XLPE Insulation	Red, Yellow, Blue, Black, Grey, Natural, for 6 Core and above as per Cl.10.1 of IS:7098
	Type of Inner Sheath	Thermoplastic
ARMOURING	Type of Cable	Armoured cable
	Material of Armouring	Galvanized round steel wire, Galvanized steel formed wire
	Type of Armouring	Single strip
OUTER SHEATH	Outer Sheath Standard	Conforming to IS:5831:1984 latest

Additional Specification Parameters - XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (200 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	"3.5 core 120 sq.mm xlpe armoured cable. Conductor Material: Annealed stranded aluminum. Insulation: XLPE (Cross-Linked Polyethylene) Armour: Galvanized Steel Strip or Round Wire Armour (SWA/RWA) for mechanical protection Sheath: Extruded PVC (Black) Rated Voltage: 1.1 kV Conductor Class:CLASS 2(as per IEC 60228). Make-Finolex,havells,polycab,kei"

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	200	90

XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (200 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Cables suitable for use in mines	No
GENERIC	Classification of cables for improved fire performance category	01, C1 - FR, C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	95
	Number of Cores	3.5
CONSTRUCTION	Material of Conductor	Aluminium
	Construction of the conductor	Stranded, Stranded and shaped
	Colour of XLPE Insulation	Red, Yellow, Blue, Black
	Type of Inner Sheath	Thermoplastic
ARMOURING	Type of Cable	Armoured cable
	Material of Armouring	Galvanized round steel wire, Galvanized steel formed wire, Aluminium flat strip

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Type of Armouring	Single strip

Additional Specification Parameters - XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (200 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	"3.5 core 95 sq.mm xlpe armoured cable. Conductor Material: Annealed stranded aluminum. Insulation: XLPE (Cross-Linked Polyethylene) Armour: Galvanized Steel Strip or Round Wire Armour (SWA/RWA) for mechanical protection Sheath: Extruded PVC (Black) Rated Voltage: 1.1 kV Conductor Class:CLASS 2(as per IEC 60228)Make-Finolex,havells,polycab,kei"

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	200	90

XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (300 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Cables suitable for use in mines	No
GENERIC	Classification of cables for improved fire performance category	01, C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	70
	Number of Cores	3.5
CONSTRUCTION	Material of Conductor	Aluminium

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Construction of the conductor	Stranded
	Type of Inner Sheath	Thermoplastic
ARMOURING	Type of Cable	Armoured cable
	Material of Armouring	Galvanized round steel wire, Galvanized steel formed wire
	Type of Armouring	Single wire, Single strip

Additional Specification Parameters - XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (300 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	"3.5 core 70 sq.mm xlpe armoured cable. Conductor Material: Annealed stranded aluminum. Insulation: XLPE (Cross-Linked Polyethylene) Armour: Galvanized Steel Strip or Round Wire Armour (SWA/RWA) for mechanical protection Sheath: Extruded PVC (Black) Rated Voltage: 1.1 kV Conductor Class:CLASS 2(as per IEC 60228)Make-Finolex,havells,polycab,kei"

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	300	90

XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (300 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Cables suitable for use in mines	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01, C1 - FR, C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	50
	Number of Cores	3.5
CONSTRUCTION	Material of Conductor	Aluminium
	Construction of the conductor	Stranded, Stranded and shaped
	Type of Inner Sheath	Thermoplastic
ARMOURING	Type of Cable	Armoured cable
	Material of Armouring	Galvanized round steel wire, Galvanized steel formed wire
	Type of Armouring	Single wire, Single strip

Additional Specification Parameters - XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (300 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	"3.5 core 50 sq.mm xlpe armoured cable. Conductor Material: Annealed stranded aluminum. Insulation: XLPE (Cross-Linked Polyethylene) Armour: Galvanized Steel Strip or Round Wire Armour (SWA/RWA) for mechanical protection Sheath: Extruded PVC (Black) Rated Voltage: 1.1 kV Conductor Class:CLASS 2(as per IEC 60228)Make-Finolex,havells,polycab,kei"

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	300	90

XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (300 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ / Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01, C1 - FR, C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	35
	Number of Cores	3.5
CONSTRUCTION	Material of Conductor	Aluminium
	Construction of the conductor	Stranded, Stranded and shaped
	Type of Inner Sheath	Thermoplastic
ARMOURING	Type of Cable	Armoured cable
	Material of Armouring	Galvanized round steel wire, Galvanized steel formed wire, Aluminium round wire
	Type of Armouring	Single wire, Single strip

Additional Specification Parameters - XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (300 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	"3.5 core 35 sq.mm xlpe armoured cable. Conductor Material: Annealed stranded aluminum. Insulation: XLPE (Cross-Linked Polyethylene) Armour: Galvanized Steel Strip or Round Wire Armour (SWA/RWA) for mechanical protection Sheath: Extruded PVC (Black) Rated Voltage: 1.1 kV Conductor Class:CLASS 2(as per IEC 60228)Make-Finolex,havells,polycab,kei"

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	300	90

XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (300 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes, No
GENERIC	Classification of cables for improved fire performance category	C1 - FR, C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	25
	Number of Cores	3.5
CONSTRUCTION	Material of Conductor	Aluminium
	Construction of the conductor	Stranded, Stranded and shaped
	Type of Inner Sheath	Thermoplastic
ARMOURING	Type of Cable	Armoured cable
	Material of Armouring	Galvanized round steel wire, Galvanized steel formed wire
	Type of Armouring	Single strip

Additional Specification Parameters - XLPE Cable For Working Voltage Up To And Including 1.1 KV Marked To IS 7098 (Part 1) (300 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	"3.5 core 25 sq.mm xlpe armoured cable. Conductor Material: Annealed stranded aluminum. Insulation: XLPE (Cross-Linked Polyethylene) Armour: Galvanized Steel Strip or Round Wire Armour (SWA/RWA) for mechanical protection Sheath: Extruded PVC (Black) Rated Voltage: 1.1 kV Conductor Class:CLASS 2(as per IEC 60228)Make-Finolex,havells,polycab,kei"

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	300	90

PVC Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor ISI Marked To IS 694 (500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	02, FR
	Type of Insulation	Type A
	Number of Core	2
	Sheath Type	Type ST1
	Shape of Conductor	Solid, Stranded
	Nominal Cross Sectional Area of Conductor (in Sq. mm)	16.0

Additional Specification Parameters - PVC Insulated Aluminium Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor ISI Marked To IS 694 (500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)

Specification Parameter Name	Bid Requirement (Allowed Values)
SPECIFICATION	"2C,16 Sq.mm 1.1 KV, AL UNARMoured FLEXIBLE CABLE Type: 2 Core Flexible Aluminum Cable Conductor Size: 16 sq.mm Conductor Type:Stranded,Flexible Aluminum Insulation: PVC Outer Sheath: PVC (BLACK) Rated Voltage: 1.1 kV make-finolex,kei,polycab,havells."

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shailesh Chaurasia	284305,Parichha Thermal Power Plant	500	90

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer, is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid. All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM. If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.

4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---