


SPECIFICATION FOR 4 TON TOWER AC

SI No:	Technical Requirement	Bidders Response Yes/No
1.	Split Ac Indoor Unit- Floor Standing/ Tower Type	
2.	Split Ac confirming to IS 1391 (Part 2)	
3.	BIS/ ISI Marking Certificate	
4.	Material of Evaporator - Copper Coil	
✓ 5.	Material of Condenser-Copper Coil with Blue Fin Coating	
6.	AC – Make & Model of the Two ACs should be the same	
7.	Warranty- Three Years for AC including Compressor	
8.	Input Supply- 415 AC/50 Hz, Three Phase	
9.	Installation – Standard Installation	
✓ 10.	Five Star Rating	

Bidders should specify the Brand which is to be supplied and attach the Technical Information for the offered product.


01/06/2026
DDE (AJ).

T.A. Tamil Selvi
ADE.

HOD/DDCE) pl. : Extra parameters added (Sl.no: 5210)
required to be approved by the Competent Authority,
which may pl. be approved/signed.

1/6/26


01/06/2026
DDE.