



OFFICE OF THE CHIEF GENERAL MANAGER (STORE & PURCHASE)
M.P. POORV KSHETRA VIDYUT VITARAN Co. Ltd.
REGD. OFFICE – BLOCK No. 8TH, 3RD FLOOR, SHAKTI BHAWAN,
RAMPUR, JABALPUR - 482 008 (M.P.)
CIN: U40109MP2002SGC015120
(Telephone no. 0761- 2997711, 2667808, Extn. 270-2473, 270-2425 & 270-2541)
e-mail:- cepurez@yahoo.in

No. CGM/S&P/EZ/GM-I/II/

450

CORRIGENDUM NO.-1

Dated:-

25 MAY 2026

Sub:- Tender Specification No. DISCOM/EZ/PUR/1729 (E-Tender No. 2026_PKVVC_ 507161_1) for supply of 11KV & 33KV Current Transformers (CTs)

- (i) The modification are incorporated in the clause no. 7 “Acceptance of Material” of Annexure-IV “Special Terms and Conditions of Purchase” against the subject tender is as under:-

7. ACCEPTANCE OF MATERIAL

The MPPKVVCL has option to conduct Routine/Type tests/STC test with acceptance test on the samples from the consignment of material received at our consignee Area Stores before its acceptance from any of the lot to be supplied against the order. The said test shall be conducted on any one unit of each rating of the received lot. The MPPKVVCL reserve the right to waive off the testing of the lot, in case of urgency.

The sample Unit shall be selected for conducting Type Test/routine tests/STC test with acceptance test from the lot of CTs received in Area stores by a committee constituted by CE (W&P). The body of the samples so selected shall be sealed by at least 2-3 seals by the committee members. The selected samples shall be sent with complete details for testing as per specification at purchaser’s in-house lab/NABL accredited Laboratory like ERDA, CPRI etc.

The sample size for testing and criteria for acceptance testing shall be as under:-

Lot Size	Sample size		Failure quantity on sample size (in %/No)			Failure quantity on re-sampling (in %/No)	
	Nos.	%	Acceptable Limit	Permissible limit for Resampling	Rejection criteria of lot/DI Qty	Acceptable Limit	Rejection criteria of lot/DI Qty
Up to 100 nos.	2 Nos.	NA	0	1 no.	> 1 no. sample	0	> 0 no. sample
101 to 500 Nos.	3 Nos.	NA	0	2 nos.	> 2 nos. sample	0	> 0 no. sample
Above 500 Nos.	5 Nos.	NA	0	2 nos.	> 2 nos. sample	0	> 0 nos. sample


The EE (stores) shall verify and ensure that the serial number and make is engraved on the sides of the CTs.

The testing charges shall be borne by the MPPKVVCL. However, in case the CTs fails in any of the test(s), the entire lot shall be rejected and the entire testing charges shall be recovered from the supplier.

In case of any dispute relating to test results against the rejected lot and on contesting by the supplier, the retesting of another randomly selected sample from the rejected lot in presence of firm’s representative may be considered at the discretion of MPPKVVCL. The retesting charges including other expenses viz transportation, loading/unloading etc. shall be borne by the supplier. In case of failure of the lot in second testing, the lot shall be finally rejected and shall have to be lifted & replaced by the supplier.

No further representations /requests shall be entertained and the decision/ discretion of MPPKVVCL in this regard shall be final and binding on the supplier.

Other terms and conditions of the tender shall remain unchanged and applicable.


Chief General Manager (S&P)
M.P.P.K.V.V.Co.Ltd., Jabalpur

