



NOTES:

1. **NO. OF RISER PER SUPPORT - 2 (RISER FOR 66KV 50X6MM GI FLAT FOR 10KA FAULT CURRENT AND 50X8MM GI FLAT FOR 25KA FAULT CURRENT & ABOVE CLASS 75X10MM GI FLAT).**
2. **ALL DIMENSIONS ARE IN MM.**
3. **EARTHING LEADS FROM ONE EQPT / STRUCTURE SHALL BE CONNECTED TO DIFFERENT CONDUCTORS OF EARTHING GRID.**
4. **NO. OF CLEAT TYPE CLAMP PER SUPPORT - 5 IN 400KV, 4 IN 220KV & 2 IN 66 AND 132KV.**

EXECUTION PURPOSE



GUJARAT ENERGY TRANSMISSION CORPN.LTD.
 S.P.VIDYUT BHAVAN, RACE COURSE,
 VADODARA - 390 007

Typical Earthing Arrangement for BPI

		DRAWN:	CHECKED:	APPD:	
		N.P.P.	P.B.M.	EE (ENGG) ACE (ENGG)	
REV:	DESCRIPTION:	SCALE:	DATE:	DRG. NO:	SHEET:
		N.T.S.	01-06-08	GETCO / E / STD / P-012	11 OF 24
					REV: R0