



NOTES:

1. ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE SPECIFIED.
2. NO.OF RISER PER SUPPORT - 06 NOS. (4NOS. PER STRUCTURE + 2NOS. PER JUNCTION BOX)
3. RISER FOR 66KV 50X6MM GI FLAT FOR 10KA FAULT CURRENT AND 60X6MM GI FLAT FOR 20KA FAULT CURRENT & ABOVE CLASS 75X10MM GI FLAT.
4. EARTHING LEADS FROM ONE EQPT / STRUCTURE SHALL BE CONNECTED TO DIFFERENT CONDUCTORS OF EARTHING GRID
5. NO. OF CLEAT TYPE CLAMP 4 PER SUPPORT

EXECUTION PURPOSE



GUJARAT ENERGY TRANSMISSION CORPN.LTD.
S.P.VIDYUT BHAVAN, RACE COURSE,
VADODARA - 390 007

Typical Earthing Arrangement for CT

		DRAWN:	CHECKED:	APPD:	
		N.P.P.	P.B.M.	EE (ENGG) ACE (ENGG)	
REV:	DESCRIPTION:	SCALE:	DATE:	DRG. NO:	SHEET:
		N.T.S.	01-06-08	GETCO / E / STD / P-012	08 OF 24
					R0