



**NOTES:**

1. RISER FOR 68KV 50X8MM GI FLAT FOR 10KA FAULT CURRENT AND 50X8MM GI FLAT FOR 25KA FAULT CURRENT & ABOVE CLASS 75X10MM GI FLAT.
2. ALL DIMENSIONS ARE IN MM

EXECUTION PURPOSE

**GUJARAT ENERGY TRANSMISSION CORPN.LTD.**  
 S.P.VIDYUT BHAVAN, RACE COURSE,  
 VADODARA - 390 007

Typical Earthing Arrangement for Tower without Peak

		<b>DRAWN:</b>	<b>CHECKED:</b>	<b>APPD:</b>	
		N.P.P.	P.B.M.	EE (ENGG) ACE (ENGG)	
<b>REV:</b>	<b>DESCRIPTION:</b>	<b>SCALE:</b>	<b>DATE:</b>	<b>DRG. NO:</b>	<b>SHEET:</b>
		N.T.S.	01-06-08	GETCO / E / STD / P-012	14 OF 24
					RD