



TYP. PLAN

NOTE:-

- 1. RISER FOR 66KV 50X6MM GI FLAT FOR 10KA FAULT CURRENT AND 50X8MM GI FLAT FOR 25KA FAULT CURRENT & ABOVE CLASS 75X10MM GI FLAT.**

EXECUTION PURPOSE



GUJARAT ENERGY TRANSMISSION CORPN.LTD.
S.P.VIDYUT BHAVAN, RACE COURSE,
VADODARA - 390 007

Typical Earthing Arrangement of Cable Trench

		DRAWN: N.P.P.	CHECKED: P.B.M.	APPD: EE (ENGG) ACE (ENGG)	
REV:	DESCRIPTION:	SCALE: N.T.S.	DATE: 01-06-08	DRG. NO: GETCO / E / STD / P-012	
					SHEET: 19 OF 24
					REV: R0