

NOTES:


1. ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE SPECIFIED.
2. NO. OF RISER PER 6 NOS.(2 PER SUPPORT + 2 PER CONTROL BOX + 2 FOR COMMON CONTROL CUBICLE)
3. NO. OF CLEAT TYPE CLAMP 4 PER STRUCTURE
4. EARTHING LEADS FROM ONE EQPT/STRUCTURE SHALL BE CONNECTED TO DIFFERENT CONDUCTORS OF EARTHING GRID
5. RISER FOR 66KV 50X6MM GI FLAT FOR 10KA FAULT CURRENT AND 50X8MM GI FLAT FOR 25KA FAULT CURRENT & ABOVE CLASS 75X10MM GI FLAT.

EXECUTION PURPOSE



GUJARAT ENERGY TRANSMISSION CORPN.LTD.
 S.P.VIDYUT BHAVAN, RACE COURSE,
 VADODARA - 390 007

Typical Earthing Arrangement for Circuit Breaker

		DRAWN: N.P.P.	CHECKED: P.B.M.	APPD: EE (ENGG) ACE (ENGG)	 SIZE: A4
R0	FIRST PREPARATION	SCALE: N.T.S.	DATE: 01-06-08	DRG. NO: GETCO / E / STD / P-012	
REV:	DESCRIPTION:				REV: R0