



NOTES:-

1. NO. OF CU.FLEXIBLE BRAID REQD. 2 PER GATE POST.
2. EVERY ALTERNATE POST OF THE FENCE SHALL BE CONNECTED TO EARTH MAT THROUGH A RISER.

| | |
|------|-------------------|
| | |
| | |
| R0 | FIRST PREPARATION |
| REV: | DESCRIPTION: |

| | | | |
|--|-----------------|-------------------------|---|
| EXECUTION PURPOSE | | | |
|  GUJARAT ENERGY TRANSMISSION CORPN.LTD. S.P.VIDYUT BHAVAN, RACE COURSE, VADODARA - 390 007 | | | |
| Typical Earthing Arrangement for Switch Yard Gate | | | |
| DRAWN: | CHECKED: | APPD: |  SIZE: A4 |
| N.P.P. | P.B.M. | EE (ENGG) ACE (ENGG) | |
| SCALE: | DATE: | DRG. NO: | SHEET: REV: |
| N.T.S. | 01-08-08 | GETCO / E / STD / P-012 | 21 OF 24 R0 |