



DETAILS OF FLAT TYPE 'C'



DETAIL OF FLAT TYPE 'D'

NOTES:-

1. ALL DIM. ARE IN MM.
2. AFTER FABRICATION BOTH FLATS ARE TO BE HOT DIP GALVANISED AS PER IS-2629.
3. FLAT TYPE 'C' IS TO BE PROVIDED ON ONE LEG OF EACH TOWER
4. FLAT TYPE'D' IS TO BE PROVIDED WITH PIPE EARTH ARRANGEMENT AND TO BE CONNECTED WITH FLAT 'C' FOR THE LOCATION WHERE TOWER FOOTING RESISTANCE IS MORE THAN 10 OHMS.

| LIST OF BOLTS & NUTS WITH SP.WASHER | | | |
|-------------------------------------|---------------|------|------------------------|
| S.NO. | SIZE | QTY. | REMARKS |
| 1. | M 16Ø X 45LG. | 2 | PER TOWER |
| 2. | M 16Ø X 35LG. | 2 | PER PIPE TYPE EARTHING |
| 3. | M12Ø X 30LG. | 2 | PER PIPE TYPE EARTHING |

| | |
|------|--------------|
| | |
| | |
| | |
| | |
| REV: | DESCRIPTION: |

| | | | |
|--|----------|--|--------------------------|
| TENDER PURPOSE | | | |
| GUJARAT ENERGY TRANSMISSION CORPN.LTD. S.P.VIDYUT BHAVAN, RACE COURSE, VADODARA - 360 007 | | | |
| Details of Flats for Earthing | | | |
| DRAWN: | CHECKED: | APPD: | SIZE: A4 |
| SCALE: | DATE: | DRG. NO: | |
| N.T.S. | | GETCO / E / 4L-STD /EARTHING-04/001 | SHEET: 3 OF 3 REV: RD |