




NOTE:-

- THIS TEST PIT IS TO BE PROVIDED TO UNTREATED EARTH ELECTRODE AND TO BE JOINED WITH MAIN MESH FOR THE PURPOSE OF :
1. TO MEASURE THE EARTH RESISTANCE OF MAIN MESH. (DURING SHUTDOWN)
 2. TO PROVIDE EXTERNAL EARTH CONNECTION TO THE EQUIPMENT / DEVICE TO BE CONNECTED TEMPORARILY.
 3. IT'S WORKING SPACE IS REVISED FROM 400 TO 650MM AS PER CBIP MANUAL ON EARTHING SYSTEM # 302.

		EXECUTION PURPOSE			
		 GUJARAT ENERGY TRANSMISSION CORPN.LTD. S.P.VIDYUT BHAVAN, RACE COURSE, VADODARA - 390 007			
		Typical Arrangement of Earth Test Pit (Check Pit)			
		DRAWN:	CHECKED:	APPD:	SIZE:
		N.P.P.	P.B.M.	EE (ENGG) ACE (ENGG)	A4
		SCALE:	DATE:	DRG. NO:	SHEET:
		N.T.S.	01-06-08	GETCO / E / STD / P-011	1 OF 2
REV:	DESCRIPTION :				REV:
R1	REVISED AS PER FIELD INPUT & CBIP MANUAL # 302				R1
R0	FIRST PREPARATION DATE > 01-06-2007				