

TENDER NOTICE NO: TCJND/2026-27/N-89

NAME OF WORK:

Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh.

Technical Bid (All relevant documents) and Price Bid both must be submitted online only. No physical bid accepted. Payment of Tender Fee/E.M.D. can be accepted by RTGS/NEFT /Online Only

IMPORTANT NOTE:

IF BIDDER FAILED TO SUBMIT ANY OF THE REQUIRED DOCUMENT ALONG WITH THE ONLINE TECHNICAL BID AS PER QUALIFICATION REQUIREMENT, THEIR BID MAY BE REJECTED WITHOUT INTIMATION TO BIDDER.

HENCE, BEFORE QUOTE THE BID, BIDDER HAVE TO ENSURE THAT ALL THE DOCUMENTS ARE SUBMITTED ONLINE ALONG WITH TECHNICAL BID.

જો બિડર ઓનલાઈન ટેકનિકલ બિડ સાથે માંગેલા જરૂરી ડોક્યુમેન્ટ્સ માંથી કોઈપણ ડોક્યુમેન્ટ સબમિટ કરવામાં નિષ્ફળ જશે તો બિડરને જાણ કર્યા વિના તેમનું બિડ રદ થઈ શકે છે.

આથી ઓનલાઈન બિડ સબમિટ કરતાં પહેલા, બિડરે ખાતરી કરી લેવી કે તમામ જરૂરી ડોક્યુમેન્ટ્સ ઓનલાઈન ટેકનિકલ બિડ સાથે જોડેલા જ છે.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



NAME OF WORK: 'Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh'.

INDEX

Sr.No.	Particulars
1	Technical Bid
2	Tender Notice
3	Integrity Pact
4	Annexure-1
5	Annexure-2
6	Annexure-3
7	Annexure-4
8	Annexure-5
9	Annexure-6
10	Annexure-7
11	Annexure-8
12	Annexure-9
13	Annexure-10
14	Qualification requirement & scope of work
15	Safety clause
16	WORK & SAFETY REGULATIONS
17	General Commercial Conditions
18	Special Commercial Conditions
19	Industrial & Labour laws
20	Bonds & Agreement sample
21	Form of Banker's Undertaking for "Bank Guaranty"
22	General Technical Condition for Substation & line work
23	Special Technical Conditions
24	Technical Specifications
25	A/T Acceptance letter sample
26	Application For Refund Of EMD
27	Price Bid (Schedule-B)

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmail.com



Technical Bid

Sign & Stamp of Contractor

Regd. Corporate office:

Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.

Corporate Identity No. (CIN): U40100GJ1999SG036018

Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



TENDER NOTICE No: TCJND/2026-27/N-89

Superintending Engineer, Transmission Circle GETCO Junagadh invites "On line Tenders" (e-tendering) for the work '**Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh**' from registered contractors in GETCO and who has executed similar nature of work successfully as mentioned in Qualification requirement criteria given in the tender document. Bidders should fulfill all the qualification criteria. Otherwise their bids will not be considered & price bid will not be opened. All the bidders should have valid e-tender vender registration.

Tender papers & specifications may be down loaded from web site <https://getco.nprocure.com> (for view, download and online submission) and GUVNL/GETCO websites www.gseb.com & www.getcogujarat.com (for view & download only). All the relevant documents of tender to be submitted online. **Tender Fee and E.M.D. should be paid in RTGS/NEFT/Online in favor of GETCO, Junagadh. Bank details are specified in Tender.**

The Superintending Engineer (TR)
Gujarat Energy Transmission Corporation Limited.,
Circle Office, Dhandhusar road, Opp Nandbava Gaushala,
66KV Zanzarda substation,
Junagadh – 362 015 District: Junagadh, Gujarat

Tender Notice No.	Name of work	Estimated Cost Rs.	Time limit	Tender fee Rs.	EMD Rs.	Appropriate Class
TCJND/2026-27/N-89	'Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh'	Rs. 4229553.46 + Rs. 761319.62 (GST @18%) = Rs. 4990873.08	3 (Three) Months	(1000 + 180 (GST 18%)) = Rs.1180/- (Non refundable)	Rs. 40000.00	ANY CLASS GETCO

1	On line (e-tendering) tender/offer submission last date up to 16:00 hours only (This is mandatory)	21.10.2026
2	Date of opening of Tender Fee, EMD, and technical bid on line opening at 16:30 hrs.	21.10.2026
3	Tentative Date of online opening of price bid	After Evolution of Technical Bid.

IMPORTANT:

- All the relevant documents as per requirement of the tender to be submitted online i.e. Technical bid, Qualification requirement data, detail specification except Tender Fee plus GST as applicable, EMD Amount should be paid either by RTGS/NEFT/Online. Otherwise the offer will not be considered and no any further communication in the matter will be entertained.
- Any deviation found in Data/Details/Documents in on line offer (e-tendering) submitted documents (Tender document fee, EMD, Vendor Registration, Technical and commercial documents etc.) of bidder, offer of the same bidder will not be considered and no any further communication in the matter will be entertained. Tender will be evaluated on Data/Details/Documents of the "on line" offer.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

3. It is mandatory for all the bidders to submit their tender documents by on-line (e-tendering) in schedule time.
4. The bidders are required to fill up all the online appendices (annexure)/forms. This is intended for transparency and speedy evaluation of the bids. Instead of simply confirming, the bidder shall fill in the particulars against appropriate place in respect of each line appearing in each online annexure.
(In the absence of required details in the online annexure, the corporation has every right to evaluate the bids accordingly and bidder cannot raise any objection against any point during evaluation.)
5. Bidders are requested to remain in touch with the web site for any amendment/ corrigendum or extension of due date etc.
6. No tender shall be accepted/opened in case of receipt after due date and time of tender, irrespective of delay due to postal services or any other reasons and the Corporation shall not assume any responsibility for late receipt of tender.
7. The Earnest Money Deposit and tender fee plus GST as applicable will be accepted by NEFT/RTGS/Online payable at Junagadh drawn in favor of "**GUJARAT ENERGY TRANSMISSION CORPORATION LTD.**" Tender without EMD and tender fee plus GST as applicable shall be rejected.
8. The GETCO reserves the right to award the work to one or more bidders, considering their technical and financial capacity OR to reject any or all tenders or accept any tender without assigning any reason thereof.
9. **Suitable payment option can be selected for Tender Fee & EMD. Amount should be paid either by RTGS/NEFT/Online.**
Also bidder has to mail following details as a payment reference:

Sr. No.	Required Details	
1	Name & Address of Bidder	
2	Bidder GST No.	
3	Tender Notice No. with due Dt.	
4	Mode of Transfer	
5	Ref. ID with Bank details	
6	Paid Amount	
7	Payment against (Tender Fee/EMD)	

Mail To,

1. setrjunagadh.getco@gmail.com
2. aojunagadh.getco@gmail.com
3. cashierjunagadh.getco@gmail.com
4. cashier.junagadhcircle@gmail.com

Bidder has to provide all above details on the same date of payment so that receipt can be generated.

GETCO Junagadh Circle Beneficiary Bank Detail Is As Under

1	Name of Account Holder	THE SUP ENG (TRANS) GETCO TR CIRCLE NON OPERATIVE A/C
2	Account Number	66000382476
3	Name Of Bank	STATE BANK OF INDIA
4	Branch Code	60445
5	Address Of Bank	ZANZARDA ROAD – JUNAGADH
6	IFSC Code	SBIN0060445

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

	GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gebmail.com	
7	PAN No.	AABCG4029R
8	TAN No.	RKTG00895G
9	GST No.	24AABCG4029R2ZC

Payment of Earnest Money Deposit (EMD) and Tender Fee should be accepted by RTGS/NEFT/Online only along with Tender. Also submit bank payment proof i.e. Bank statement. If possible, please inform to our Account Department for the said payment through phone/email for verification.

- 1. Payment of Tender Fee**
 - Payment of Tender Fees can be accepted by RTGS/NEFT/Online.
- 2. Payment of Earnest Money Deposit (EMD)**
 - Payment of Earnest Money Deposit (EMD) can be accepted by RTGS/NEFT/Online.
- 3. Documents with Bid submission**
 - Bidder has to upload scanned copies of original (Notarized/ Self attested copies of original – as specified in tender documents) documents with bid and no physical documents to be called from bidder.

It shall be sole Responsibility of the bidder that the uploaded scanned documents (in PDF form) remain legible and should not be password protected.

Any technical questions, information and clarification that may be required pertaining to this enquiry should be referred to: **The Superintending Engineer (TR), Gujarat Energy Transmission Corporation Limited. Circle office Junagadh.**

GETCO reserves the right to reject any OR all tenders without assigning any reasons thereof.

Yours faithfully,

**Superintending Engineer
Transmission Circle office
GETCO Junagadh**

To view the PDF file please use “Acrobat Reader” software which can be downloaded from ‘Adobe’ website.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gmail.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
BARODA**

Date :

I N T E G R I T Y P A C T

OUR ENEAVOUR

To create environment where Business Confidence is built through Best Business Practices and is fostered in an atmosphere of trust and respect between providers of goods and services and their users for the ultimate benefit of society a the nation.

GETCO COMMITMENT

- ☐ To maintain the highest ethical standards In business and professional
- ☐ Ensure maximum transparency to the Satisfaction of stakeholders.
- ☐ To ensure to fulfill the terms of agreement / contract and to consider objectively the viewpoint of parties.
- ☐ To ensure regular and timely release of payment on due dates for work done.
- ☐ To ensure that no improper demand is made by employees or by anyone on our behalf.
- ☐ To give maximum possible assistance to all the Vendors / Suppliers / Service provider and other to enable them to complete the contract in time.
- ☐ To provide all information to suppliers/ contractors relating to contract / Job which facilitate him to complete the contract / job successfully in time.
- ☐ To ensure minimum hurdles to Vendors/ suppliers / contractors in complete of agreement / contract / work order.

PARTY'S COMMITMENT

- ☐ Not to bring pressure / recommendations outside GETCO to influence its decision.
- ☐ Not to use intimidation, threat, inducement or Pressure of any kind on GETCO or any of it's employees under any circumstances.
- ☐ To be prompt and reasonable in fulfilling the contract, agreement, legal obligations.
- ☐ To provide goods and / or services timely as per agreed quality and specifications at minimum cost of GETCO.
- ☐ To abide by the general discipline to be maintained in our dealings.
- ☐ To be true and honest in furnishing information including payment to agents / sub-agent.
- ☐ Not to divulge any information, business details available during the course of business relationship to others without the written consent of GETCO.
- ☐ Not to enter into carter / syndicate / understanding whether formal / non-formal so as to influence the price.

**Seal & Signature
(GETCO Authorized Signatory)**

Name :
Designation :

**Seal & Signature
(Party's Authorized Person)**

Name :

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmail.com



ANNEXURE-1 (to be upload online)

Details of the Firm

Name of the Firm

A

1 Address of registered office

2 Contact personnel

3 Designation

4 Residential Address

5 Phone No.

Office

Residential

6 Fax No.

7 Telegraphic code

8 E-mail address

B

1 Address of WORK

2 Contact personnel

3 Designation

4 Residential Address

5 Phone No.

Office

Residential

6 Fax No.

7 Telegraphic code

8 E-mail address

CONTRACTOR SIGNATURE WITH STAMP

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

		GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gmail.com						
ANNEXURE-2 (to be upload online)								
Details of experience in last three years from the due date of tender								
Sr. No.	Name of s/s	Order reference no. & Date	Order value	Nos. of sub-stations/feed er bays	Due date of completion	Actual Date of completion	Order fully executed Yes/No	Status if order under execution
A	Gujarat Energy Transmission Corporation Ltd.							
1								
2								
3								
4								
5								
B	Other state electricity board							
1								
2								
3								
4								
5								
C	Private Firms							
1								
2								
3								
4								
5								

ANNEXURE-3 (to be upload online)			
List of work completion certificate submitted with technical bid			
Sr.No.	Name of work	Name of the authority by whom the work completion certificate issued	Reference No. & Date
1			
2			
3			
4			
5			

CONTRACTOR SIGNATURE WITH STAMP

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

ANNEXURE-4 (to be upload online)

**Qualification Requirement Terms.
Contractor must fill up below details**

TENDER NOTICE No: TCJND/2026-27/N-89

1.	PRICES: [FIRM ONLY] (Please Specify YES / NO.)	
2.	PENALTY TERMS AGREED (Please Specify YES / NO.)	
3.	SECURITY TERMS AGREED: (Please Specify YES / NO.)	
4.	TENDER TERMS AGREED: (Please Specify YES / NO.)	
5.	VALIDITY Of the offer for 180 DAYS From the date of opening of the Technical Bid: AGREED: (Please Specify YES / NO.)	
6.	PAYMENT TERMS AGREED: (Please Specify YES / NO.)	
7.	MOBILE NOS., TELEPHONE NOS. & FAX NO:	
8.	Authorized person of the firm :	
9.	Name of the proprietor, partners, directors [as the case may be], along with address, telephone, fax no. etc.	

Signature of Tenderer

Date :

Place:

Company's Round Seal

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

ANNEXURE-5 (to be upload online)

(UNDERTAKING IN REGARD TO STOP DEAL / BANNED FOR BUSINESS DEALING/ BLACK LIST THEREOF)

Sub: Undertaking in regard to Stop Deal/ Banned for Business dealing/ Black List thereof

Ref: Tender Notice No. **TCJND/2026-27/N-89**

All bidders will have to furnish the following undertaking dully filled in, signed and stamped for each quoted item of the tender along with the Technical Bid.

I/We _____ authorized signatory of M/S _____ here by certify that M/S _____ and their proprietor / any partner / any directors of the firm is not stop deal and / or banned for business dealing and / or black listed by GUVNL and / or their any subsidiary company viz. GSECL / GETCO / DGVCL / MGVL / UGVCL / PGVL.

Seal of the Firm

Signature of the Tenderer

Date :

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

ANNEXURE-6 (to be upload online)

UNDERTAKING IN RESPECT OF REFERENCE TO NCLT UNDER INSOLVENCY & BANKRUPTCY CODE

Subject: - Undertaking in respect of reference to nclt under insolvency & bankruptcy code

Name of Work: 'Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh'.

Tender No. TCJND/2026-27/N-89

In connection with above subject, I / We confirm that our firm is not declared in NCLT under Insolvency & Bankruptcy Code. Further, I / We also agree that, if any found NCLT under Insolvency & Bankruptcy Code, the offer shall be out rightly rejected without assigning any reason thereof.

(Seal, Sign & Name of Authorized Signatory of Bidder)

Date :

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

ANNEXURE-7 (to be upload online)
Declaration Of Conflict On Interest
(On the letter pad of the company)

To
The Superintending Engineer
Gujarat Energy Transmission Corporation Limited.,
Circle Office, Dhandhusar road, Opp. Nandbava Gaushala,
66KV Zanzarda substation,
Junagadh – 362 015

Subject: - Declaration Of Conflict On Interest

Reference: Tender Notice No: **TCJND/2026-27/N-89**

Anent to the above subject & reference tender notice no. For the work of '**Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh**'.

We do not have any conflict of interest with any other bidder who has submitted the bid in this tender.

Yours Faithfully,

(Seal, Sign & Name of Authorized Signatory of Bidder)

Date :

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

ANNEXURE -8 (to be upload online)
No deviation certificate
(On the letter pad of the company)

Name of Work: 'Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh'.

Sub: **No deviation certificate**

Reference: Tender Notice no. : **TCJND/2026-27/N-89**

In connection with the above subject and reference, I/ We confirm the following:

1. I / We, the under signed have read and examined the Tender Specifications in tender mentioned under reference along with the Commercial terms and conditions.
2. I / We, declare that our Technical Bid is strictly in line with the Tender specifications.
3. Further, I /We also agree that additional conditions / deviations, if any, found in the commercial terms & conditions, our offer shall be out rightly rejected without assigning any reason thereof.

(Seal, Sign & Name of Authorized Signatory of Bidder)

Date:

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

ANNEXURE -9
Declaration Relationship with employee
(On the letter pad of the company)

ANNEXURE -10
UNDERTAKING FOR LABOUR LAWS
(On the letter pad of the company)

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

QUALIFICATION REQUIREMENT

1) REGISTRATION:

The bidder shall be strictly a GETCO registered contractor.

2) TECHNICAL CRITERIA

The bidder should satisfy following minimum technical requirements....

1. Bidder shall have executed minimum **01 No of 66/11KV substation** with state or Central Transmission Utility or major industries OR **03 Nos of 66KV bays** i.e. Transformer / Feeder Bays at same or different locations. Substations include minimum **02 Nos of feeder bays, 01 No of Transformer bay, as a Main contractor only.** (Bidder have to upload Work order & Work Completion certificate 3A form scanned copy as Experience in online Technical bid)
2. Electrical contractor's license with latest validation

3) FINANCIAL CRITERIA

1. Payment of Tender fee and EMD.
2. GST registration certificate.
3. Details of Partners/Directors of the Firm/Company. Partnership deed if applicable.
4. Copy of power of attorney as the case may be.
5. PF registration
6. Latest Bank solvency certificate of 20% of the tender value is required to be furnished by the tenderer along with the technical bid.
7. The Bidder should have to submit copy of PAN card.
8. Last 3 year Income Tax return.
9. Under Undertaking in respect of reference to NCLT under Insolvency & Bankruptcy Code.
The undertaking is to be furnished by the bidder in its bid as per the format attached and shall be deemed to be part of the bidding schedule and submitted along with QR Bid.
10. Declaration regarding Relationship with employee, as per SPECIAL COMMERCIAL CONDICATION Clause no.5

4) ANNEXURE - 1 to 10 (All Declaration should be submitted as duly signed copy instead of just fixing image of signature on all the declaration).

5) Duly signed copy of Tender document.

- All documents, which are mention in Qualification Requirements are must be submitted online only. No physical bid accepted.

NOTE: IF BIDDER FAILED TO SUBMIT ONE OF THE ABOVE DOCUEMNTS ALONG WITH THE ONLINE TECHNICAL BID, THEIR BID WILL BE REJECTED WITHOUT INTIMATION TO CONTRACTOR & PRICE BID WILL NOT BE OPEN. PRICE BID OF ONLY THOSE BIDDERS WILL BE OPEN WHO WILL 100% TECHNICALLY QUALIFIED AS PER OUR TERMS AND CONDITIONS. HENCE, BEFORE QUOTE THE BID, BIDDER HAVE TO ENSURE THAT ALL THE DOCUMENTS ARE SUBMITTED ONLINE ALONG WITH TECHNICAL BID.

CONTRACTOR SIGNATURE WITH STAMP

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

SCOPE OF WORK

1. The Scope of the proposal shall be on the basis of a single Bidder's responsibility, completely covering all the services specified under the accompanying Technical Specifications.
2. The Bidder shall complete all the schedules & annexure in the Bid Proposal Sheets, technical Data Sheets and specified elsewhere and submit scan copy in online.
3. The scope of work is **"Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh."** as per standard specification and standard practice of GETCO and as per EIC.
4. The above work shall be done as per GETCO's approved drawing/layout.
5. Necessary field quality plan of GETCO shall be implemented and necessary documentation shall also be maintained as per GETCO's norms and instruction of EIC. If required field quality plan shall be available at field offices.
6. During the work of erection of feeder bay/transformer bay/ Line, safety check list shall be followed. Necessary check list will be available at our field office.
7. Successful bidder has to appoint site Engineer to maintained site register & FQP as per ISO.
8. All work should be done accordingly to ISO & FQP and all require documents including Filled FQP, testing results etc. should be submitted while handing over the completed work.
9. The quantity mentioned in price bid is tentative and may vary in actual work order.

CONTRACTOR SIGNATURE WITH STAMP

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



SAFETY CLAUSE

1. The Contractor shall follow and comply with all GETCO Safety Rules, relevant provisions of applicable laws pertaining to the safety of workmen, employees, plant and equipment as may be prescribed from time to time without any demur, protest or contest or reservations. In case of any discrepancy between statutory requirement and GETCO Safety Rules referred above, the latter shall be binding on the Contractor unless the statutory provisions are more stringent.

1. In case if any safety related fatal Elect. / Mech. accident occurred to any employee of agency or outsider due to negligence or non-compliance of GETCO safety norms then in addition to the compensation and liability as per statutory requirement, contractor / agency shall be penalized as under:

Sr. No	Amount of Contract in Rs.	Penalty amount per person
1	Up to →1 Lac	Rs.5000/- plus GST as applicable
2	Above1 Lac to → 10 Lacs	Rs.25000/- plus GST as applicable
3	10 to → 100 Lacs	Rs.100,000/- plus GST as applicable
4	> 100 Lacs	1.0 % plus GST as applicable

2. **Reporting:-**

1. The contractor shall inform concerned Ex. Engineer Const/TR in writing within 24 hours of fatal/Non-fatal accident occurred to human being.
2. The GETCO investigating officer findings in to accident shall be final and binding to the contractor /Agency.

3. **Safety Requirement:**

- i) Kick off Meeting exclusively for safety shall be done in each contract in presence of contractor's site in charge and supervisor. Safety document shall be handed over and vital safety norms and key points of safety related to project shall be explained and recorded for commitment by erection contractor. Such records are mandatory for clearing first erection bill.
- ii) During site visit by GETCO official of Executive Engineer and above rank, the following checks during execution of work shall be covered.
 - I. Safety equipment available and utilize.
 - (a) Helmet.
 - (b) Safety belt.
 - (c) Safety shoes.
 - (d) Live line Voltage detector
 - II. Safety procedure adopted.
 - (a) Permit to work
 - (b) Earthing at the place of work.
 - (c) Adequate supervision.
 - III. T & P physical Check. (Healthiness and Quality)
 - (a) P.P. rope.
 - (b) Wire rope and sling.
 - (c) Earthing rod
 - IV. If above-mentioned safety requirements found violated in any of the above three conditions shall attract penalty of Rs.1000/- plus GST as applicable per occasion. (Max.Rs.3000/-for violation of three conditions)
 - V. During subsequent visit, if violation is found, then double penalty plus GST as applicable shall be deducted from the bill of the Contractor/Agency.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

WORK & SAFETY REGULATIONS

1. The contractor shall ensure proper safety of all the workmen, materials, equipment & plant & belonging to him or to GETCO or to others, working at the site. The contractor shall also be responsible for provision of all safety notices and safety equipment required both by the relevant legislations and Engineer, as he may deem necessary.
2. Contractor has to provide ISI marked ELCB / MCB having sufficient capacity of standard make at point of supply.
3. All equipment used in construction and erection by contractor shall meet Indian/International Standards and where such standards do not exist, the contractor shall ensure these to be absolutely safe. All equipment shall be strictly operated and maintained by the contractor in accordance with manufacturer's operation manual and safety instructions and as per guidelines/ rules of GETCO in this regard.
4. Periodical examinations and all tests for all lifting/ hoisting equipment & tackles shall be carried – out in accordance with the relevant provisions of Factories Act 1948, Indian Electricity Act 1910 and associated Laws/Rules in force from time to time. A register of such examinations and tests shall be properly maintained by the contractor and will be promptly produces as and when desired by Engineer or by the person authorized.
5. The contractor shall provide suitable safety equipment of prescribed standard to all employees and workmen according to the need.
6. The contractor shall provide safe working conditions to all workmen and employees at the site including safe means of access, railings, stairs, ladders, scaffoldings etc. the scaffoldings shall be erected under the control and supervision of an experienced and competent person. The contractor only shall use good and standard quality of material.
7. The contractor shall not interfere or disturb electric fuses, wiring and other electrical equipment belonging to the owner / other contractors under any circumstances, whatsoever, unless expressly permitted in writing to handle such fuses, wiring or electrical equipment.
8. Before the contractor connects any electrical appliances to any plug or socket belonging to the other contractor or owner, he shall:
 - a. Satisfy the Engineer that the appliance is in good working condition;
 - b. Inform the Engineer of the max. current rating & voltage of the appliances;
 - c. Obtain permission of the Engineer detailing the sockets to which the appliances may be connected.
9. The Engineer will not grant permission to connect until he is satisfied that;
 - a. The appliance is in good condition and is fitted with suitable plug
 - b. The appliance is fitted with a suitable cable having two earth conductors, ones of which shall be an earthed metal sheath surrounding the cores.
10. No electric cable in use by the contractor/ Owner will be disturbed without prior permission. No weight of any description will be imposed on any cable and no ladder or similar equipment will rest against or attached to it.
11. No repair work shall be carried out on any live equipment. The equipment must be declared safe by the Engineer and a permit to work shall be issued by the Engineer before any repair work is carried out by the contractor. While working on electric lines/ equipment, whether live or dead, suitable type and sufficiently quantity of tools will have to be provided by the contractor to electricians/ workmen/ officers.
12. In case any accident occurs during the construction/ erection or other associated activities undertaken by the contractor thereby causing any minor or major fatal injury to his employees due to any reason, whatsoever, it shall be the responsibility of the contractor provide medical facility / treatment & to promptly inform the same to the Engineer in prescribed form and to also to all the authorities envisaged under the applicable laws.
13. The Engineer shall have the right at his sole discretion to stop the work, if in his opinion the work is being carried out in such a way that it may cause accidents and endanger the safety of the persons and/or property and/or equipment. In such cases, the contractor shall be informed in writing about the nature of hazards and possible injury/ accident and he shall comply to remove shortcomings promptly. The contractor after stopping the specific work can, if felt necessary, appeal against the order of stoppage of work to the Engineer within 3 days of such stoppage of work and decision of the Engineer in this respect shall be conclusive and binding on the contractor.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



14. The contractor shall not be entitled for any damages/ compensation for stoppage of work due to safety reasons and the period of such stoppage of work will not be taken as an extension of time for completion of work and will not be the ground for waiver of levy of liquidated damages.
15. it is mandatory for the contractor to observe during the execution of the works, requirements of safety rules which would generally include but not limited to following;
 - a. Each employee shall be provided with initial indoctrination regarding safety by the contractor, so as to enable him to conduct his work in a safe manner.
 - b. No employee shall be given a new assignment of work unfamiliar to him without proper introduction as to the hazards incident thereto, both himself & his fellow employees.
 - c. Employee must not leave naked fires unattended, smoking shall not be permitted around fire prone areas and adequate fire fighting equipment shall be provided at crucial location.
 - d. There shall be a suitable arrangement at every work site for rendering prompt and sufficient first aid to the injured.
 - e. Requirements of ventilation in underwater working to licensed and experienced divers, use of gumboots for working in slushy or in inundated conditions are essential requirements to be fulfilled.
16. The contractor shall follow and comply with all GETCO safety Rules, relevant provisions of applicable laws pertaining to the safety of workmen, employees, plant and equipment as may be prescribed from time to time without any demur, protest or contest or reservations. In case of any discrepancy between statutory requirement and GETCO safety rules referred above the latter shall be binding on the contractor unless the statutory provisions are more stringent.

a. Fatal injury or accident Causing death	Rs. 1,00,000/- per person for death/	These are applicable
b. Major injuries or accident causing 25% or more permanent disablement To workmen or employees	Rs. 20,000/- per person	injury to any person,

Permanent disablement shall have same meaning as indicated in workmen's compensation Act. The compensation mentioned above shall be in addition to the compensation payable to the workmen/ employees under the relevant provisions of the laws as applicable from time to time. In case the owner is made to pay such compensation then the contractor is liable to reimburse the owner such amount in addition to the compensation indicated above.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

ANNEXURE-A

OUR ENDEVOUR - Safety a habit

To create environment where Business Confidence is built through Best Business Practices and is fostered in an atmosphere of trust and respect between providers of goods and services and their users for the ultimate benefit of society a the nation, safety guidelines are agreed upon by the agency as under.

Safety is our prime concern and zero accident is our goal. In order to prevent the accident, while execution of works in indoor and outdoor systems of GETCO, the following guideline and preventive measures are identified.

Indoor safety precaution	Outdoor safety precaution
The method of work required T&P and manpower should be discussed between GETCO supervisor, contractor's supervisor and gang leaders.	The method of work required T&P and manpower should be discussed between GETCO supervisor, contractor's supervisor and gang leaders.
Prior to execution of work a joint survey must be conducted by GETCO supervisor and contractor's supervisor for risk assessment. - Clearly identify the work location, to distinguish between the equipment that is dead and other equipment / part that maybelive. - Disconnect equipment from supply. - Protect against other live parts. - Take special precautions when close to bare conductors/Busbar.	Prior to execution of work a joint survey must be conducted by GETCO supervisor, contractor's supervisor and DISCOM line man in order to identify the following : - HT/LT line or tap line crossing under each span of line of the work. - Isolation point of each line crossing. - Each line crossing & isolation point under each span must be discussed and noted in maintenance register with sketch.
Following safety guidelines are mandatory for all contractors operating in GETCO premises for Electrical, non-electrical & civil works. - The contractors must provide advance planning of work to concerned in-charge of substation in writing. - Before starting any work whether switch yard, "permit to allow to work" must be taken from control room in-charge. - Utilizing Electrical / non-electrical equipments, safety rules must be implemented. - If the work is to be carried out on Sunday or public holiday, the necessary permission must be taken in advance, requesting in writing. - Unwanted person including children of labours will not be allowed at working site/ in the switchyard and in the prohibited area. - Any electrical work or electrical connections to equipment for any other work must be carried out by certified	Contractor's supervisor and GETCO Supervisor must ensure all isolations physically with adequate earthing technically prior to give clearance to gang leader for taking up job. While execution of stringing work, the identified line crossing must be isolated / de-energized and written clearance should be obtained from concerned DISCOM supervisor. The isolation of Tap line must be physically seen and verified by Contractor and GETCO supervisor. At D.O. fuse junction contractors person should be posted to ensure that no person restore D.O. supply while work is under execution Contractor's supervisor must ensure that concern officer take LCP for EHV line and power line crossing.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



electrician/wiremen with adequate size of wire through MCB as per I.E. Rule. - Live penal area / bus bar must be isolated and sealed / bifurcated with red colour tape for visible warning. - Display Board must hang on LCP panel. - Transformer must be switched off whenever and wherever contractor and line workers are not satisfied with isolation, earthing or any equipment performance of GETCO, it will be pointed out and work shall begin only after resolution. Contractor shall not take up job in absence of GETCO authorized person. All wire temporary connection & material whenever erection activity has any connection and disconnection work of bus bar, string bus.	
All workers / labour of contractor & supervisors must use personal protective equipment (PPE) during the work like gloves, safety belt, Safety shoes, Helmet, earthing rods, etc, duly approved by GETCO.	All workers / labour of contractor & supervisors must use personal protective equipment (PPE) during the work like gloves, safety belt, Safety shoes, Helmet, earthing rods, Live line detector etc, duly approved by GETCO.
The local earthing must be done at the place of work before execution of any work.	The local earthing must be done at the place of work before execution of any work.
11 kV breaker in panel must be switched off and racked out only after ensuring no voltage in breaker and without door opening.	Circuit breaker opening is not an isolation and isolator on either side must be opened. No work during rains and cloudy weather condition.
	Transmission line activities. 1) Used of Voltage detector to ensure outage. 2) Earthing at three point, local, left & right side of bus bar / string bus. 3) Match line colour code with colour of wrist band.
	Local earthing of electrical equipments like filter M/c, welding machine, testing kits etc. is must. Crane shall only be used for material handling and erection. Working platform shall only be used for work in switchyard.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

GENERAL COMMERCIAL CONDITIONS

1. The Gujarat Energy Transmission Corporation Ltd., Junagadh hereinafter called 'GETCO' 'OWNER' intends to receive bids for **'Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh'** detailed in the accompanying specifications in accordance with Terms and Conditions herein. The bids shall be prepared and furnished as per these instructions.
2. **The validity of tender is 180 days from the date of opening of technical bid**
3. **Earnest Money Deposit :**
 - a. Bidders are requested to pay an earnest money deposit (1% of estimated cost plus GST as applicable) by **RTGS/NEFT/Online only** on any Nationalized Bank at GETCO Junagadh for the amount as specified in the tender notice.
 - b. **EMD in form of DD/Banker's Cheque/Pay Order is not allowed. If bidder submit the DD/ Banker's Cheque/Pay Order for Tender Fee and EMD, in that case the same tender will not be considered.**
 - c. Tenders no accompanied by EMD shall be rejected.
 - d. If during the tender validity period, i.e. 180 days, the tenderer withdraws his tender, the EMD shall be forfeited and the tenderer may be disqualified from tendering for future works of GETCO.
 - e. The EMD will be returned promptly to the unsuccessful tenderer. The EMD will be returned to the successful tenderer after he furnishes the Security Deposit for performance and duly enters into the contract. If he fails to furnish the SD or to execute the contract for the work offered to him, his EMD shall be forfeited and the tenderer may be disqualified from tendering for further works for GETCO.
4. All commercial terms and conditions except rates shall be indicated in the technical & commercial bid only.
5. The Tenderers shall specifically note that the Tenders are invited on percentage basis only.
6. Arithmetical error will be rectified on the following basis:
 - a. If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected. If there is a discrepancy between the total bid amount and the sum of total costs, the latter shall prevail and the total bid amount will be corrected accordingly. If there is a discrepancy between work and figures, the amount advantageous to the Owner will prevail. If the bidder does not accept the correction of the errors as above, his bid will be rejected and the amount of EMD will be forfeited. The bidder should ensure that the prices furnished in various price schedules are consistent with each other.
 - b. In the case of any inconsistency in the prices furnished in the specified prices schedules to be identified in Bid Form, the Owner shall be entitled to consider the highest price for the purpose of evaluation and for the purpose of award of Contract use the lowest of the prices in these schedules.
 - c. Prior to the detailed evaluation, the Owner will determine the substantial responsiveness of each bid to the Bidding Document. For purpose of these Clauses, a substantially responsive bid is one which conforms to all the terms and conditions of the Bidding Document without material deviations. A material deviation is one which affects in any way the prices, quality, quantity or delivery period of the equipment, completion of works or which limits in any way the responsibilities or liabilities of the Bidder of any right of the Owner as required in these specifications and documents. The Owner's determination of a bid's responsiveness shall be based on the contents of the bid itself without resource to extrinsic evidence.
 - d. A bid determined as not substantially responsive will be rejected by the Owner and may not subsequently be made responsive by the Bidder by correction of non-conformity.
7. The tenderers will ensure submission of the Tenders duly filled and uploaded online before the due date and time.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



8. **Security deposit:** - The contractor will have to pay the Security Deposit at 5% of the order value on placing the LOI, The contractor will have to pay **entire S.D. i.e. 5% by demand draft in the name of 'GUJARAT ENERGY TRANSMISSION CORPORATION LTD'** within 10 days from the date of the issue of LOI, and higher percentage of security deposit may be fixed at the direction of The Superintending Engineer. Alternatively, you may pay the entire S.D. in the form of B.G.as per approved format of the GETCO issued by Nationalized/Scheduled Bank. **If SD amount is less then Rs 100000/- (Rupees One lakh) only DD will be acceptable.**

DD/B.G. issued by some co-operative bank is acceptable for S.D. as per listed under

a. Guarantees issued by following Banks will be accepted as SD on permanent basis;

1. All Nationalized Banks.

b. Guarantees issued by following Banks will be accepted as SD/EMD for the period up to **31.03.2027**. The validity cut-off date in GR is with respect to date of issue of Bank Guarantee irrespective of date of termination of Bank Guarantee.

1. **AXIS Bank**
2. **AU Small Finance Bank**
3. **Bandhan Bank**
4. **City Union Bank**
5. **CSB Bank**
6. **DBS Bank India Limited**
7. **DCB Bank**
8. **Dhanlaxmi Bank**
9. **Equitas Small Finance Bank**
10. **FEDERAL Bank**
11. **HDFC Bank**
12. **HSBC Bank**
13. **ICICI Bank**
14. **IDBI Bank**
15. **IDFC First Bank**
16. **IndusInd Bank**
17. **Jammu and Kashmir Bank**
18. **Jana Small Finance Bank**
19. **Karnataka Bank**
20. **Karur Vysya Bank**
21. **Kotak Mahindra Bank**
22. **RBL Bank**
23. **South Indian Bank**
24. **Standard Chartered Bank**
25. **Tamilnad Mercantile Bank**
26. **Ujjivan Small Finance Bank**
27. **YES Bank**
28. **Ahmedabad Mercantile Co-Op Bank**
29. **Nutan Nagrik Sahkari Bank Ltd.**
30. **Rajkot Nagrik Sahkari Bank Ltd**
31. **Saraswat Co-Operative Bank Ltd**
32. **SBPP Co-operative Bank Ltd.**
33. **SVC Co-Operative Bank Ltd.**
34. **The Cosmo Co-Op Bank Ltd.**
35. **The Gujarat State Co-Operative Bank**
36. **The Surat District Co-Operative Bank**
37. **The Surat People's Co-Op. Bank Ltd**
38. **The Baroda Central Co-operative Bank**
39. **The Panchmahal District Co-Operative Bank**
40. **The Kalupur Commercial Co-Op. Bank**
41. **The Rajkot Commercial Co-operative Bank**
42. **The Banaskantha Mercantile Co-op. Bank**

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

43. Gujarat Gramin Bank

Bank Guarantee of other than above mentioned banks towards, Performance Bank Guarantee for Supply, Erection & Warranty will not be acceptable.

The security deposit will be refunded only after issuance of NOC for completion of work by In-charge engineer, completion of guarantee period of 1 year for work done related to Schedule- B1, Schedule -B2, Schedule -B3 & Schedule- B5 (except Schedule-B4: CCTV Camera Surveillance System) or finalization of final bill And on submission of Performance Guarantee of Three years for work related to Schedule-B4 (i.e CCTV Camera Surveillance System) whichever is later.

9. SECURITY DEPOSIT-CUM-PERFORMANCE GUARANTEE DEPOSIT for CCTV Camera Surveillance System:

- The successful bidder has to submit the security deposit-cum-performance deposit by DD / Bank Guarantee within **15 days of issuance TOC by In-charge engineer & on commission of CCTV Camera Surveillance System.**
- The successful bidder will be required to pay an amount equivalent to 10% of the value of **Schedule-B4** (END cost) as a Security Deposit for satisfactory execution of the contract and as performance guarantee. Such Security Deposit will be payable either in DD payable at Vadodara / Bank guarantees from Scheduled / Nationalized Banks will be acceptable. The Bank Guarantees furnished should have clear one-time validity till the completion of the order in all respect and up to the expiry of the Guarantee period of **37 Months (i.e. 36 Months + 1 Month) from the date of Commissioning of CCTV camera Surveillance system.** Bank Guarantee for interim period will not be allowed. If by any reason the contract period is extended, then contractor should undertake to renew the Bank Guarantee at least one month before the expiry of the validity failing which Board will be at liberty to redeem the same, without entering into further correspondence in the matter.
- No interest will be allowed on amount of Security deposit.
- The Security Deposit-cum-performance Guarantee deposit as above on total shall be kept deposited up to 3 years from the date of commissioning of CCTV camera surveillance system.
- This security deposit is for the performance of contract and the same is liable to be forfeited by the GETCO in event of non-fulfillment of the term and conditions of this contract by the contractor.
- Corporate Guarantees are not admissible.

10. BG CONDITIONS

- A) The bank guarantee should have clear one-time validity till the completion of facilities in all respect. Bank guarantee for interim period will not be allowed. If for any reason, the contract period is extended, the contractor should undertake to renew the bank guarantee at least one month before the expiry of the validity, failing of which corporation is at liberty to redeem the same, without entering in to further correspondence in the matter.
- B) There should be a "claim period" of at least one month after expiry of the Bank Guarantee.
- C) For lodgment of claim for invocation of bank guarantee, the clause should specifically state that the said BG can be presented at the local branch of the issuing bank.
- D) For Invocation of BGs, a written application from the GETCO should be sufficient for lodgment of concern office's claim.

11. **Contract Period :-** The time allowed for completion the work is **03 (Three) month** from the date of the commencement of the work, failing which the penalty ½% per week or part thereof plus GST as applicable on delayed portion of work and / or supply value subject to ceiling of 10% of the total contract value plus GST as applicable will be imposed.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

12. The time limit for the work may be reduced and contractor should make all his efforts to complete the work within stipulated time limit as may be given by the Engineer in charge depending upon emergency of work, GETCO reserves the right to reduce the time limit without giving any notice.
13. **GST :-**
- Contractor has to submit the GST Registration certificate
 - Contractor should be registered under GST laws which they shall pay the GST for this contract.
 - Contractor has to submit invoice/Challan as documentary proof with each RA bill & Final Bill and in which it shall be specifically mention the nature of service SAC code under which the amount of GST payable by contractor and payable by GETCO (if any)) without fail.
 - GETCO will withheld the GST amount of contractor and it shall be reimbursed on production of documents evidences of payment made by contractor.

The Contractor has to submit invoice to GETCO indicating following;

Name, address and GST registration no. of the service provider Name and address of person receiving the service i.e. GETCO Description and value of taxable service provided. The total GST payable thereon with bifurcation of GST payable by service provider and service receiver.

- Contractor has to also supply tax invoice as described under GST rules and Regulation indicating GST No.

PRICES:

If the Supplier/Contractor has opted for the Composition scheme of GST, the same must be clearly specified with valid Declaration & Certificate from Department. In the event of withdrawal/cessation of the Supplier from Composition scheme during the tenure of the contract, the rate (i.e. price) mentioned in the price bid shall be final and any additional GST will have to be borne by the tenderer himself. In no case additional amount towards GST or otherwise will be paid / reimbursed to supplier/contractor. Further Statutory Variation clause will not be applicable in case of Supplier / Contractor has opted for Composition Scheme under GST.

Also, please mention separate applicable HSN / SAC Code and rate of GST and Cess as applicable for each item of Goods/Service. If not specifically mentioned, then COMPANY will have the option to take the prices as exclusive of taxes and duties at maximum higher slab rates for the evaluation of the tenders.

The offers having price INCLUSIVE OF GST and Cess is likely to be rejected if the rate of GST and Cess is not mentioned clearly unless the bidder has opted for Composition Scheme under GST Act, which should be clearly indicated in the price bid. COMPANY may at its discretion consider such offer with presumption of highest applicable rate of VAT/GST/Cess prevailing when the price quoted is inclusive of GST and Cess.

The offered prices to be indicated in online mode of tender in the format given (i.e. Schedule-B). The price bid submitted in physical mode shall not be considered.

Every bidder shall inform their GSTIN No. of the registered place(s) wherefrom the bidder intends to supply the goods / services, meaning thereby the bidder has to supply the goods / services from the relevant declared / registered place of supply only.

Goods and Service Tax (GST) :

The F.O.R. Destination prices are including GST and Cess as applicable which will be paid extra on a given taxable goods and/or services within the original contractual delivery period. The amount of GST, Percentage (%) of GST and Cess as applicable should clearly be indicated separately. (GST/Cess means all applicable Tax/Cess under GST Laws. GST Laws means IGST Act, GST(Compensation to the State for Loss of Revenue) Act, CGST Act, UTGST Act and SGST Act, 2017 and all related ancillary legislations).

You shall have to submit a C.A Certificate & duly authorized Signatory of successful bidder, certifying that you have not claimed Refund of any applicable GST and Cess, charged to COMPANY or shall not claim

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

any such Refund, on a future date, from the concerned Authorities and if, any Refund, in respect of such GST and Cess, is claimed by you, it will be immediately passed on to the COMPANY, without COMPANY making any specific Claim, for the same, either from the Department or from you.

If the Supplier/Contractor has opted for the Composition scheme of GST, the same must be clearly specified with valid Declaration & Certificate from Department. In the event of withdrawal/cessation of the Supplier from Composition scheme during the tenure of the contract, the rate mentioned in the price bid shall be final and any additional GST will have to be borne by the tenderer. In no case additional amount towards tax or otherwise will be paid / reimbursed to supplier/contractor. Further Statutory Variation clause will not be applicable in case of Supplier / Contractor has opted for Composition Scheme under GST.

Contractor has to provide Tax invoice in a standard format as per CGST act, CGST rules 2017 and GST invoicing rules containing all details as provided Act and rules. Contractor / Supplier has to mentioned GST no. of GETCO **24AABCG4029R2ZC** in the invoice invariably failure of which payment will not be made.

GST at the applicable rate will be levied on the total of schedule B. GST will be subject to CGST, SGST, UTGST, IGST act and rules, regulation and notifications issued by government from time to time. Contractor has to classify the supply / services according to the HSN / SAC of CGST Act, 2017. GETCO also reserve the right of classification in case of any misclassification of goods / services.

Further, any additional liability of GST (later on due to wrong mentioning of GST rate, mis-interpretation of HSN/SAC Code, etc.) over and above as charged in the invoice shall be borne by the Supplier/Contractor. However, any refund received by the supplier / contractor on account of GST charged from the company; such refund shall have to be passed on to the company, along with interest if any. Such refund along with interest needs to be passed on suo-moto by the supplier / contractor.

The amount of GST in the invoice will be reimbursed subject to matching of transaction in GST return. In case of mismatch, amount of GST will be retained from the subsequent invoice of the contractor. For final bills, GST will be retained and reimbursed on matching the same in GST return and after receipt of request from the contractor.

Further, the Company has a right to recover the amount of GST along with penal interest at the rate of 15% per annum if GST charged is not paid / short paid to the government or fail to upload the details or uploads inaccurate particulars on GSTIN portal by the Supplier / Contractor within the stipulated time limit.

GST TDS 2% Deducted on basic amount If applicable (w.e.f from 01.10.2018.)

In case, Govt. revises the rate of GST rate / Code during the tenure of the contract, the provision of GUVNL's statutory variation clause shall apply.

INPUT TAX CREDIT BENEFIT :

In the event of any statutory increase in the rate of Input Tax Credit and / or due to inclusion of any other additional item of their inputs / input services under the ambit of the Input Tax Credit provisions under the GST Act, subsequent to the date of submission of the offer, the same should be passed on to COMPANY and you should inform such changes to COMPANY from time to time.

GST Registration on GETCO's web portal:

The Bidder should have to take registration under the "GOODS AND SERVICE TAX(GST)". Bidder has to register online in given link before bidding. Link for the same is www.getcogujarat.com/gst. The certified Xerox copy of such registration shall have to be submitted along with the bid by the bidder.

On forfeiture of EMD, SD or guarantee under the terms and conditions of this tender, applicable GST will also be recovered from the bidder / contractor and GETCO reserves all rights of such recovery of such forfeited amount along with GST.

PENALTY FOR DELAY / RECOVERY (if applicable)

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

The completion time allowed for carrying out the work should be strictly observed. For any delay, penalty will be levied at the rate of ½ % per week or part thereof on delayed portion of the work subject to ceiling of 10% of total contract value plus GST as applicable will be imposed. If any recovery is applicable as per GETCO's rules and regulation, it will be deduct along with GST will be imposed (if applicable).

In event of failure of the contractor to pay the amount of penalty as demanded, the Owner shall be entitled to deduct the amount of penalty for delay from the amounts payable under any other contract with the GUVNL and its subsidiary companies i.e. GETCO, GUVNL, GSECL, MGVL, DGVCL, PGVCL, UGVCL. It is permissible for the owner to adjust the amount of Penalty of delay against any bank Guarantee furnished by the contractor under this contract or any other contract with GUVNL and/or its subsidiary companies.

STATUTORY VARIATION:

Any statutory increase or decrease in the taxes and duties including GST and Cess as applicable or in the event of introduction of new tax/cess or cessation of existing tax/cess subsequent to suppliers offer if it takes place within the original contractual delivery date will be to COMPANY's account subject to the claim being supported by documentary evidence. However, if any decrease takes place after the contractual delivery date, the advantage will have to be passed on to COMPANY.

Statutory Variation clause will not be applicable in case of Supplier / Contractor has opted for Composition Scheme under GST.

14. WELFARE CESS:-

1. As per the Welfare Cess Act, the welfare cess @ 1% is applicable on supply and erection items for supply, erection, testing & commissioning of substation, transmission lines, EPC/Turnkey projects, and civil works.
 2. Contractor shall get registered under Welfare Cess Act before commencement of work in required head as per nature of work. Office of the Factory Inspector is authorized at present as a registering authority.
 3. GETCO shall pay the welfare cess by way of reimbursing to contractors on production of documentary evidence of payment. Registration charges will not be reimbursed.
 4. The contracts for which supply or part supply of material are in the scope of GETCO, then contractors shall deposit welfare cess on estimated cost of supplied items to GETCO on progressive basis of utilization. As this part of welfare cess is on GETCO account, the same shall be reimbursed to the contractor on receipt of request letter along with documentary evidence of payment. For calculation of welfare cess on supply part, valuation as per MR shall be taken and informed to the contractor for payment. This will be over and above the A/T value. The modality of payment/ reimbursement of welfare cess will be as under.
 5. On receipt of A/T, the contractor / bidder will get them registered under Welfare Cess Act and submit the documentary evidence to the concern office. Copy of Registration certificate shall be submitted before submission of 1st RA bill
 6. Before release of payment of first R.A.Bill, the contractor has to submit the documentary evidence of registration. Only thereafter, the bill will be processed for payment.
 7. Before release of payment of subsequent R.A.Bills, the contractor has to submit the documentary evidence of payment of welfare cess of previous R.A.Bill.
 8. The welfare cess shall be reimbursed to the contractor on submission of copy of documentary evidence of payment by observing due formalities.
- 15. GST & welfare tax shall be reimbursed on production of proof of such payments made by the contractor to the appropriate department as per GETCO & Govt's rules.**
- 16. The contractor will have to give indemnity bond on Non-judicial Stamp paper of value Rs. 300/- to GETCO for material as per attached format. The cost of stamp paper will be born by the contractor.**
- 17. Also the successful bidder will have to execute Agreement on stamp paper of value Rs.300/- at our Circle office Junagadh before commencement of works as per GETCO's prescribed Performa. The cost of stamp paper will be born by the contractor.**
- 18. The contractor will have to give safety cum indemnity on Non-judicial Stamp paper of value Rs. 300/- to GETCO against any possible claim of compensation for damage to contractor's staff or any of third party during the execution of work. The cost of stamp paper will be born by the contractor.**

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

19. **Guarantee period:** - It is the responsibility of the contractor to handover the complete work free of all defects. If within a period of one year from the date of handing over the work, if it is noticed that any defects occurs due to bad workmanship, it is the duty of the contractor to rectify / replace the same at his own cost. If within seven days from the date of receipt of such notice, the contractor does not take up the work, same will be carried out at his risk and cost.

Guaranty Period for CCTV camera surveillance system: Total material supplied and work executed shall be covered under guarantee period against any defect in materials, poor workmanship or defect/ wrong design etc. for a warranty period of 36 months (03 years) from the date of Commissioning of CCTV camera surveillance system.

In the event any defect is found or developed in the system within guarantee period, shall be rectified/replaced by the Empaneled Agency at his own expense promptly.

In case the defects are not rectified within 7 (seven) days of the receipt of the complaint, GETCO shall have full liberty to rectify such defect or undertake such repairs as may be necessary to restore the system in working condition at the risk and cost of the Empaneled Agency.

The expenditure so incurred by GETCO shall be deducted from pending claims, security, etc. and if necessary may be recovered in other mode provided under the law. In the event of failure of the complete system, if necessary, the whole system shall be replaced by the Empaneled Agency promptly.

20. 10% retention money will be deducted from each R.A. Bills against material issued to contractor.
21. 10% amount of bill will be retained from each RA bill for the work executed after the scheduled date of completion and on finalization of time limit extension by competent authority, this amount will be released after deducting amount towards the time limit penalty plus GST as applicable if any.
22. As regard damage the materials, equipment and worker of the contractor, he himself will be responsible. If there is any compensation to be paid in respect of "WORKMAN" compensation act of any other statutory provisions, the same will have to be paid by the contractor direct. If he thinks fit he may take necessary insurance cover, at his cost.
23. The quantum of the work as mentioned in estimate/ schedule –'B' is tentative and it can be varied or differed as per site condition. The payment shall be made only on actual work executed or order quantity, whichever is less.
24. The tenderer will be abided by and fulfill all the terms and provisions of the "Tender & Contract" for works as applicable and incase of any default there to the GETCO shall forfeit the S.D. or any other action as may be decided by SE (TR) Junagadh.
25. The cost of damages, if any will be recovered from the Contractor's bill. The assessment of which will be done by field Engineer at his sole discretion and his decision shall be binding to the contractor and shall be considered as final and unchallengeable.
26. GETCO shall deduct the Income-Tax and other taxes as per prevailing rules from each and every bill.
27. No part rate or reduced rate shall be allowed in final bill.
28. The contractor has to follow all labour laws, safety rules and regulations. The GETCO does not take any responsibility in case of accident or injury to the workers. The safety/ security of men, materials and equipments shall be sole responsibility of the contractor.
29. The compliances of all Central/ State Govt. rules, safety and insurance rules etc. and that of local body, is a must condition for the agency.
30. The Gujarat Energy Transmission Corporation Limited does not bind itself to accept the lowest or any tender. GETCO reserves the right to reject any or all tender without signing any reasons whatsoever.
31. The erection work should be commenced immediately from the date of receipt of instructions from office and should be completed within thereafter.
32. The tender includes all minor accessories and items of work which are not have been specifically mentioned in the specification schedule etc. but are essential for completion of work. The contractor will not be eligible for any extra payment in respect of such minor accessories and items of work.
33. Tenderer will be qualified only who have submitted all the required documents as mentioned in tender notice.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



34. No higher rate or revised rate will be applicable for the work, if work is held up/ closed due to whatever so reasons.
35. GETCO will not pay any idle charge for any site conditions or any circumstances.
36. In case of any dispute/ doubt, the decision of SE (TR) Junagadh shall be unchallengeable, final and binding to the contractor.
37. The contractor has to remain in close day to day contact with Engineer in charge of work i.e. DE of concerned s/dn who will issue detailed instruction for the commencement of the work.
38. Contractor will abide by and fulfill all the terms and conditions and general terms and condition of the contract for works available in the office.
39. All other general terms and conditions as prevailing in the GETCO shall be applicable to the contract.
40. The contractor will have to complete entire job as per directive and instruction of Engineer in charge. If he fails to do so entire work will be carried out at contractor's risk and cost.
41. The contractor must engage sufficient knowledgeable persons round the clock, exclusively for oil filter machine provided by GETCO for oil filtration work. No loss of oil should occur and in case if occurs; its cost will be recovered from contractor's bill. The contractor has to apply sufficient nos. of cycles for oil filtration works as decided by the Engineer in charge.
42. The tender shall be issued to only the experienced contractor who has completed such job of similar nature and magnitude satisfactorily in time. However, filling of on line tender, does not qualifies the tenderer to offer the bid.
43. Tender offer without payment of EMD required certificate, documents, list of tools, tackles, equipments etc. required for execution of job will be out rightly rejected without assigning any reason thereof and decision of Superintending Engineer (TR), GETCO, Junagadh will be final and unchallengeable.
44. The Contractor will be governed by The GETCO's general conditions of works contract. The Booklet will be available in the concerned office in any working days. In the event of placing order, the contractor will have to sign this booklet along with other document and agreement. All the usual terms and conditions of the GETCO, through the same might have not been mentioned in this specification or contractor booklet will applicable to this contract, and the decision of the Superintending Engineer shall be binding on the contractor.
45. After completion of the work, all the surplus materials issued by the GETCO shall be returned by you to the respective center of the GETCO as per instruction of Engineer in charge at your cost.
46. Specification in any items mentioned in tender are subject to change without any prior notice and binding to the contractor.
47. If the work is required to be carried out during fix outage then the contractor has to deploy adequate man power, material, tools etc. well in advance and has to complete the entire work during this specific outage period only, failing to which GETCO shall be at liberally to deduct the amount of revenue loss due to prolong outage.
48. If required by GETCO you shall have to provide free to and fro traveling facility to our Junior Engineer or Technical staff for the work.
49. The contractor shall not refuse to execute the work order at any time and it will be his sole responsibility to execute and complete this work as per the instruction of Engineer in charge.
50. For shortages of any materials issued by the GETCO for the work, recovery shall be made from you, on the basis of prices of the materials (prevailing on the date of settlement of materials account) plus 15% supervision charges plus GST as applicable.
51. No subcontractor, Power of Attorney shall be allowed without prior approval of competent authority.
52. All the materials issued by GETCO shall be transported to the work site on same day and to be preserved in safe custody failing to which GETCO shall initiate legal action. Similarly as per instruction of Engineer in charge, you have to credit the material at GETCO store without any loss of time failing to which GETCO shall initiate legal action.
53. No tools, tackles, manpower, crane facilities etc. will be provided by the GETCO.
54. The contractor has to submit the list of tools, tackles, equipments with him along with his tender offer. The tender without this list and other required documents (as mentioned above herein the tender) should be rejected out rightly.
55. The contractor has to deploy minimum 8 to 10 skill labours/ fitters at site daily failing to which GETCO shall deduct 1,000/- plus GST as applicable per day from the bill.
56. The bidder shall specifically note that GETCO will not pay any extra amount towards any type of claim except for the description indicated in Schedule – 'B'. The party has to carry out all other/ additional required activities/ works as directed by Engineer in charge which is not mentioned in

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

Schedule but required to be completed as per site condition and for this work no extra payment shall be made by GETCO.

57. **GENERAL:-**

- a) **The interpretation of specifications doubts etc.:-**In case of any doubts about what is mentioned in specification or schedule or elsewhere, the tenderer should get all doubts cleared from the Department in writing and in advance of filling in the Tender. In case of difference of opinion about interpretation of specification etc the decision of **Superintending Engineer, Transmission Circle, GETCO, Junagadh** will be final and shall be binding to the contractor.
 - b) **Accounts of Materials issued:-**The contractor shall have to maintain accurate day to day and item wise account of use of issued materials which shall be got checked from time to time by the representative of the GETCO. The contractor will be responsible for custody and preserving the issued materials till the work is handed over by the contractor after completion.
 - c) The contractor has to maintain site register, covering all the daily details of material receipt and utilization, progress of work etc. This register shall be checked and signed by Engineer in charge and Executive Engineer during the site visit. Any bill without site register shall not be passed.
58. The contractor shall be responsible for breakages, losses and theft of material during transit or erection after the materials issued from the stores till the completion of work and is taken over by the GETCO.
59. The contractor will be responsible for the loss, distribution or deterioration of the materials, stores or articles supplied to him by the GETCO, even if such a loss distribution or deterioration has occurred under any circumstances whatsoever beyond his control as if the materials, stores or articles so supplied were his property.
60. The contractor shall co-operate with the GETCO in recording measurement etc. as expeditiously as possible and he shall fulfill all the requirements which are necessary to finalize the accounts on the basis of its records and pay him such amount as if found due to him together with the amount of security deposit. If any remaining payable to him after deduction, there from the amount due by him to the GETCO. The GETCO shall not entertain further claim from thereafter.
61. The competent authority can delete any item in schedule of the tender, if he feels that the rate quoted by the contractor for that item is abnormally high when compared to the estimated rates.
62. **Delivery of Material:-**All material/ equipment required for this work as per schedule shall be delivered at any store centers of Const. Division, Junagadh jurisdiction and contractor has to take delivery from these stores at his own cost only.
63. You will ensure that completion of erection work i.e. all works connected with substation having been completed correctly as per Indian Electricity Rules & procedure. Any extra cost involved due to incompleteness of work or bad workmanship found out Subsequently shall be set right forth with by you at your own cost.

64. **Billing and Payment Terms**

- (a) The contractor shall have to submit the RA bill of order to the concerned Deputy Engineer of sub-division of concerned division for payment once in a month period.
- (b) 90% payment of amount claimed covering various activities such as excavation, foundation, erection, earthing, stringing of bus bar and earthwire including insulator hoisting works against R.A. bills duly certified by EIC within 60 days from the date of R.A. bill.
- (c) Balance 10% of erection value shall be paid within 60 days against completion of work only after settlement of material account statement of items supplied, used, erected and successful commissioning of Sub-Station line the same amount will be release in final bill only and payment will be made only after passing of final bill.
- (d) If net payable amount is more than Rs 5.0 Lacs, payment will be released from circle office/corporate office.
- (e) The payment will be released within 60 days. However, in case of any delay due to any eventuality no interest charges shall be paid.
- (f) All the bills in accordance with the above clauses must be submitted with the following information:
 - 1) Item wise work done during billing period.
 - 2) Item wise cumulative work done.
 - 3) Account for material consumed and balance stock.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

- 4) For non-submission or part submission of above information, an additional 5% amount of the respective RA bill shall be withheld and shall only be released at the time of final bill.

(g) PAYMENT TERMS UNDER MSME ACT:

- (1) You have to update your MSME detail on GETCO's website by following link <https://getco.co.in/msme/> (and intimate to concern bill submitting office with copy to this office).
- (2) The payment will be made within 45 days from the ***date of acceptance** or the ****date of deemed acceptance** of goods or Services i.e. After submission of all required documents as per AT Terms & time to time circular issued by GETCO's Corporate Office as well as statutory requirement to process the Bill.

•**Date of acceptance means –**

- (a) The day of actual delivery of goods or the rendering of services; or
- (b) Where any objection is made in writing by the buyer regarding acceptance of goods or services, the day on which such objection is removed by the supplier;

**** "Date of deemed acceptance"**

means, where no objection is made in writing by the buyer regarding acceptance of goods or services within fifteen days of the delivery of the goods or the rendering of services, the day of the actual delivery of goods or the rendering of services;

- (h) Vendor Management System(VMS) : "To streamline and enhance the effectiveness of the invoice submission process by the Vendors, GUVNL has introduced Vendor Management System(VMS) for both material supply bills and work-related bills at the Circle/Division/Sub-division level.

All the Supplier/Contractor have to use this portal (www.vms.guvnl.com) to upload the Invoice of any of the GUVNL group company including GETCO along with relevant documents like Tax Invoice, Commercial Invoice, Proper Dispatch Certificate, Lorry Receipt, Test Certificate, Advanced Stamp Receipt etc. for supply bills and Tax Invoice, PF documents, GST Challans, Welfare cess challans, Insurance copies etc. in one file as per the AT / PO/ Work Order Terms and Conditions. Supplier/ Contractor login / password will be provided on request by respective company, one login credential for all GUVNL group companies for uploading of invoices."

65. PROTECTION OF PROPERTY AND CONTRACTOR'S LIABILITY

The Contractor shall be responsible for any damage resulting from his operations. He shall also be responsible for protection of all persons including members of public and employees of the Owner and the employees of other Contractors and Sub-Contractors and all public and private property.

66. Quantities given in the Schedule of erection in price Bid are to be executed by the contractor at the rates accepted by the Board in the A/T. In case of any deviation in tower quantity / type of tower / length of line, excavation / concreting resulting into an increase in which event the field officer shall obtain prior approval of the Head Office and excess quantity shall be paid only at the accepted rate of the A / T. No any Excess work / amount to be executed without prior approval of competent authority.

67. The erection work beyond contractual ceiling amount shall be done only after approval from the GETCO authority.

68. **CONTRACTOR'S SITE ESTABLISHMENT**

The Contractor shall at all times keep posted an authorized representative for the purpose of the Contract. Any written order or instruction of the Engineer or his duly authorized representative shall be communicated to the said authorized resident representative of the Contractor and the representative shall be available at a stated address for this purpose.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

69. CO-OPERATION WITH OTHER CONTRACTORS

Contractor shall co-operate with all other Contractors or tradesmen of the Owner, who may be performing other works on behalf of the Owner and the workmen who may be employed by the Owner and doing work in the vicinity of the Works under the Contract. The Contractor shall also so arrange to perform his work as to minimize, to the maximum extent possible, interference with the work of other Contractors and their workmen. Any injury or damage that may be sustained by the employees of the other Contractors and the Owner, due to the Contractor's work shall promptly be made good at the Contractor's own expense.

70. PROTECTION OF WORK

The Contractor shall have total responsibility for protecting his works till it is finally taken over by the Engineer. No claim will be entertained by the Owner or by the Engineer for any damage or loss to the Contractor's works and the Contractor shall be responsible for complete restoration of the damaged works to original conditions to comply with the specification and drawings.

71. Definition of Terms: 'Owner' shall mean the Gujarat Energy Transmission Corporation Ltd, Vadodara or any of its group companies i.e. GUVNL, GSECL, MGVL, DGVCL, PGVCL UGVCL and shall include its legal representatives, successors and assigns.

72. Contractor's Default: If the Contractor shall neglect to execute the works with due diligence and expedition or shall refuse or neglect to comply with any reasonable order given to him, in writing by the Engineer in connection with the works or shall contravene the provisions of the Contract, the Owner may give notice in writing to the Contractor to make good the failure, neglect or contravention complained of. Should the Contractor fail to comply with the notice within thirty (30) days from the date of serving the notice, then and in such case the Owner shall be at liberty to employ other workmen and forthwith to execute such part of the works as the Contractor may have neglected to do or if the Owner shall think fit, without prejudice to any other right he may have under the Contract to take the work wholly or in part out of the Contractor's hands and re-contract with any other person or persons to complete the works or any part thereof and in that event the Owner shall have free use of all Contractor's equipment that may have been at the time on the Site in connection with the works without being responsible to the Contractor for fair wear and tear thereof and to the exclusion of any right of the Contractor over the same, and If the sum that the Contractor is entitled to be paid plus the costs incurred by the Owner in completing the works, exceeds the Contract Price or the entire works if entire works have been completed or the price for part of the works if part of the works have been completed. the Contractor shall be liable for such excess.

If such excess is greater than the sums due to the Contractor, the Contractor shall pay the balance to the Owner and if such excess is less than the sums due to the Contractor, Owner shall pay the balance to the Contractor. For facilitating such payment. Owner shall encase the Bank Guarantees of Contractor available with Owner/s and retain such other payments due to the Contractor under the Contract in question or any other Contract that the Owner/s may have with the Contractor. Such payment of excess amount shall be independent of the liquidated damages for delay which the Contractor shall have to pay if the completion of works is delayed.

73. RIGHTS OF THE OWNER

Whenever any claim or claims for payment of a sum of money arises out of or under the contract against the contractor, the Owner shall be entitled to withhold and also have lien to retain such sum or sums in whole or in part from the security, if any, deposited by the contractor and for the purpose aforesaid, the Owner shall be entitled to encash and withhold the amount of Performance Bank Guarantee or other security, if any, furnished as the case may be. The Owner shall also have a lien over the same pending finalization or adjudication of any such claim. In the event of the security is insufficient to cover the claimed amount or amounts, the Owner shall be entitled to withhold and have lien to retain to the extent of the such claimed amount or amounts referred to above, from any sum or sums found payable or which at any time-thereafter may become payable to the Contractor under the same contract or any other contract with the Owner or GUVNL or its subsidiary companies pending finalization or adjudication of any such claim.

Lien in respect of Claims in other Contracts:

a) Any sum of money due and payable, to the Contractor (including the security deposit) under the contract may be withheld or retained by way of lien by the Owner against any of its claim in respect of payment of a sum of money arising out of or under any other contract made by the contractor with the owner or GUVNL or any of its subsidiary companies.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

b) It is agreed that the sum of money so withheld or retained under this clause by the Owner will be kept withheld or retained as such by the owner till its claim arising out of the same contract or any other contract is either mutually settled or determined by the arbitrator or competent court, as the case may be, and the Contractor shall have no claim for interest or damages whatsoever on this account or on any other ground in respect of any sum of money withheld or retained under this clause and as may be duly notified to the contractor."

74. DISPUTE RESOLUTION MECHANISM:

1) Amicable settlements

Any dispute, difference, controversy or claim between the parties arising out of or relating to this contract with reference to the construction, interpretation, breach, termination or validity thereof (hereinafter referred to as "the dispute") shall, upon the written request of either party be referred to the authorized representatives of the disputing parties for resolution. The authorized representatives shall promptly meet and attempt to negotiate in good faith a resolution of the dispute within thirty days of the service of the request.

2) Arbitration

If the parties fail to amicably resolve the disputes or differences or contrary claims as indicated herewith in sub clause (1) of **Clause 74** arising under or in connection with the present works contracts, whether pertaining to works contracts alone or works and procurement both, the same shall be referred to arbitration under the Gujarat Public Works Contracts Disputes Arbitration Tribunal Act, 1992.

75. Use of Call before you dig (CBUD) App

All the excavators/excavating agencies engaged by "GETCO (Gujarat Energy Transmission Corporation Limited) must self-register "Call Before you Dig (CBUD) " app as excavator.

All digging agencies/Contractors must be mandated to do any type of digging/excavation only after prior intimation through CBUD Mobile app.

Contractor Signature with stamp

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

SPECIAL COMMERCIAL CONDICATION FOR TENDERER

1. TAKING DELIVARY AND INSURANCE

- 1.1 The contractor has keep S/S and Line materials in safe custody and transport to the respective sites and will be reasonable for any damages to or loss of all materials at any stage during transportation or erection or taking over of the line by GETCO.
- 1.2 The Contractor has to open site store and ensure for safe custody of all the stored materials at his own cost.
- 1.3 The Contractor shall have total responsibility for the entire materials stored loose, semi assembled and/or erected by him at site in his custody. The Contractor shall make suitable security arrangements is at own cost to ensure the protection of all materials, equipments and works from theft, fire pilferage and any other damages and loss, it shall be the responsibility of the contractor to arrange for security till the works are finally taken over by the Corporation.

2 STORAGE-CUM-ERECTION-INSURANCE

- 2.1 The contractor shall take suitable storage-cum-erection insurance cover at his cost to the extent of 100% cost of sub-station/line materials, which are required to complete the sub-station /line. Bidder shall have to take the comprehensive **Marine cum Erection (MCE)** insurance policy against any loss, damage, theft, pilferage, fire etc. for the complete period of storage, erection and commissioning up to the time of taking over of the sub-station/line by GETCO. **However, if the work is not completed within the stipulated time limit as mentioned into work order, the MCE shall be extended by the contractor up to the work completion and taking over the line or S/S by GETCO. Moreover, the charge of extension of insurance shall be borne by contractor if the delay is attributed to the contractor. The charge for extension of insurance shall be reimbursed by GETCO to the contractor on production of proof for extension of MCE if the delay is attributed on the part of GETCO.**
- 2.2 The contractor shall deal directly and pursue the claim with the insurance Company and shall be responsible in regard to maintenance of all insurance coverage as well as for settlement of claim. The proof of insurance policy taken by the successful contractor shall be furnished/ submitted to Engineer-in-charge of GETCO.
- 2.3 **No material shall be issued to bidder/erection agency in absence of such insurance policy. The risk shall be covered for lifting of materials from store to final handing over to GETCO. Further in absence of the above insurance policy, R.A. bill payment will be withheld.**

2.4 The estimated cost of material is Rs. 30 LACS. (Rs. Thirty Lacs).

3.0 INSURANCE

- 3.1 The Contractor at his cost shall arrange, secure and maintain all insurance as may be pertinent to the Works and obligatory in terms of law to protect his interest and interests of the Owner against all perils detailed herein. The form and the limit of such insurance as defined herein together with the under-writer in each case shall be acceptable to the Owner. However, irrespective of such acceptance, the responsibility to maintain adequate insurance coverage at all time during the period of Contract shall be of Contractor alone. The Contractor's failure in this regard shall not relieve him of any of his contractual responsibilities and obligations. The insurance covers to be taken by the Contractor shall be in the joint name of the Owner and the Contractor. The Contractor shall, however, be authorized to deal directly with Insurance Company or Companies and shall be responsible in regard to maintenance of all insurance covers. Further the insurance should be in freely convertible currency.
- 3.2 Any loss or damage to the material during handling, transportation, storage, erection, and all activities to be performed till the successful completion of commissioning of the line shall be to the account of the Contractor. The Contractor shall be responsible for preference of all claims and

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



make good the damages or loss by way of repairs and/or replacement of the equipment, damaged or lost. The transfer of title shall not in any way relieve the Contractor of the above responsibilities during the period of Contract. The Contractor shall provide the Owner with copy of all insurance policies and documents taken out by him in pursuance of the Contract. Such copies of documents shall be submitted to the Owner immediately after such insurance coverage. The Contractor shall also inform the Owner in writing at least sixty (60) days in advance regarding the expiry/cancellation and/or change in any of such documents and ensure revalidation, renewal etc., as may be necessary well in time.

- 3.3 The perils required to be covered under the insurance shall include, but not be limited to fire and allied risks, miscellaneous accidents (erection risks) workman compensation risks, loss or damage in transit, theft, pilferage, riot and strikes and malicious damages, civil commotion, weather conditions, accidents of all kinds, etc. The scope of such insurance shall be adequate to cover the replacement/reinstatement cost of the equipment for all risks up to and including delivery of goods and other costs till the equipment is delivered at Site. The insurance policies to be taken should be on replacement value basis and/or incorporating escalation clause. Notwithstanding the extent of insurance cover and the amount of claim available from the underwriters, the Contractor shall be liable to make good the full replacement/rectification value of all equipment/materials and to ensure their availability as per project requirements.

4. PENALTY FOR DELAY

The bidder should note that the completion time allowed for carrying out the work should be strictly observed. Any delay that may take place in supply and erection beyond contractual cutoff date stated as per stipulated delivery period shall be subject to the penalty ½% per week or part thereof plus GST as applicable on delayed portion of work and / or supply value subject to ceiling of 10% of the total contract value plus GST as applicable will be imposed

- *In event of failure of the Contractor to pay the amount of Penalty as demanded **the Owner shall be entitled to deduct the amount of Penalty for delay from the amounts payable to the Contractors under any bills raised under this contract of any other amount payable under any other contract with the GUVNL and its Subsidiary Companies i.e. GETCO, GUVNL, GSECL, MGVL, DGVCL, PGVCL, UGVCL.** It is permissible for the Owner to adjust the amount of Penalty of delay against any Bank Guarantee furnished by the Contractor under this contract or any other contract with GUVNL and / or its subsidiary companies.*
- The parties agree that delay in completion of contract will result into loss of revenue and consequently loss of profit to the owner, however, the amount of loss of revenue on account of delay in commissioning the works cannot be calculated accurately at this stage the parties, therefore, agree the penalty stipulated above is a genuine estimate of the loss/damage which will be suffered on account of delay and/or breach on the part of the contractor and the said amount will be payable by the contractor on demand.
- Any delay causing extension of outages shall be contractor's responsibility and appropriate amount (in term of Rupees) as decided by Ex. Engineer (Const), Junagadh shall be recovered from Contractor's bill as a penalty.

5. Relationship with employee:-

Every bidder should, at the time of submission of bid, give a declaration as under.

"If in any Bidder Company/Firm, the interest (i.e. Shareholding in company and share in Partnership firm) of any employee of the tendering Company or his/ her relative as defined in Section 2(77) of the Company's Act. 2013 is 10% or more, the tendering Company will not deal with Such Company/ Firm at all.

Tenderer therefore, must specifically disclose this fact in his technical Bid. Non-disclosure of such facts would immediately disqualify the tenderer for further dealing with the tendering Company."

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

6. Conflict of Interest among Bidders/ Agents

A bidder shall not have conflict of interest with other bidders for particular quoted item. Such conflict of interest can lead to anti-competitive practices to the detriment of Procuring Entity's interests. **The bidder found to have a conflict of interest shall be disqualified.**

A bidder may be considered to have a conflict of interest with one or more parties in this bidding process for particular quoted item, if:

- a) they have proprietor/ partner(s)/ Director(s) in common; or
- b) they receive or have received any direct or indirect subsidy/ financial stake from any of them; or
- c) they have the same legal representative/ agent for purposes of this bid; or
- d) they have relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another bidder; or
- e) bidder participates in more than one bid in this bidding process. Participation by a bidder in more than one Bid will result in the disqualification of all bids in which the parties are involved. However, this does not limit the inclusion of the components/ sub-assembly/ assemblies from one bidding manufacturer in more than one bid.
- f) in cases of agents quoting in offshore procurements, on behalf of their principal manufacturers, one agent cannot represent two manufacturers or quote on their behalf in a particular tender enquiry. One manufacturer can also authorise only one agent/ dealer. There can be only one bid from the following:
 1. The principal manufacturer directly or through one Indian agent on his behalf; and
 2. Indian/ foreign agent on behalf of only one principal.
- g) a Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the contract that is the subject of the Bid;
- h) in case of a holding company having more than one independently manufacturing units, or more than one unit having common business ownership/ management, only one unit should quote. Similar restrictions would apply to closely related sister companies. Bidders must proactively declare such sister/ common business/ management units in same/ similar line of business.
- i) Bidder shall not act in contravention/ violation to the provisions of competition act, as amended from time to time.

Every bidder should, at the time of submission of bid, give a declaration, that bidder shall not have conflict of interest with other bidders, as above.

Responsibility for correctness of the information submitted in the bid lies with bidder. If any information furnished in the bid is proved to be false at a later date, GETCO reserve right to reject the bid and the bid will not only be rejected but the bidder will be BLACKLISTED as per GUVNL Policy

CONTRACTOR SIGNATURE WITH STAMP

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



**TERMS & CONDITIONS REGARDING INDUSTRIAL LAWS AND OTHER RELATED
MATTERS**

1) WAGES TO BE PAID AT TIME OF PAYMENT ETC. BY THE CONTRACTOR.

- a. The contractor shall pay minimum prevailing rates per day or as may be specified hereafter or rates fixed under the minimum wages Act. Whichever is higher. The wages or very contract labour employed by him under this contract shall be paid by him before the expiry of 7th day of the month in respective of which the wages are payable (i.e. wages of a month have to be paid by him in the first week of the next month). The payment shall be disbursed in the presence of management representative during the working hours in factory premises and the contractor shall get the entries certified in the register of wages by the representative of the GETCO. Any default will result in cancellation of contract forthwith or also the contractor shall be paid punishable to the extent of Rs.100/- fine per each day.
- b. The contractor shall give his telephone number and address to the GETCO so that in case of labour troubles etc. the contractor can be contacted. The contractor shall arrange to have his office outside the factory premises and the contractor shall keep himself present through out the working hours.

2) LABOUR LAWS

- (A) Person below the age of 18 years shall not be employed for the work.
- (B) No. female worker shall be employed in the night shift between 7 p.m. to 6 a.m.
- (C) Contractor shall maintain a valid labor license under the contract labour (Regulation and Abolition) Act for employing necessary manpower to be required by him. In the absence of such license the contract shall be liable to be terminated without assigning any reason thereof.
- (D) The contractor shall at his own expenses comply with all labour laws and keep the GETCO indemnified in respective thereof. Some of the major liabilities under various labour and industrial laws which the contractor shall comply with are as under :-
 - (i) Payment of contribution by way of employer's contribution towards provident fund, family pension scheme, Deposit linked insurance scheme, Administrative charge etc. at the rates make applicable from time to time by Government of Gujarat/Government of India or other statutory authority.
 - (ii) Payment of deposit in respect of each contract labour at the rate as per admissible with the office of commissioner of Labour as per the contract Labour (Regulation and abolition Act.).
 - (iii) License fee as prescribed under the contract labour (Regulation and abolition Act) and rules framed there under depending upon the number of workmen employed by the contractor.
 - (iv) Paid leave facility and wages as per the provision of the factories Act at the rate of one day for every 20 days of working.
 - (v) Identify cards as prescribed under the factories Act with photo at fixe there to the same identification. Liabilities as per industrial Disputes Act any payment to the contractor's employees arising out of any claim or disputes under the industrial Disputes Act, 1947 or any other labour laws.
 - (vi) Payment of compensation in case accidental injury.
 - (vii) Maternity leave as per the provisions of the maternity Benefit Act. The above are some of the major liabilities of the contractor in addition to other liabilities. Prescribed under the various labour laws in force from time to time from statutory authorities like State Government/ Government of India which the contractor shall have to comply with.

3) PROVIDENT FUND & FAMILY PENSION SCHEME

The contractor shall submit along with his bill (month wise) a statement regarding deduction against employees provident fund and family pension scheme in respective of each concerned employee, provident fund and family pension scheme at the rate at admissible (or at the rate made applicable by the Government from time to time) of the wages. The contractor's contribution and his workers contribution towards provident fund and family pension scheme shall be deposited by the contractor with concern regional Provident Fund Commissioner office.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

4) DEPOSIT LINKED INSURANCE SCHEME

The contractor shall have to deposit ½ % of the wage in respect of employees who is a member of the Provident Fund as the contribution to the deposit.

Linked insurance Scheme with concern regional Provident Fund Commissioner office.

(5) ADMINISTRATIVE CHARGES

Administrative charges for maintaining provident fund A/C shall be deposited by the contractor with concern regional Provident Fund Commissioner office at the rates applicable.

(6) PAID LEAVE FACILITY

Paid leave facility at the rate of one day for every twenty days worked by the contract labour shall be provided by the contractor to his workers. He shall maintain leave Records/leave cards for individual labourer which shall be duly verified and approved/certified by the authorized officer of the GETCO.

(7) WORKMEN'S COMPENSATION FUND & EMPLOYER'S LIABILITY INSURANCE

The contractor shall cover all his employees under workmen's compensation fund and under the liability insurance. Insurance shall be affected for the entire contractor's employee engaged in the performance of this contract. If any of the work is subject the contractor shall require the sub-contractor to provide workmen's compensation and employer's liability insurance for the latter's employees unless such employees are covered under the contractor's insurance.

(8) The contractor shall employ adequate number of experienced staff at site for dial supervision and for maintenance of various register and records required under the law and contract No. payment for supervision shall be admissible.

(9) CONTRACTOR TO IDENTIFY THE GETCO

The contractor shall indemnify the GETCO and every member officer and employees of the GETCO also, engineering in charge and his staff against all actions, proceeding, claims demands, costs and expenses which may be made against the GETCO or Government for or in respective of formance of his obligation under the contract documents. The GETCO shall not liable for or in respective of or in consequence of any accident or injury to any workman or other person in the employment of the contractor or his sub-contractor and the contractor shall indemnify and keep indemnified the GETCO against all such damage and compensation and against all claims, demands, proceedings costs, charges and expenses whatever in respective thereof in relation thereto.

(10) The GETCO reserves the right to terminate this rate contract at any time during its tendency without giving notice of termination or any reasons thereof.

(11) The GETCO will be entitled to deduct directly from the bills, to be paid to the contractor any sum or payable by you and which sum/sums the GETCO is required to pay as principal employer on account of your default in respect of all liabilities referred to in above clauses.

CONTRACTOR SIGNATURE WITH STAMP

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



SAFETY CUM INDEMNITY BOND

(On Non-judicial Stamp paper of value not less than Rs. 300.00)

KNOW ALL MEN BY THESE PRESENTS that we, _____ By this SAFETY CUM

INDEMNITY BOND Executed on this _____ Day of _____ 2026. I/We _____ Having Registered Office _____ (herein after called "THE CONTRACTOR" which expression shall mean and includes my /our heirs, executors, administrators and legal representatives, successors and permitted assigns) do hereby binds myself/ourselves and also our company/firms after having the power to bind by this promise and undertaking in favour of the Gujarat Energy Transmission Corporation Limited (GETCO), Vadodara a State Transmission Utility under The Electricity Act, 2003 having its registered office at Sardar Patel Vidhyut Bhavan, Race course, Vadodara.(hereinafter called as GETCO, which expression shall mean and include its legal representative, administrators assigns) has agreed under the terms and conditions of the contract no. _____ Dated _____ made _____ between _____ and _____ for the contract of the _____ value of Rs. _____ interalia on Production of Safety cum Indemnity Bond.

We do hereby undertake and agree to Indemnify and keep Indemnified GETCO from time to time to the extent of Rs. _____ Rupees _____ only against any losses or damages, costs, charges and expenses caused to or suffered by reason of the CONTRACTOR while Project, R&M, O&M work including work carried out by outsourcing agency, failing to take proper care or not complying the guidelines given hereunder as per Annexure-A and instructions which may be given from time to time during the continuance of the contract and we further undertake to unconditionally pay the amount claimed by the GETCO on demand and without demur to the extent aforesaid.

Whereas the CONTRACTOR has/have been awarded to execute the job/works under order no. _____, dated _____ for _____ issued by the GETCO after having observing necessary formalities, the details of which is described in the order no. _____ dated _____ and whereas the said job/works will be /likely to be done in places covered under Employees' State Insurance Act,1948 (ESI) and /or the Workmen Compensation Act,1923 and /or other laws relating to the Labour Management and Welfare Act. (Respective Amendments)

And whereas according to the condition of the Contract the CONTRACTOR is under obligation to execute this Safety cum Indemnity Bond before the commencement of actual execution of work

Now the indenture witnesses that I/We the CONTRACTOR do hereby undertake to follow the guidelines as per Annexure-A prepared by the GETCO.

Further we the CONTRACTOR agree that the GETCO shall be sole judge of and as to whether there has been any breach of the guidelines as per Annexure-A of this bond and as to the extent of the loss, damages, costs, charges and expenses caused to or suffered by the GETCO.

We the CONTRACTOR further agree that our liability under this bond shall not be discharged because of the change in the constitution of the GETCO or for the extension of the time limit or for any other reason.

We the CONTRACTOR further agrees to the given terms and conditions:

- That the CONTRACTOR undertakes /undertake to indemnify and keep harmless the GETCO from all claims, actions, proceedings and risk, damage danger to any person whether belonging or not belonging to the. CONTRACTOR.
- That the CONTRACTOR shall keep harmless the GETCO from all claims, compensation, damages any proceedings in respect of any of its employee / workmen under the Workmen Compensation Act or any other laws for the time being in force.
- That, if during the course of execution of work as stated in the contract order mentioned hereinabove issued by the OBLIGEE, it is found that the CONTRACTOR has not complied with guidelines as per Annexure-A or terms and conditions / formalities within the meaning of Employees' State Insurance Act,1948 (ESI) or Workmen Compensation Act 1923 or any other laws relating to the Labour Welfare for the time being in force, and also has not observed the

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

safety norms in accordance with the law prevailing at the place of work/job to the satisfaction of the GETCO, the GETCO shall have the right to stop the execution of work/job and the period of such stoppage shall not be taken into account for the calculation of the total period of completion of work for which the CONTRACTOR is responsible to complete the work/job and it will be deemed that discontinuance was due to default of the CONTRACTOR .

- d. That, if any time, due to exigency, GETCO as the Principle Employer, becomes liable to pay any such compensation mentioned hereinabove, whether on failure of the CONTRACTOR or for any other reason, the GETCO shall have the right to recover the said amount from any amount receivable by GETCO or any bank guarantee deposited or anything payable whether in connection with this contract or other contract by the CONTRACTOR to the OBLIGEE.
- e. That the CONTRACTOR is/are aware and accept that for the persistent or repeated violation of any guidelines as per Annexure-A and terms and conditions mentioned in this Safety cum Indemnity Bond, GETCO shall have right to terminate the contract of work issued to the CONTRACTOR .
- f. In case if any safety related fatal Electrical / Mechanical accident occurred to any employee of agency or outsider due to negligence or non-compliance of GETCO safety norms then in addition to the compensation and liability as per statutory requirement, contractor / agency is hereby agreed to pay the penalty amount as given below:

Sr.No	Amount of Contract in Rs.	Penalty amount
1	Up to 1Lac	Rs.5000/- plus GST as applicable
2	Above1Lac to 10Lacs	Rs.40000/-plus GST as applicable
3	10 to 100 Lacs	Rs.100,000/- plus GST as applicable
4	>100Lacs	1.0%of contract value plus GST as applicable

- g. I/We the CONTRACTOR hereby confirm that in case of any dispute/difference for settlement of claims under this Safety Cum Indemnity bond the courts in Gujarat State wherever job/work is performed or as per GETCO norms shall have the jurisdiction to decide the rights & liabilities of the parties while adjudicating the matter of claims under this Safety Cum Indemnity Bond.
- h. This Safety cum Indemnity Bond shall continue and hold good until it is released by the GETCO in Writing on the CONTRACTOR's application after the Contractor has discharged all his obligations under the order mentioned hereinabove and submitted a "NO DEMAND CERTIFICATE" from the GETCO under the said order. The Safety cum Indemnity Bond shall be valid for a CONTRACT PERIOD and renewable thereof (Claim Period).
- i. This Safety cum Indemnity Bond and the guidelines as per Annexure-A herein contained are in addition to And not by way of limitation or substitution for any other guarantee, indemnities Hereto before given to the GETCO by the CONTRACTOR and this indemnity does not Revoke or limit such indemnities or guarantees. IN WITNESS WHEREOF the Parties hereto have executed this indenture the day the year First hereinabove written.

(Signature with seal of The CONTRACTOR)

In the presence of:

1.

2.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



**INDEMNITY BOND
(Non Judicial Stamp Paper of Rs. 300/-)**

KNOW ALL MEN BY THESE PRESENTS that we, Messer's _____
_____ (hereinafter called "the Contractor" which
expression shall, where the context so admits, include their heirs, executors, administrators and legal
representatives, successors and permitted assigns) are hereby held and firmly bind unto the Gujarat Energy
Transmission Corporation Ltd (hereinafter called "the GETCO" which expression shall, where the context so
admits, include its successors and assigns) to refund the full amount of materials supplied by the GETCO
under the terms and conditions of A/T No. _____

dated _____ against any loss damage or
deterioration of whatsoever nature occurs to said materials supplied by the GETCO and which are in the
custody of the contractor at their works site, on behalf of the GETCO, at _____ (name of S/S / line)
_____ and / or if any of the said materials, when inspected by any officer authorized by the
GETCO in this behalf, is found to be damaged, lost, deteriorated in quality or quantity, the contractor hereby
agrees to bind himself to indemnity and at all times keep indemnified the GETCO against all loss, damage
and deterioration to the any material supplied by the GETCO during his custody and shall pay in cash on
demand from the GETCO within 30 days the market value of such materials which is lost, damaged or
deteriorated in full to the GETCO and shall also hereby authorize the GETCO to deduct the said sum from any
sum due to the contractor or any sum which may at any time become due to the contractor under the above
referred contract or any other contract entered into by the contractor with the GETCO.

AND WHEREAS the contractors do hereby agree to be responsible for the safe custody and protection and
preservation of the said materials against all risks (excluding war risks) and against loss, damage and
deterioration of whatsoever nature in respect of the said materials while it remains in the custody and
possession of the contractor.

AND WHEREAS the said materials shall at all times be open for inspection by any officer authorized by the
GETCO

Now the conditions of the above written bond are such that the contractor shall pay the full amount forthwith to
the GETCO in the event of loss, damage or deterioration or whatsoever except due to circumstances arising
out of war in respect of the materials supplied by the GETCO and shall fully and effectually indemnify and
keep indemnified to the GETCO against such loss, damage and deterioration.

The contractor shall keep the said materials open at all times for inspection by the officers authorized by the
GETCO and produce at anytime when demanded.

THE WITNESS WHERE OF: We the

Said M/S _____

(Signature of contractor)

(Seal of Firm)

hereto signed at _____

this day _____

In the presence of

1. _____ Name _____

_____ address _____

(Signature)

2. _____ Name _____

_____ address _____

(Signature)

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

PROFORMA FOR CONTRACT AGREEMENT

(Non Judicial Stamp Paper of Rs. 300/-)

This Agreement is made at _____ the _____ day of _____ in the Christian Year Two Thousand Twenty-Six between M/s. _____ (address of office) _____ (hereinafter referred to as "THE CONTRACTOR" which expression shall unless excluded by or repugnant to the contract include its successors or permitted assigns) of the ONE PART and the Gujarat Energy Transmission Corporation Ltd, having their Head office at Vidhyut Bhavan, Race Course, Baroda 390 007 (hereinafter called "The GETCO" which expression shall unless excluded by or repugnant to the context include its successors or assigns) of the other part.

WHEREAS the aforesaid GETCO has accepted the tender of the aforesaid contractors for _____

_____ as per GETCO's Order No. _____ hereinafter called "the works" and more particularly described and enumerated or referred to in the specification, terms and conditions prescribed in the order letter, covering letter and other letters and schedule of price which for the purpose of identification have been signed by Shri _____ on behalf of the contractors and by _____ on behalf of the GETCO, a list whereof is made out in the Schedule hereunder written and all of which said documents are deemed to form part of this contract and included in the expression "The works" wherever herein used, upon the terms and subject to the conditions hereinafter mentioned.

AND WHEREAS THE GETCO has accepted the tender of contractors for the construction of the said works for the sum of Rs. _____ Rupees (_____) upon the terms and subject to the conditions herein mentioned.

NOW THIS AGREEMENT WITNESSESS AND IT IS HEREBY AGREED AND DECLARED THAT.

1. The contractors shall do and perform all works and things in this contract mentioned and described or which are implied therein or there from respectively or are reasonably necessary for the completion of the works as mentioned and at the times, in the manner and subject to the terms and conditions and stipulations contained in this contract, and in consideration of the due provision, executions, supply and completion of the works agreed to by the contractor as aforesaid the Board doth hereby covenant with the contractor to pay all the sums of moneys as and when they become due and payable to the contractors under the provisions of the contract. Such payment to be made at such times and in such manner as is provided by the contract.
2. The conditions and covenants stipulated here-in-before in this contract are subject to and without prejudice to the rights of the Board to enforce penalty for delays and / or any other rights whatsoever including the right to reject and cancel on default or breach by the contractor of the conditions and the covenants as stipulated in the general conditions, specifications, forms or tender schedule etc. attached with GETCO's Order No. _____. The contract value, extent of supply & erection works, delivery dates, specifications and other relevant matters may be altered by mutual agreement and if so altered shall not be deemed or construed to mean or apply to affect or alter other terms and conditions of the contract and the general conditions and the contract so altered or revised shall be and shall always be deemed to have been subject to and without prejudice to said stipulation.

3. DISPUTE RESOLUTION MECHANISM :

1). Amicable settlements

Any dispute, difference, controversy or claim between the parties arising out of or relating to this contract with reference to the construction, interpretation, breach, termination or validity thereof (hereinafter referred to as "the dispute") shall, upon the written request of either party be referred to the authorized representatives of the disputing parties for resolution. The authorized

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

representatives shall promptly meet and attempt to negotiate in good faith a resolution of the dispute within thirty days of the service of the request.

2). Arbitration

If the parties fail to amicably resolve the disputes or differences or contrary claims as indicated herewith in sub clause (1) of Clause 3 arising under or in connection with the present works contracts, whether pertaining to works contracts alone or works and procurement both, the same shall be referred to arbitration under the Gujarat Public Works Contracts Disputes Arbitration Tribunal Act,1992.

SCHEDULE

List of documents forming part of the contract:

1. GETCO's Tender Specification No. _____ and contractor's offer opened on dated ____/____/2026
 2. GETCO order No. _____ Dtd. ____/____/ 2026
 3. Contractor's acceptance of order vide letter no. _____.
 4. Contractor's Partnership Deed dtd. _____.
 5. Contractor's Power of Attorney / Board Resolution authorizing person to sign on behalf of Firm.
- In witness whereof the parties here to have set their hands and seals this day and month, year first above written.

- 1) Signed, sealed and delivered by
(Signature with name, Designation and official seal)

For and behalf of M/s. _____

(Signature)

Address: _____

In the presence of (Full Name, Address and Signatures)

i) _____

(Signature)

ii) _____

(Signature)

- 2) Signed, sealed and delivered by

(Signature with name, Designation and official seal)

for and on behalf of Gujarat Energy Transmission Corporation Ltd Circle Office Junagadh.

In the presence of name, Full address and Signature:

(1) _____

(2) _____

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

BANK GUARANTEE FORMAT

NON JUDICIAL STAMP PAPER OF RS. 300/- (Stamp Paper Validity Six months)

FORM OF BANKER'S UNDERTAKING

[For Performing Guarantee (PBG) towards execution / supply Period
As per Commercial Terms and Condition of Tender]

FOR SD

To,
The Superintending Engineer (TR)
GETCO, Transmission Circle Office,
Junagadh.

BG.NO.
Issue Date.
Expiry Date.
Amount.

We, _____ (Name of the Bank and Address of the person giving the Bank Guarantee) having our registered office at _____ (Address of Bank's registered office) hereby give this Bank Guarantee No. _____ Dated _____ and hereby agree Unequivocally and Unconditionally to pay immediately on demand on writing from the beneficiary Company GETCO or any officer authorized by it in this behalf any amount up to and not exceeding Rs. _____ (Amount of performance Guarantee toward execution / supply period), (Rupees _____ (in words)) to the said GETCO on behalf of M/s _____ who have entered into a contract for the supply/works specified below

LOA No _____ dated _____
 This agreement shall be valid and binding on this Bank up to and inclusive of _____ (Date of validity of the Bank Guarantee) and shall not be terminable by notice or by change in the constitution of the Bank or the firm of Contractors / Suppliers or by any other reasons whatsoever and our liability hereunder shall not be impaired or discharged by any extension of time or variations or alteration made, given, conceded or agreed, with or without our knowledge or consent. By or between parties to the said written contract.

Notwithstanding anything contrary contained in any law for the time being in force or banking practice, this Guarantee shall not be assignable, transferable by the Beneficiary GETCO. Notice or invocation by any person such as assignee, transferee or agent of beneficiary shall not be entertained by the Bank. Any invocation of the Guarantee can be made only by the beneficiary directly.

NOTWITHSTANDING anything contained herein before, our liability under this guarantee is restricted to Rs. _____ (Rupees _____ only). Our guarantee shall remain in force until _____ (Date of validity of the Bank Guarantee). Unless demands or claims under this Bank Guarantee are made to us in writing on or before _____ (Date of validity of the Bank Guarantee), all rights of Beneficiary under this Bank Guarantee shall be forfeited and we shall be released and discharged from all liabilities there under.

Place:
 Date:

Please Mention Here Complete Postal
 Address of the Bank with Branch Code,
 Telephone and Fax nos

Signature of the
 Bank's Authorized Signatory
 With Official Round Seal

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

GENERAL TECHNICAL CONDITION FOR WORK

1. The erection work should be carried out according to the specification and as per instructions and programmed laid out by the Engineer in-charge of the work.
2. The contractor should employ as Supervisor with sufficient qualification and experience who can supervise the execution of work throughout. He should always be present on the site.
3. The GETCO will supply steel section required for substation earth mesh/ structure, G.I. / MS Strip required for completion of substation earthing work. The wooden charcoal, salt, black cotton soil, G.I. Pipe, C.I Pipe, nuts and bolts and lugs etc required for completion of earthing work shall be arranged by the contractor. However scope for supply of material as per schedule-B shall be final and binding to agency.
4. Cutting, bending, welding, brazing, wherever necessary is to be done by the contractor.
5. Erection of panel board includes shifting in control room – bolting with side panel – leveling of panel with proper grouting as per instruction of Engineer-in-charge.
6. The contractor has to carry out all the works in accordance with revised and latest provision under I.E. Rules Act made there under and as per instruction of Engineer in charge.
7. Contractor has to co-ordinate E.I.C. for planning of outage and work schedule thereof, so as to complete all the planned work in outage. Contractor has to deploy adequate manpower accordingly.
8. It will be bidder's sole responsibility for erection of complete line/equipment in all respect as per the provision of I.E. Rules and procedures and as per the instruction of Engineer in charge.
9. In addition to the general of the construction particular, attention shall be paid to the final finish and every effort shall be made to have the entire work contented with standard of workmanship by the contractor.
10. **Electricity Rules:** -All the works shall be carried out in accordance with latest rules under Electricity Act.
11. **Testing:** - Complete installation shall be put to the necessary test as required and shall be got approved by Government Electrical Inspector.

12. CONTRACTOR'S MATERIALS BROUGHT TO SITE

- a) The Contractor shall bring to Site all materials, including construction equipment, tools and tackles for the purpose of the works under intimation to the Engineer. All such goods shall, from the time of their being brought vest in the Owner, but may be used for the purpose of the works only and shall not on any account be removed or taken away by the Contractor without the written permission of the Engineer. The Contractor shall nevertheless be solely liable and responsible for any loss or destruction thereof and damage thereto.
- b) After the completion of the Works, the Contractor shall remove from the Site under the direction of the Engineer the materials such as construction equipment, erection tools and tackles, scaffolding etc. with the written permission of the Engineer.

13. FIELD OFFICE RECORDS

The Contractor shall maintain up to date copies of all drawings, specifications and other Contract Documents and any other supplementary data complete with all the latest revisions thereto. The Contractor shall also maintain in addition the continuous record of all changes to the above Contract Documents, drawings, specifications, and supplementary data, etc. effected at the field and on completion of his total assignment under the Contract shall incorporate all such changes on the drawings and other Engineering data to indicate as installed conditions of the equipment furnished and erected under the Contract. Such drawings and Engineering data shall be submitted to the Engineer in required number of copies.

14. Contractor shall purchase all brought out items as per schedule-B with taking prior approval from Executive Engineer (Const), GETCO, Junagadh. Any item without approval shall not be permitted and GETCO shall not be responsible for accept such items.

15. DISCIPLINE OF WORKMEN

The Contractor shall adhere to the disciplinary procedure set by the Engineer in respect of his employees and workmen at Site. The Engineer shall be at liberty to object to the presence of any representative or employee of the Contractor at the Site, if in the opinion of the Engineer such

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

employee has misconduct himself or is incompetent or negligent or otherwise undesirable and then the Contractor shall remove such a person objected to and provide in his place a competent replacement.

16. CONTRACTOR'S FIELD OPERATION

- 1 The Contractor shall keep the Engineer informed in advance regarding his field activity plans and schedules for carrying-out each part of the works. Any review of such plan or schedule or method of work by the Engineer shall not relieve the Contractor of any of his responsibilities towards the field activities. Such reviews shall also not be considered as an assumption of any risk or liability by the Engineer or the Owner or any of his representatives and no claim of the Contractor will be entertained because of the failure or inefficiency of any such plan or schedule or method of work reviewed. The Contractor shall be solely responsible for the safety, adequacy and efficiency of plant and equipment and his erection methods.
- 2 The Contractor shall have the complete responsibility for the conditions of the Work-site including the safety of all persons employed by him or his Sub-Contractor and all the properties under his custody during the performance of the work. This requirement shall apply continuously till the completion of the Contract and shall not be limited to normal working hours.

17. PROGRESS REPORT

The Contractor shall furnish three (3) copies each to the Engineer of progress including if any, photographs of the work done at Site. The monthly progress report detailing-out the progress achieved on all erection activities shall highlight comparison to the schedules. The report shall also indicate the reasons for the variance between the scheduled and actual progress and the action proposed for corrective measures, wherever necessary.

18. MAN-POWER REPORT

The Contractor shall submit to the Engineer, on the first day of every month, a man hours schedule for the month, detailing the man hours scheduled for the month, skill-wise and area-wise.

19. CONTRACT QUALITY ASSURANCE:

The Bidder shall include in his proposal the Quality Assurance Programme containing the overall quality management and procedures which he proposes to follow in the performance of the Works during various phases. At the time of Award of Contract, the detailed Quality Assurance Programme to be followed for the execution of the Contract will be **mutually discussed and agreed and such agreed Programme shall form a part of the Contract.**

CONTRACTOR SIGNATURE WITH STAMP

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
 Zanzarda Junagadh-362 015
 e-mail : setrjunagadh.getco@gebmil.com



SPECIAL TECHNICAL CONDITION

1. All erection work is to be carried out as per the manual of OEM (Original equipment manufacturer), FQP, approved drawing, specification and instruction of E.I.C.
2. All equipment erection charges are inclusive of shifting dragging handling of the respective equipment up to S/S erection site from its S/S site store.
3. Contractor has to ensure safe shifting dragging erection of all equipments to comply with labour laws I.E. rules etc.
4. All erection charges are inclusive of fixing of clamp connectors, all necessary accessories to the respective equipments.
5. Transformer erection charges cover shifting, dragging, handling etc. for its bushings, radiators, conservator tank and allied accessories and oil filling, filtration (if require).
6. All erection work includes erection insurance to be arranged by the contractor at his cost.
7. All the required tools and tackles like compression jointing machine for conductor, earth wire, cutting machine, welding set, drill machine, etc are to be arranged by the contractor at his cost.
8. Contractor should complete transportation within one job as per schedule if applicable. No extra payment will be given in any case other than this job.
9. If filtration of transformer is required in any case the filter machine shall be arranged by Contractor at his own cost.
10. Earthing pit activities should be done in such a way in presence of GETCO supervisor that final earthing pit resistance should be record as per standard. All expenditure like sufficient watering to maintain earth resistance up to the mark should be born by contractor.
11. All the brought out items get to be approved from DE/EE invariably for its specifications and quantity to be order out only as per instruction of EIC looking to the site condition. Payment will be given for those quantity for which clearance given from EIC and not for those which is mentioned in A/T
12. The executions of bore are to be carried out as per soil strata in consultation with E.E.
13. The Classification of hard rock strata should be got approved from E.E. invariably.
14. Contractor has to make arrangement for site engineer and skill labours for maintaining all activities and records as per FQP. Also assisting to staff/Engineer in charge to take IR values, Earth pits values, name plate detail, oil samples etc all activities relative to commissioning of project.
15. Contractor has to make arrangement for skill labours for assisting to commissioning engineer, PLCC staff/engineer, SMS/CMS/CRM/DCRM/testing staff/Engineer, Staff of as and when require as per instruction of Engineer in charge.
16. After completion of project successful bidder has to submit all the records like battery charging report, control wiring schedule, earth pit lay out, earthing grid layout, power cable lay out, yard light pole and ckt lay out etc in hard and soft copy for handing over the project.
17. For Colony & Yard lighting and Control Room Industrial Electrical wiring works the rates quoted shall be inclusive of providing and fixing / Installation, testing and commissioning of complete Control Room lightings, Ceiling Fans, Exhaust Fans etc.
18. All items / materials shall be installed / erected in accordance with specified manuals /technical guide lines of the manufacturer and as per instruction of EIC.
19. Cable laying, Circuit distribution and Fixture fixing shall be carried out as per GETCO Standard Drg. No. GETCO/E/06S-STD/S-013 (R0) Sheet 1 to 3 of 3 and as per Instruction of Engineer In charge.
20. Control Room Wiring, Fixing of fixture, Ceiling fan & Exhaust fan etc shall be carried out as per Standard Drawing No. GETCO/E/6S-STD/S-015 (R0) Sheet No 1 & 2 of 2. and GETCO/E/6SSTD/S-013 (R0) Sheet No 1 of 3 and as per instruction of Engineer In charge.
21. For entire control Room, Office & store etc. building wiring is to be done by Providing and fixing of ISI Marked GI conduit pipes 20mm dia. & 1.6 mm wall thickness size (Minimum Size) and PVC insulated stranded copper wire of FENOLEX/ANCHOR make as per relevant IS.
22. Total tilting angle for the flood light luminaries provided on pole is considered as maximum of 45 degree, looking to the tilting angle 20 degree available with luminaries itself & supporting pipe should be fabricated & welded accordingly. Also arm for fixing of Flood light luminaries shall be fix as per required angle & direction as per instruction of EIC.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

23. EE/DE will decide the make of luminaries, fan, cable, MCB, Switches etc. and same is to be inspected at authorize depot.
24. Yard light pole should be inspected at the cost of contractor.
25. Successful bidder has to appoint site engineer to maintain site register and FQP as per ISO.
26. All work should be done according to ISO & FQP and all require documents including filled FQP, testing results, etc should be submitted while handing over the project.
27. The above rates are with supply of cement by the contractor.
28. Control wiring must be executed as per standard Ferruling philosophy circulated by GETCO letter No;- CE(Engg)/PROT/V/Circular/346 dated. 14.03.2014. wiring terminations are to be made with standard Ferruling philosophy only. Only machine printed ferrules (Black letters on white tube) shall be utilized for each and every work.
29. Contractor has to make all required mechanical and electrical setting of all the isolators by deputing skill technician and offer for final inspection of all isolators.
30. All the brought out supply items shall be provided only specific make mention in schedule-B. No any alternative make shall be allowed.
31. Contractor has to submit the planning bar chart before starting the work in kickoff meeting.
32. Contractor has to complete all the work related to this title in stipulated outage period as per instruction of EIC
33. After successful completion / commissioning of work awarded to agency in all respect, security arrangement shall be made by GETCO subjected to advance intimation at least 15 days before work completion. Till security arrangement by GETCO, contractor is responsible for security of project.
34. The successful bidder shall depute qualified and experienced site engineer during the work execution by contractor. In case the contractor doesn't engage qualified and experienced site engineer having qualification of BE/Diploma (Electrical) from recognized university, penalty of ₹ 10000/- (plus GST as applicable) per month from RA/Final bill shall be deducted and it will be non-refundable.
35. To achieve target given by competent authority / GOG, successful bidder has to start & execute the work as per availability of material at GETCO's store & progress of Civil work. It may be in piecemeal manner. No any IDEAL charges will be paid if work front is not clear due to civil work / non availability of material. Successful bidder has to claim only Time Limit Extension for such type of cases if arise with detail justification along with documentary proof.
36. Successful bidder has to attend the Kick off / progress review meeting at any venue arranged by GETCO by deputing conversant, authorized representative / site engineer with all records for better planning & to avoid any delay in project completion. No any Extra charges will be paid for attending meeting.
37. Successful bidder has to provide security from date of commencement upto forward charge /back charge of S/S and upto 100% electrical work completion.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



SPECIAL TECHNICAL CONDITION FOR YARD LIGHTING, C.R. BUILDING & QUARTER ELECTRIFICATION WORK

1. Laying and termination of 415 V, PVC armored power cable from lighting panel to the junction box at the bottom of the gantry to lighting fixtures receptacles & looping from one gantry to other shall be buried underground. Contractor shall quote the unit price of cable erection separately. Cables glands and lugs are included in contractor's scope.
2. Laying & termination by 415 V, PVC armored power cable from street lighting panels to street lighting poles and power cables for looping from one gantry to gantry shall be in the scope of lighting contractor. These cables shall be buried underground. Cable glands and lugs are included in contractor's scope.
3. Materials & components not specifically stated in this specification & which are necessary for satisfactory installation & operation of the lighting system shall be deemed to be included in the scope of the specification.
4. The design manufacture & performance of equipment shall comply with all currently applicable statues, regulations and safety codes in the locality where the equipment will be installed. Nothing in this specification shall be construed to relieve the bidder of these responsibilities.
5. Unless otherwise specified, equipment offered shall confirm to latest applicable Indian and IEE standards. Equipments complying with one another authoritative standards such as British, U.S.A., V.D.E., etc., will also be consider if it insures performance equivalent of supplier to Indian Standards. In such cases the bidder shall clearly indicate the standard adopted and furnish a copy of the latest English version of the standards along with the tender should there by any dispute of design, work shall be followed.
6. Indian Standards as per latest amendment should be followed :-

(i)	IS : 1913	-General & Safety requirement for Electric Lighting Fittings.
(ii)	IS : 3523	-Water Proof Electric Lighting Fittings.
(iii)	IS : 4012	-Dust Proof Electric Lighting Fittings.
(iv)	IS : 4013	-Dust Tight Electric Lighting Fittings.
(v)	IS : 1777	-Industrial Lighting Fittings with Metal Reflectors.
(vi)	IS : 3287	-Industrial Lighting Fittings with Plastic Reflectors.
(vii)	IS : 2493	-Well glass Lighting Fittings for use underground in mines. (Non flamp proof type).
(viii)	IS : 1947	-Specification of Flood Light.
(ix)	IS : 2149	-Luminaries for Street Lighting.
(x)	IS : 2183	-High Pressure Mercury Vapor Lamps.
(xi)	IS : 1534	-Ballasts for use in Fluorescent Lighting Fittings (PART-I).
(xii)	IS : 1569	-Capacitors for use in Fluorescent Lamps.
(xiii)	IS : 2215	-Starters for Fluorescent Lamps.
(xiv)	IS : 2713	-Tubular Steel Poles.
(xv)	IS : 5133	-Steel & Cast Iron Boxes.
(xvi)	IS : 2629	-Hot Dip Galvanizing of Iron & Steel.
(xvii)	IS : 694	-PVC Insulated Cables for Working Voltage up to & including 1100 V
(xviii)	IS : 732	-Code of practice for Electrical Wring Installation (System Voltage not exceeding 650 Volts.)
(xix)	IS : 3043	-Code of Practice for Earthing.
(xx)	Indian Electricity Act.	
(xxi)	Indian Electricity Rules.	
7. The Standards mentioned above are available from Indian Standards Institution. Manek Bhavan,9, Bahdoor Shah Zafar Marg, New Delhi – 110 001.
8. All Sodium Lamps fixtures shall be complete with accessories like balasts, Ignintors,Power Factor Improvement Capacitors etc. This shall be mounted as possible in the fittings assembly only. If these can not be accommodated inside, then a separate metal enclosed box shall be included to accommodate the accessories and in addition with fuse & terminal block suitable for Loop – In – Loop – Out connections. Outdoor type Weather proof box. They shall indicate starting time of this lamps to get full light out put. Curves for starting characteristics and variation of lamp characteristics with varying supply voltage etc to be furnished by the bidders.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

9. Each lighting fixture shall be provided with and earthing terminal suitable to connection to 8 SWG G.I. Earthing Conductor.
10. **CABLE TERMINATION BOX:-**
 1. Cable Termination Box for gantry structures, shall be completely weather proof Confirming to IPW 55 and provided with lockable door & HRC fuse mounted on fuse Carrier and fuse base assembly. The terminal shall be stud type and suitable for two nos. 4 mm² cable necessary arrangement for glanding cable along with supply of gland are included in tender scope.
 2. The bolts, nuts & screw required for erection is to be supplied by the contractor at His own cost.
 3. Outside and inside the cable terminal boxes shall be supplied by the contractor at his colours.
 4. Finished painted appearance on equipment shall aesthetically pleasing appearance, free from dots and uneven surface.
 5. Touch up paint at site shall have to be done, if necessary.
11. **STREET LIGHT POLES:-**
 1. The structure/pole & wall mounted G.I. pipe post shall be supplied with one "SINTEX" make SMC junction box described in Schedule'B' heavy duty bakelite connector, brass Neutral link, rewire able fuse, rubber gaskets etc.
 2. The junction box should be provided with proper bracing arrangement on structure/ wall by means of G.I. strips. The junction box should have two holes at the bottom to accommodate two Siemens type tinned brass cable glands of suitable size for cable to be used. The cable glands of approved make should be supplied by the contractor.
 3. The wall mounted G.I. Pipe post shall be painted with one coats of Anti -Corrosive oxide primer & two coats of Aluminum paint. as per instruction of Engineer – In – Charge.
12. **INSTALLATION OF POLES AND WALL MOUNTED G.I. PIPE POST:-**
 The G.I. Pipe post shall be fixed on the face of wall at suitable height, by means of 3 pairs of wall clamps, nuts and bolts.
13. **CABLE WORK:-**
 PVC Insulated PVC cuter and inner sheath, armoured copper conductor cables suitable for 1100 Volts A.C. as per IS : 1554 (Part – I – 1964) of size as specified in schedule of quantities. The cables should be approved make, any of following, Unicable C.C. / Unistrar / Gloster / I.C.C. or equipment, subject to approval of Competent Authority.
14. **GENERAL PRECAUTIONS FOR HANDLING OF CABLES:-**
 1. Before laying cables there shall be tested for physical damage, continuity, absence of cross phasing, insulation resistance to earth and between conductor, insulation resistance tests shall be carried out with 500 / 1000 volts megger.
 2. The cable shall be supplied for site wound on wooden drum as far as possible. For smaller length and sizes cables in properly coiled from can be accepted. The cables shall be laid by mounting the drum of cable on drum shall be mounted on a properly supported axle and the cable laid out from the drum in no case the cable will be rolled on as it produces kinks which may damage the conductor.
 3. Sharp bending and kinking of cables shall be avoided. The bending radius for PVC insulated & sheet armoured cables shall not be less than 10 'D', where 'D' is overall dia. Of the cable armoured cable shall never be concealed in roads with G.I. Pipe conductor R.C.C. pipes, required pipes will be supplied by the contractor. After drawing cable, the end of the pipe shall be sealed with cotton/bituminous compound
15. **LAYING OF CABLES (UNDERGROUND SYSTEM):-**
 1. Cables shall be so laid in ground that, these will not interfere with other underground structures. All water pipe sewage lines or other structure which become exposed by excavation shall be properly supported and protected from injury until the filling has been rammed solidly in places under and around them. Any Telephone or other cables coming in the way are to be properly shielded / diverted as directed by the Engineer – In – Charge. Cables shall be laid at a minimum depth of 750 mm from ground level. Excavation will generally be in ordinary alluvial soil. The width of the trench shall be sufficient for laying of required number of cables. The surface of the ground after back

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



filling the earth, shall be made so as to confirm in all respects to the surrounded ground and to the entire satisfaction of site Engineer.

2. For wall mounted fixture the cable shall be laid in wall, by using grooved wooden base block G.I. saddles, screw etc.
3. Joints in the cable through out its length of laying shall be avoided as far as Possible and if unavoidable, prior approval of site Engineer shall be taken. If allowed proper straight through epoxy joint shall be made without any additional cost. A loop of one meter of each length of cable shall be left near each street light pole. Also a loop of one meter shall be provided on both ends of the cable. This additional length shall be used for fresh termination in future. Cable for this loop shall be paid for supply & laying.

16. TERMINATION AND JOINTING OF CABLES:-

On both ends of cables suitable size brass heavy duty cable glands shall be used before it enters junction box/ main LT panel/ joint box etc. armour of cable shall be connected to earth point.

17. EARTHING TO G.I. PIPE/ STRUCTURE/POLES & FIXTURE :-

1. Each fixturestructure/wall and G.I. Pipe post shall be earthed by coil type earthing. 10 SWG G.I. wire coil (10 cms. Dia x 45 Cms. Length) shall be buried in specially prepared Earth pit of depth 1.5 Mtr. Necessary G.I. wire including coil, salt (10 KGs. per pit) & Charcoal/ coke (10 Kgs. per pit) required for earthing, shall be supplied by the Contractor. The upper end of G.I. earthing wire shall be fixed on each pole and G.I. pipe post by means of 2 Nos. of 8 mm.dia. Brass bolts and nuts with washer as shown in drawing shall be made available with pole. There should not be any joint of G.I. earth wire, in between earthing terminal of pole and bottom end of coil.
2. The common earthing shall be done for two post – top luminaries installed on main gate of the switch yard for measurement recording. The quantity will be considered as ONE only and no extra payment will be made, for common earthing.

18. INSTALLATION STREET LIGHTING LUMINAIRES:-

This include fixing of street light fitting complete with accessories and lamp on The pole/ bracket, connecting it with 2 x 2.5 sq. mm (710.67 mm) Dia. PVC insulated and PVC sheathed copper flexible conductor and commissioning the same.

19. INSTALLATION POST TOP LUMINAIRE:-

This includes providing & installation of post top lantern complete with all accessories & lamp connection it with 2 x 2.5 sq. mm. (710.67 mm Dia) PVC insulated & PVC sheathed copper flexible conductor testing & commissioning the same.

20. All the fitting required for fixing the luminaries, such as reducer, coupler, gasket & all types of hardware shall be provided by the contractor himself. All tools and Tackles required for the entire work shall also be arranged by the contractor. In any case Board will not provided any such facility, whatever.
21. All materials shall be got approved from E.E./D.E. Construction, Junagadh before commencement of work. If there is any dispute regarding interpretation of specifications. The decision of E.E. Construction, Junagadh shall be final and binding to the contractor.

22. SPECIFICATIONS:-

The fitting will have to be supplied and the work will have to be carried as per specification attached herewith and the same should be got approved by the Executive Engineer, Junagadh. The successful bidder has to follow strictly standard design of illumination for 66 KV Sub-Station as per circular No: CE(Project)/SE(Proj)/V/4858 Dtd: 24-06-2008 issued by C.E.(Pro) details are as under.

1. GETCO Technical Specification Illumination
2. Annexure –I (Fitting detail of Control Room).
3. Annexure-II (Luminance details for switch yard area).
4. Standard drawing for switchyard Illumination No: GETCO/E/06S-STD/S-013 (Sheet 1 To 3).
5. Standard drawing for Control Room No: GETCO/E/06S-STD/S-015 (Sheet 1 & 2).

If any change in quantity as well as specification will be intimated well in advance before commencement of work & accordingly the successful bidder has to carry out the work & procure the required items.

Sign & Stamp of Contractor

Regd. Corporate office:

Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.

Corporate Identity No. (CIN): U40100GJ1999SG036018

Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

TECHNICAL SPECIFICATION FOR S/S

ERECTION OF EQUIPMENT

1. All the equipment to be opened carefully and any damage during opening of equipment cases or during shifting at erection places will be at Contractor's cost.
2. Before erection of equipment it should be cleaned properly or if required may be washed as per instruction Engineer-in-charge.
3. Before erection initial testing of equipment whatever is required is to be done with the help of Engineer-in-charge for which no any extra charge will be paid.
4. Arrangement of erection is to be got inspected by Engineer-in-charge before erection of equipment and its structure.
5. No any extra charges are to be paid if any equipment is required to change its position as per requirement after erection.
6. Within the sub-station yard no any extra shifting charge will be paid to the Contractor for any equipment.
7. The detailed drawings of equipments can be seen from this office/concerned field/division during any working day and the equipments which are to be erected can also be seen physically at Keshod store or at store specified by the EIC during any working day and time.
8. The erection work should be carried out according to the specification as per instructions and programmed laid out by the Engineer in charge. Contractor has to ensure safe shifting and erection of all accessories/ equipments as per standard norms.
9. The contractor has to arrange for minor fabrication (if required) at free cost & follow all labour laws I.E. Rules safety rules, Insurance rules, GETCO rules at his risk & cost.

ERECTION OF 66 KV GI STRUCTURES

1. All the structures are to be erected in line level and in plumb as per instruction of Engineer-in-charge.
2. If any structure falls after erection but before grouting then it will be responsibilities of Contractor to get replaced damaged members at his cost.
3. After taking delivery of the structures from GETCO stores, contractor will be fully responsible for safe custody and theft of which will be at Contractor's cost till completion of work.
4. During erection due care is to be taken for any damage to any equipment inside the S/S yard and any damage to the equipment is at Contractor's Cost.
5. Required tools, tackles, ropes, spanners and skilled labours etc. are to be arranged by the Contractor at his cost.
6. All bolt and nuts should be fixed properly and spring washer, flat, washer to be used as per drawing.
7. If any minor fabrication / modification is required during erection to the structure i.e. holes, cutting, which is to be carried out by the Contractor at free of cost.
8. Any loose materials which obstacles during the erection are to be shifted by the contractor for which no extra charges are to be paid.

SUB-STATION STRUCTURE AND EQUIPMENT EARTHING

1. Earthing pits are to be excavated as per standard drawing and as per instruction of Engineer-in-charge of s/s.
2. Generally in rocky / soft rock strata mesh type earthing are to be provided from scrap /flat which will be given to the contractor at free of cost for which account to be submitted and necessary fabrication welding, joining with pipe is to be done by the contractor.
3. Back filling and watering of earthing pits is to be done in the presence of GETCO Supervisor only.
4. Contractor has to arrange watering in such way that resistivity of each pit should come to the required limit.
5. For laying of earthing strip inside the sub-station yard for equipment and s/s structure contractor has to be carry out as per the specification is to be laid properly by making welding joint and bolt wherever is required.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

6. In case of hard strata contractor has to fill-up earthing trench after laying of strip by black cotton soil.
7. All earthing joints are to be welded with structure of equipment by means of proper welding and bolt with structure and with the earthing pits. All the welded joints are to be painted with Aluminum Paint.
8. For earthing GETCO will supply only G. I. Strip & Scrap for mesh, remaining materials such as salt-cock pipe etc. is to be supplied by the contractor.
9. All earthing joints including the earthing trench are to be made over lapped with earthing strip.
10. The earthing mat laying should be done as per approved drawing.
11. Arrangement of earth pit (check pit) & pipe earthing should be done as per drawing No: GETCO/E/06S/STD/P-011. (2 sheet)
12. Equipment earthing should be done as per drawing No: [GETCO/E/06S/STD/P-012 \(sheet 1 to 24\)](#).

BUS-BAR AND EARTH WIRE STRINGING

1. For stringing of conductor any size or any type is to be utilized which must be properly cut after taking correct measurement.
2. Conductor to be spread in a straight condition and no any twist is permitted if any twist is there then same is to be replaced by the Contractor at his cost.
3. No any scratches should be allowed during spreading bus conductor.
4. All disc insulators are to be cleaned and all the 'W' pin must be ensured before fixing to the conductor.
5. Before taking the tension of bus conductor on gantry beam, beam tension plate bolt, nuts to be checked and tightened. No over tension is to be allowed during tensioning of conductor and sag of conductor is to be kept as per instruction of Engineer-in-charge.
6. Wherever spacers are required, they should be provided at regular interval as per instruction of Engineer-in-charge.
7. Jumpering is to be done as per standard practice however it must be done with taking proper care of clearance between conductor and column.

LAYING OF CONTROL CABLES AND TERMINATION

1. Before laying of control cable proper schedule of cable showing length of each cables is to be prepared and is required to be approved by Engineer-in-charge.
2. Cable should be laid in such a way that no any twisting of cables is to be found or no cable should be cut under length or over length.
3. All cables are to be laid and clamped inside the cable trench as per the instruction of Engineer-in-charge.
4. Cable markers should be provided nearby termination at both ends.
5. Wherever there is no cable trench for small equipment and having a small length about 10 meters, cable should be laid by providing half round gutters for above 10 meter. If half round gutter is required same will be supplied by the GETCO at free of cost.
6. For termination of control cable required size of cable glands copper lungs ferrules tap, sleeves, etc. are to be supplied by the Contractor at his cost.
7. All cables terminated inside the panel / equipment with giving proper shape and clamping and taping no any cable leads to be got earthed.
8. Complete cable schedule in triplicate is to be given by the contractor with giving details of each termination of cables from one end to other end with giving cable number and size of cable and this to be approved by Engineer-in-charge. For preparing the schedule necessary drawing will be provided by the GETCO. And contractor will be paid extra charges for preparation of schedule which is to be approved by Executive Engineer.
9. During testing of control wiring of panel / equipment, contractor has to witness the job and any changes is required that is to be done by the contractor without any charge.
10. Any fabrication is required inside the kiosk box / panel / equipment for fixing of glands and clamps is to be done by the contractor at his cost.
11. The Control wiring work should be carried out according to the specification and as per instructions and programmed laid out by the Engineer-in-charge of the work.
12. The Control wiring work should be commenced immediately from the date of receipt of instructions from office and should be completed within thereafter.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

13. Erection of Battery Charger includes shifting in control room – bolting with side panel – leveling of Battery Charger with proper grouting as per instruction of Engineer-in-charge.
14. GETCO has adopted "Maintenance free earth electrode and ground improving material "As per technical specification for maintenance free treated earth pit. Hence the successful bidder shall have to purchase the "Maintenance free earth electrode and ground improving material from GETCO approved vendors only. The specification/drawing etc. shall be issued to the successful bidder by field office/division office.

SPECIAL (LINE) TECHNICAL CONDITION:

1. All erection work is to be carried out as per the manual of OEM (Original equipment manufacturer), FQP, approved drawing, specification and instruction of E.I.C.
2. All erection work includes erection insurance to be arranged by the contractor at his cost.
3. All the required tools and tackles like compression jointing machine for conductor, earth wire, cutting machine, welding set, drill machine, etc are to be arranged by the contractor at his cost.
4. All the work related to the transmission line like detailed survey, check survey, tower/DP foundations, material testing, tower/DP erection, stringing, final testing, etc should be carried out as per GETCO'S standard FQP for transmission line.
5. Successful bidder has to appoint site engineer to maintain site register and FQP as per ISO
6. All work should be done according to ISO & FQP and all require documents including filled FQP, testing results, etc should be submitted while handing over the line
7. While calculating the weight of stub-setting, the weight of stub, cleat & templates shall also be added in stub weight.
8. The rates are with supply of cement by the contractor.
9. Red oxide & zinc rich paint shall be applied after tack welding of nuts.
10. The rate indicated includes taking delivery of all stringing material Board's stock at destination keeping them in safe custody and transporting the same to erection site
11. Contractor has to ensure safe shifting dragging erection of all equipments to comply with labour laws I.E. rules etc.
12. Earthing pit activities should be done in such a way in presence of GETCO supervisor that final earthing pit resistance should be record as per standard. All expenditure like sufficient watering to maintain earth resistance up to the mark should be born by contractor.
13. Contractor has to make arrangement for skill labours for assisting to commissioning engineer as an when require as per instruction of Engineer in charge.
14. After completion of project successful bidder has to submit all the records like Final as build check survey, profile, clearance, foundation register, soil classification record, stringing chart, material inventory sheet etc in hard and soft copy for handing over the project.
15. All items / materials shall be installed / erected in accordance with specified manuals /technical guide lines of the manufacturer and as per instruction of EIC.
16. Successful bidder has to appoint site engineer to maintain site register and FQP as per ISO.
17. All work should be done according to ISO & FQP and all require documents including filled FQP, testing results, etc should be submitted while handing over the project.
18. Contractor has to submit the planning bar chart before starting the work in kickoff meeting.
19. Contractor has to complete all the work related to this title in stipulated outage period as per instruction of EIC
20. Material from store shall not be issued until contractor will submit proof for taking storage cum erection insurance policy for particular project.
21. **The successful bidder shall depute qualified and experienced site engineer during the work execution by contractor. In case the contractor doesn't engage qualified and experienced site engineer having qualification of BE/Diploma (Electrical) from recognized university, penalty of 10000/- (plus GST as applicable) per month from RA/Final bill shall be deducted and it will be non-refundable**

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



TECHNICAL SPECIFICATIONS-(PRT-II)

PRINCIPAL TECHNICAL PARAMETERS for Supply, Installation & commissioning of CCTV camera surveillance system at various 66 KV to 400 KV class Substation/Store of GETCO.

Sr. No.	Item Description	Specifications	TECHNICAL SPECIFICATIONS
1	IP Bullet Camera 2 MP	Image Sensor:	1/2.8" 2 Megapixel progressive scan CMOS
		Min. Illumination:	Color:0.08 Lux; B/W:0 Lux 0 Lux with IR illumination ON or Better
		Lens:	Fixed F 1.2 or Better
		Day& Night:	Auto
		Wide Dynamic Range:	90dB or batter
		Digital noise reduction:	Supported
		IR Range:	Min. 50 meters
		Compression Standard	
		Video Compression:	H.265 or better
		Image	
		Image Resolution:	1920 x 1080
		Frame Rate:	25 to 30 fps
		Network	
		Protocols:	TCP/IP, ICMP, HTTP, HTTPS, FTP, DHCP, DNS, DDNS, RTP, RTSP, RTCP, PPPoE, NTP, UPnP, SMTP,SNMP, IGMP, 802.1X, QoS, IPv6, Bonjor
		Time synchronization	Auto Time synchronization of camera with NVR
		System Compatibility:	ONVIF support
		Interface	
		Communication Interface:	1 RJ45 10M / 100M Ethernet interface
		Built in memory card slot	Built-in memory card slot, support Micro SD/SDHC/SDXC, Min 128 GB
		General	
		Operating Conditions:	0 °C ~ 60 °C, less than 95 % RH
		Power Supply:	DC12V,PoE (802.3af) / (802.3at)
		Weather Proof:	IP66
		Make	Axis: Axis Communications AB. Pelco: Pelco, Inc. Honeywell: Honeywell International Inc. Bosch : Bosch Limited Matrix Comsec: MATRIX COMSEC PVT. LTD BEL : Bharat Electronics Limited American Dynamics : Tyco Security Products Vicon: Vicon Industries Inc. Sony : Sony India Pvt. Ltd.
		Certificate	Either Bureau of Indian Standards (BIS) OR UL certificate.
		Warranty	Three years

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

		GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gebmil.com			
2	PTZ Camera 2 MP				
		Image Sensor:	1/2.8" 2 megapixel progressive scan CMOS		
		Minimum Illumination:	Color: 0.3Lux; B/W: 0.01Lux 0 Lux with IR illumination ON or Better		
		White Balance:	Auto, Manual		
		AGC:	Auto, Manual		
		WDR (Wide Dynamic Range):	90 dB or better		
		Shutter Time:	1/1 s to 1/15,000 s or better		
		Day& Night:	Supported		
		Digital Zoom:	16× or better		
		Noise Reduction	Supported		
		Focus mode:	Auto, Manual		
		Lens			
		Focal Length:	4.3 mm to 129 mm or better		
		Minimum Working Distance:	10 mm to 1500 mm (wide-tele)		
		Aperture Range:	F1.2 to F5.0		
		Pan & Tilt			
		Pan Range:	360° endless		
		Tilt Range:	From 0° to 90°		
		Number of Preset:	250		
		Pattern:	Min-4		
		Infrared			
		IR irradiation distance:	Min 150 m		
		Network			
		System Compatibility	ONVIF support		
		Image Resolution:	1920 × 1080		
		Main Stream:	25 to 30 fps		
		Image Compression:	H.265 or batter		
		Communication Interface:	1 RJ45 10M / 100M Ethernet interface		
		Protocols:	IPv4/IPv6, HTTP, HTTPS, FTP, SMTP, UPnP, SNMP, DNS, DDNS, NTP, RTSP, RTP, TCP/IP, UDP, IGMP, ICMP, DHCP, PPPoE, Bonjour, 802.1x		
		Time synchronization	Auto Time synchronization of camera with NVR		
		Storage:	Built-in memory card slot, support Micro SD/SDHC/SDXC, Min 128 GB		
		Security Measures:	User authentication & Password protection supported HTTPS, 802.1x network authentication		
		General			
		Power Supply:	24 VAC & PoE+		
		Operating temperature/Humidity:	0 °C ~ to 60 °C, less than 90 % RH		
Protection Level:	IP66				

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

		GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gmail.com			
		Make	Axis: Axis Communications AB. Pelco: Pelco, Inc. Honeywell: Honeywell International Inc. Bosch : Bosch Limited Matrix Comsec: MATRIX COMSEC PVT. LTD BEL : Bharat Electronics Limited American Dynamics : Tyco Security Products Vicon: Vicon Industries Inc. Sony : Sony India Pvt. Ltd.		
		Certificate	Either Bureau of Indian Standards (BIS) OR UL certificate.		
		Warranty	Three years		
3	Network Video Recorder- 8 Ch	Software	As per attached ANNEXTURE-C		
		Video/Audio Input			
		IP video input:	8 IP channels		
		Two-way audio input / Output:	1-ch, RCA (2.0 Vp-p, 1kΩ)		
		Video/ Recording I Output			
		Interface	1 HDMI Port		
		VIDEO Compression	H.265 or better		
		Resolution	1920 x 1080		
		Recording Resolution:	8MP, 6MP, 5MP, 3MP, 2MP		
		Decoding / Playback			
		Live view / Playback:	1920×1080		
		Layouts:	Simultaneously min 8 channel for 8Ch & Simultaneously min 16 channel for 16Ch		
		Hard Disk			
		SATA Port:	1 or more Sata port		
		Capacity:	Port support min. 6 TB capacity for SURVEILLANC HDD		
		Network			
		Incoming bandwidth:	200Mbps		
		Outgoing bandwidth:	190Mbps		
		USERS	Min 10 Users		
		Network Interface:	1 RJ-45 port (10/100/1000) Mbps		
		Network Functions:	TCP/IP, DHCP, PPPOE DNS, DDNS, FTP, SMTP, NTP, RTP/RTSP, HTTP, CIFS/NFS, UPnP		
		USB Interface:	Min. 2 USB port (1x USB 3.0, 2x USB2.0)		
		Alarm In	1-Ch		
		Alarm Out	1-Ch		
		General			
		Power Supply:	240 ± 10% VAC , 50HZ		
			Make	Axis: Axis Communications AB. Pelco: Pelco, Inc. Honeywell: Honeywell International Inc. Bosch : Bosch Limited Matrix Comsec: MATRIX COMSEC PVT. LTD BEL : Bharat Electronics Limited American Dynamics : Tyco Security Products Vicon: Vicon Industries Inc. Sony : Sony India Pvt. Ltd.	
			Warranty	Three years	

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

		GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gmail.com		
4	Network Video Recorder- 16 Ch	Certificate	Either Bureau of Indian Standards (BIS) OR UL certificate.	
		Software	As per attached ANNEXTURE-C	
		Video/Audio Input		
		IP video input:	16 IP Ch	
		Two-way audio input / Output:	1 RCA (Audio output) 1 RCA (Audio input)	
		Video/ Recording I Output		
		Interface	1 HDMI Port	
		VIDEO Compression	H.265 or better	
		Resolution	1920 x 1080	
		Recording Resolution:	8MP, 6MP, 5MP, 3MP, 2MP	
		Decoding / Playback		
		Live view / Playback:	1920x1080	
		Layouts:	Simultaneously min 8 channel for 8Ch & Simultaneously min 16 channel for 16Ch	
		Hard Disk		
		SATA Port:	1 or more Sata port	
		Capacity:	For 1 SATA Port- support min. 12 TB capacity for SURVEILLANC HDD or For 2 or more SATA Port- support min. 6 TB capacity for SURVEILLANC HDD	
		Network		
		Incoming bandwidth:	200Mbps	
		Outgoing bandwidth:	190Mbps	
		USERS	Min 10 Users	
		Network Interface:	1 RJ-45 port (10/100/1000) Mbps	
		Network Functions:	TCP/IP, DHCP, PPPOE DNS, DDNS, FTP, SMTP, NTP, RTP/RTSP, HTTP, CIFS/NFS, UPnP	
		USB Interface:	Min. 2 USB port (1x USB 3.0, 2x USB2.0)	
		Alarm In	1-Ch	
		Alarm Out	1-Ch	
		General		
		Power Supply:	240 ± 10% VAC , 50HZ	
		Make	Axis: Axis Communications AB. Pelco: Pelco, Inc. Honeywell: Honeywell International Inc. Bosch : Bosch Limited Matrix Comsec: MATRIX COMSEC PVT. LTD BEL : Bharat Electronics Limited American Dynamics : Tyco Security Products Vicon: Vicon Industries Inc. Sony: Sony India Pvt. Ltd..	
		Warranty	Three years	
		Certificate	Either Bureau of Indian Standards (BIS) OR UL certificate.	
5	POE SWITCH (4-Port)	Ports		
		Network Ports:	5	
		PoE Port:	4, 10/100/1000 Mbps RJ45 ports	
		SFP port	Min. 1 Port	

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
 Zanzarda Junagadh-362 015
 e-mail : setrjunagadh.getco@gebmil.com



		Standard	
		Network Protocol:	IEEE802.3,802.3u,802.3x, 802.3af, 802.3at
		Address Database size	Min 4k MAC Addresses
		Flow Control:	IEEE802.3x full duplex
		Power Over Ethernet	
		PoE Standard:	IEEE802.3af, IEEE802.3at
		Power Budget	Min. 30W
		General	
		Power Supply:	100-240V AC, 50Hz
		Operating Conditions:	-10 °C ~ 60 °C less than 95 % RH
		Make	CISCO : Cisco Systems, Inc Netgear: Netgear Inc HP: HP Development Company, L.P. Allied Telesis: Allied Telesis, Inc. D-Link : D-Link (India) Limited
		Warranty	Three years
6	POE SWITCH (8-Port)	Ports	
		Network Ports:	9
		PoE Port:	8, 10/100Mbps RJ45 ports
		Uplink Port:	1, 1000Mbps Ethernet Port
		Standard	
		Network Protocol:	IEEE802.3,802.3u,802.3x, 802.3af, 802.3at
		Address Database size	Min 4k MAC Addresses
		Flow Control:	IEEE802.3x full duplex
		Power Over Ethernet	
		PoE Standard:	IEEE802.3af, IEEE802.3at
		Power Budget	Min. 65W
		General	
		Power Supply:	100-240V AC, 50Hz
		Operating Conditions:	-10 °C ~ 60 °C less than 95 % RH
		Make	CISCO : Cisco Systems, Inc Netgear: Netgear Inc HP: HP Development Company, L.P. Allied Telesis: Allied Telesis, Inc. D-Link : D-Link (India) Limited
		Warranty	Three years
7	POE + SWITCH (16-Port)	Ports	
		Network Ports:	18
		PoE Port:	16, 10/100Mbps RJ45 ports
		Uplink Port:	2, 1000Mbps Combo Port
		SFP port	Min. 2 port
		Standard	
		Network Protocol:	IEEE802.3,802.3u,802.3x, 802.3af, 802.3at
		Address Database size	Min 4k MAC Addresses
		Flow Control:	IEEE802.3x full duplex
		Power Over Ethernet	
		PoE Standard:	IEEE802.3af, IEEE802.3at
		Power Budget	Min. 150W
		General	

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

		GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gmail.com			
		Power Supply:	100-240V AC, 50HZ		
		Operating Conditions:	-10 °C ~ 60 °C less than 95 % RH		
		Make	CISCO : Cisco Systems, Inc Netgear: Netgear Inc HP: HP Development Company, L.P. Allied Telesis: Allied Telesis, Inc. D-Link : D-Link (India) Limited		
		Warranty	Three years		
8	22” LED Monitor With Wall Mount Bracket.	22” LCD Monitor			
		Max Resolution	1920×1080		
		Interface	RGB IN, HDMI IN, Digital Audio Output		
		Power Supply:	230V, 50Hz		
		Make	Sony: Sony India Pvt. Ltd. LG: LG Electronics India Pvt. Ltd. Panasonic: Panasonic India Pvt. Ltd. Samsung : Samsung India Electronics Pvt. Ltd		
		Warranty	Three years		
9	32 “LED Monitor with Wall Mount Bracket.	32” LCD Monitor			
		Max Resolution	1920×1080		
		Interface	RGB IN, HDMI IN, Digital Audio Output		
		Power Supply:	230V, 50Hz		
		Make	Sony: Sony India Pvt. Ltd. LG: LG Electronics India Pvt. Ltd. Panasonic: Panasonic India Pvt. Ltd. Samsung : Samsung India Electronics Pvt. Ltd		
		Warranty	Three years		
10	6 / 12 TB SURVEILLANCE HDD	RPM	7200		
		Make	Seagate : Seagate Technology LLC Western Digital : Western Digital Corporation		
		Warranty	Three years		
11	1 KVA UPS with 1hr Battery Backup digital display indication	Input Voltage	230 VAC nominal		
		Frequency	50 Hz +/- 1 Hz		
		Output			
		UPS Capacity (total)	1000VA / 600W		
		Output Voltage range	230 V +/- 10% with 50 Hz		
		Voltage on Battery	230 VAC		
		Frequency	On Battery 50 Hz ± 1 Hz		
		Operating Temperature:	-10 °C ~ 60 °C less than 95 % RH		
		Battery	60 AH Maintenance-free		
		Charger	5A		
		Make	APC : Schneider Electric Vertiv Energy Private Limited Numeric (Legard) : Legrand Group or any other reputed make having valid BIS registration.		
		Warranty	Three years		
		Certificate	Bureau of Indian Standards (BIS)		

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



12	6U Rack (Outdoor)	Dimension:	550 x 400 x 350 mm Wall Mount / Floor Standing / Table Mount option, Front door with Toughen Glass & Lockable, Closed Rubber Grommet at Cable Entry
		Complete Body	Top and Bottom of 18 SWG CRCA Material, Door & inside Channels of 16 SWG CRCA Material
			Weather proof & Compatible to accommodate LIU, Switch, PoE adopter etc. and fitted with cable manager and with mounting accessories
		Make	Valrack/APW/Rittal/APW President
13	9U Rack	Dimension:	Width 600 mm and depth 450 mm – Wall Mount / Floor Standing / Table Mount option, Front door with Toughen Glass & Lockable, Closed Rubber Grommet at Cable Entry
		Complete Body	Top and Bottom of 18 SWG CRCA Material, Door & inside Channels of 16 SWG CRCA Material
		Power Distribution Unit	1.5 meter cable length for 240/220V AC Supply having 4 sockets of 5 Amp to be used for other devices.
		Fan	Top mounted 90 CFM Fan (01nos.) with finger guard
		Make	Valrack/APW/Rittal/APW President
14	CAT-6 Armored cable	Size:	Armored CAT-6 (4 Pair) cable design for external use burial and or Arial use, 24 AWG solid copper conductor. Armored GI wire size: 0.9 mm
		Make	D-Link / TYCO / Systimax / Molex / Schneider / Digisol / Commscope / Panduit(Pannet) / Siemon
15	Fiber cable – 6 core cable	Size:	Unitube, Single Mode, Outdoor Direct Burial Cable, Central loose tube with jelly compound, High strength ripcord under armored Cable protected from moisture, suitable for indoor and outdoor use and protected against bending / damage.
		Make	D-Link / TYCO / Systimax / Molex / Schneider / Digisol / Commscope / Panduit(Pannet) / Siemon
16	LC-SC Single Mode Optical fiber duplex patch cord	Size/Length:	LC-SC SM Duplex, the patches to be supplied shall be of full standard optical specifications, length of 1 mtr.
			Terminated connector: compatible with industry standard i.e. EIA/TIA, IEC, ANSI
		Make	D-Link / TYCO / Systimax / Molex / Schneider / Digisol/Commscope/Panduit(Pannet)/Siemon
17	LIU (Line interface Unit) (Optical Fiber interconnecting unit) 06 port fully loaded		- Rack mount type with 06 ports Loaded (SC) SM, pigtail and splice tray. - Aluminum base material for light mounting - Front - mounted cable saddles for jumper management - Can manage both splice and terminations - Preassembled shelves in multiple configuration - Rubber fiber slotted bracket built in, metal splice shelf to protect the fibers - Removable Front and rear covers for better access to interior of LIU - The pigtails to be supplied shall be SC simplex of length 1 meter. The pigtails to be supplied shall be good end face geometry, standard optical specifications, precise length & tolerance.
		Make	D-Link / TYCO / Systimax / Molex / Schneider / Digisol
18	Pigtail		The Pigtails to be supplied shall be LC SM SIMPLEX of length 1 meter. The pigtails to be supplied shall be of good end face geometry, full standard optical specification.
		Make:	D-Link / TYCO / Systimax / Molex / Schneider / Digisol
19	Media Converter		The media converter should support Single Mode fiber and shall be suitable for interfacing with the camera / Ethernet switch.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

20	Power cable	Size:	Un- armored 3 core, 2.5 sq.mm with standard copper conductors
		Insulation:	PVC insulated 1100V grade, FR type suitable for steady temperature of 70 degree C.
		Make: _	Finolex/KEI/ Polycab/Universal/Asian/Delton/Havells
21	Junction Box (Outdoor)	Size:	Whether proof, FR type suitable for IP based CCTV Camera, Dimension: (100 x 100 x 50) mm,
		Make:	Any Standard make
22	HDPE Pipe	Size:	- Dia: Min 25 mm (Inner) - Thick : Min 2.3 mm
		Make:	Any Standard make
23	3 Mtr Pole (Tubular)	Size:	Height: 3 Mtr GI Tubular Poles. Size: Middle 2 Mtr. Long, 88.9mm dia & 3.25mm thick 03-meter heighted pole which to be installed on control room building including clamps and other accessories to be fixed is in the scope of bidder
		Make:	Any Standard make
24	9 Mtr Pole (Tubular) including foundation casting.	Swaged type welded GI tubular pole of Height: 9 Mtrs	
		Size: Bottom 5 Mtr. Long, 114.2mm outer dia & 3.5mm thick, Middle 2 Mtr. Long, 88.9mm dia & 3.25mm thick, Top 2 Mtr long, 76.1 mm dia (outer) and 3.25mm thick. Foundation: 1.5 mtr x 0.450 mtr x 0.450 mtr	
		Pole erection by excavating in any type of soil by providing of M15 Grad concrete (1:2:4) foundation of 1.5 mtr x 0.450 mtr x 0.450 mtr in the scope of bidder	
		Make:	Any Standard make
25	Laying of CAT-6 armor/ Fiber optical cable and Power Cable in PVC / HDPE pipe with all necessary accessories.		
26	Digging suitable width up to 450 mm and back filling in any type of soil for laying of surveillance system cable.		
27	Splicing of Single mode Pigtail with Fiber core		
28	Installation and commissioning charges for CCTV surveillance system including providing & Mounting Stand for LED and brackets for IP Bullet/PTZ camera, Patch cord, LIU, power adopter, HDMI cable, connectors, required splicing of cable etc. as per tender terms and condition. All equipment under this package is to be installed in various substation. The OFC cable and Power cable shall be laid in HDPE conduits either in cable trenches or underground depending upon site requirement. If it is underground the depth of trench shall not be less than 2 feet. Civil work if any during the installation activity shall be carried out by the bidder without any extra financial implication to GETCO.		

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

Software for Network Video Recorder (NVR)

Software for 8 Channel / 16 Channel NVR:

The Software should be designed for open platform and no proprietary hardware required for installation of the software. It should be completely scalable CMS/ CCTV system. The software should support Min. 2 Mega pixel and higher camera and should facilities viewing up to Full HD/ H.265 (0 to 30 fps) on the work station. Recording can be scheduled for the various video source with different frame rates.

Sitemap:

- **Alarms:** The alarms are displayed in the sitemap, enabling the user to take timely action.
- **Field of view:** The user can create field of view of the cameras, indicating the area of coverage.

Recording and playback

- **Video:** An optional streaming is available for rendering additional streams for recording and live viewing. Video Recording on Selected Channel.
- **Search Mode:** Date and Time, Camera, Event, Recording Type
- **Playback Modes:** Fast Forward, Slow Forward, Slow Reverse, Fast Reverse at Different Speed Control, Next Previous Frame
- **Export:** Exporting the video data in native format with multiple file export option makes it a hassle free export and playback of the video sequence. Manual Backup over USB through USB2.0 / USB3.0 interface

Events and controls

- **Alarms:** Supports inbuilt video analytic alarms such as Face detection, Boundary Crossing detection, camera occlusion, Unexpected activity detection, Motion Detection, View Tampering, Connection Failure, Recording Failure, Storage Alert, Disk Volume Full, Disk Fault, Scheduled Backup Fail.
- **Event action:** Automatic actions can be configured per camera for each event. The actions supported comprise SMS, email with Snapshot, camera pre-set, Turn On/Off Alarm Outputs, Buzzer Notification.
- **PTZ controls and digital zoom:** Digital zoom supports both on live and recorded videos.
- **Snapshots:** The snapshot of any camera in the tile can be taken and saved in the database for future investigation and evidence purposes.
- **Camera discovery:** IP cameras of different makes and models can be added automatically. Manual and bulk additions of cameras are also supported.

Reports:

A comprehensive reporting on the alarms, event logs, health status of the devices such as IP Camera, Server and Workstation are provided.

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

Type Test for Bullet Camera, PTZ Camera & NVR

(1) Following Type Test certificates shall be submitted in Technical specification for IR bullet camera and PTZ camera.

S/n	Test Name	Type Test Standard	Confirmation (Tick ✓ any one)
1	Electrical Fast Transient/burst immunity test (EFT)	IEC 61000 – 4 - 4	YES / NO
2	Damped Oscillatory (1MHz & 100 KHz)	IEC 61000 – 4 – 18	YES / NO
3	AC Voltage Dips & Interruption and voltage variation immunity test	IEC 61000 – 4 – 11	YES / NO
4	Electrostatic immunity test	IECv61000 – 4 – 2	YES / NO
5	Power Frequency Magnetic Field	IEC 61000 – 4 – 8	YES / NO
6	Ripple on DC input Power Supply Port immunity test	IEC 61000 – 4 – 17	YES / NO
7	Immunity to conducted disturbance, induced by radio-frequency fields	IEC 61000 – 4–6	YES / NO
8	Radiated, radio-frequency, electromagnetic field immunity test	IEC 61000 – 4–3	YES / NO
9	Surge immunity test	IECv61000 – 4–5	YES / NO
10	Limits for harmonic current emission (equipment input current ≤ 16A per phase)	IEC 61000– 3–2	YES / NO
11	Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection	IEC 61000– 3–3	YES / NO
12	Audio/Video, information and communication technology equipment-part 1: safety requirement	IEC 62368-1:2018	YES / NO
13	For FCC	47 CFR FCC Part 15-Sub part B (Class B) ANSI:2009	YES / NO
14	For IP66	IS/IEC 60529:2001 Clause No. 12.2,12.3,13.4,13.6,14.2.6,14.3	YES / NO
15	For Vibration	IEC 60068-2-6:2007	YES / NO
16	For IK10	IEC 62262:2002	YES / NO

***** The validity of Type Test shall be 7 years.**

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.**

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmail.com



(2) Following Type Test certificates shall be submitted in Technical specification for NVR.:

S/n	Test Name	Type Test Standard	Confirmation (Tick √ any one)
1	For CE (EMI-EMC)	IEC/EN 61000-3-3:2003 CISPR 22:2008 CISPR 24:2010 IEC/EN 61000-3-2:2005 + A1:2008 + A2:2009	YES / NO
2	For FCC	47 CFR FCC Part 15-Sub part B (Class B) ANSI:2009	YES / NO
3	For Safety	IEC/EN 60950-1:2005 + A1:2009+A2:2013	YES / NO

*****The validity of Type Test shall be 7 years.**

All Type test for Bullet camera, PTZ Camera & NVR are mandatory and submit along with GTP.

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

A/T ACCEPTANCE LETTER

TO BE SUBMITTED ON FIRM'S LETTER HEAD

Ref. No. _____

Date: _____

To,
 The Superintending Engineer (TR)
 Gujarat Energy Transmission Corporation Ltd,
 Circle Office, Dhandhusar Road,
 Opp Nandbava Gaushala, 66KV Zanzarda Substation,
 Junagadh – 362015 (Gujarat)

Sub: WORK OF **'Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh'.**

Ref Order No. _____

We hereby acknowledge, agree and accept your A/T under reference above with terms and conditions mentioned therein.

(Signature) _____

Designation _____

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

Application For Refund Of EMD

To,
 The Superintending Engineer (TR)
 Transmission Circle
 GETCO Junagadh

Sub: - Application For Refund Of EMD

Respected Sir,
 I request your good self to refund my EMD for the tender mentioned blow as soon as the price bids are opened and if I/We am /are not the L1 for the same. The details are as under....

Tender No.	TCJND/2026-27/N-89
Tender ID	
Name of work/subject	'Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh'
EMD Amount	
EMD transaction ref. No., Date & Name of Bank	
Name of Bidder	
Contact No.	
E-mail address	
Bank detail for RTGS into which EMD is required to be refunded	

Thanking You,
 Faithfully Yours,

(Name & Seal of Bidder)

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

Price Bid

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

TENDER NOTICE NO: TCJND/2026-27/N-89

SCHEDULE-B (PRICE BID)

NAME OF WORK: 'Erection, testing & commissioning work of structure, earthing, switchyard yard Lighting, office & Godown Electrification, CCTV camera surveillance system and supply of Furniture etc. at new Construction store Keshod, under Construction Division Junagadh'.

SCHEDULE B-1: STRUCTURE ERECTION & EARTHING					
Sr. No.	Description of work/Supply	Unit	Total Qty.	Rate	Amount in Rs.
1	Erection of S/S & Equipment structure including punching of nut bolts. Rates are inclusive of shifting of same up to erection site from its s/s Store. 66 KV	MT	7.75	2491	19305.25
2	Installation of earthing strips / MS round bar in any kind of soil except Rocky (HR/SR) Soil as per earthing philosophy of GETCO Earthing Grid: 1) Including digging of 600mm depth and 450mm wide trench. 2) Cutting, bending, laying and fixing of Earthing grid conductor. 3) 75x10mm / 50X6mm GI strips: Fixing of two bolt at each straight joints and lap welding, removing oxide films formed during welding, applying two coats of red oxide and black powder after welding and applying zinc rich paint on welded joints. 4) 25/32/36/40mm dia MS Rod: Lap welding at each straight & cross joints, removing oxide films formed during welding, applying two coats of red oxide and black powder after welding and applying zinc rich paint on welded joints. 5) Including supply of red oxide paint, black powder, HDGI Nuts & bolts as per specification. 6) Back filling of the trench with yellow/ Normal sold. Structure & Equipment earthing: 1) including digging of 600mm depth and 450mm wide trench. 2) Cutting, bending as per required shape, laying and fixing of risers from Grid to structures and Equipments. 3) Lap welding, removing oxide films formed during welding, applying two coats of red oxide and black powder after welding and applying zinc rich paint on welded joints including supply of HDGI Nuts & bolts for all connections including supporting to structures etc as per specification. 4) Back filling of the trench with yellow/ Normal soil. -50 x 6 mm GI strip / MS round bar up to and including 25mm	Mtr	200	43	8600.00

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

		GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gebmil.com				
3	Providing Bore type earthing with drilling of minimum 200mm dia bore upto following mentioned depth in Rocky (HR/SR) Soil as per earthing philosophy of GETCO. 1) Work includes inserting 40 mm dia MS Rod in bore depth and to be connected to the earthing grid at junction point by proper welding at both end. 2) This includes cutting, fabrication & welding of flat. 3) Refilling and compression of surrounding areas with Normal/yellow soil, ground enhancement material etc. wherever applicable as per approved Soil strata and earthing design calculation. 4) Required G.I. Earthing strip/ MS rods will be supplied by GETCO Free of Cost. 5) Earthing material like Normal/yellow soil, ground enhancement material (0.5CMT/Meter depth), water, etc. shall be supplied by contractor. -- 09 Mtr Depth	No	10	2615	26150.00	
4	Supply,Installation,Testing and commissioning of maintenance free treated earth electrodes suitable for NORMAL SOIL as per drawing No. GETCO/E/STD/P-021 (1 OF 2) R3 dated 29-05-2020 and technical specifications GETCO/E/TS-Maintenance free earth pits/R1 dated 04-06-15 for 66/11 kV substations with ground enhancement material/ back fill / grounding compound as per IEEE 80-2000 Clause 14.5 (d) and as per part-7 of IEC-62561 Using Copper bonded earth electrode (with 250 micron copper coating) having 24 mm dia (min) and 3000 mm length which shall be capable of handling STC of 25 KA-1 sec. Work also includes Providing BB masonry inspection chamber(manhole) incl. light type CI cover.	No	2	13893	27786.00	
5	Providing of M15 Grade Concrete for various equipment structure, Guy, 11kV DP, M.K. Box, Neutral channels, cable support channel, grouting of Pole/ Flood light structure with cement, sand & metal in proportion of 1:2:4 respectively. 1) Work includes muffing with smooth cement mortar (1:6) finish. 2) Necessary sand, metal, water & cement shall be supplied by the contractor.	Cmt	7.00	5276	36932.00	
6	Excavation in Hard Rock for excavation of Earthing Pits / 11kV or LT power cable trench/ Yard Light Poles only.	Cmt	3.00	525	1575.00	
7	Providing and fixing of various type of sign Board, sticker, Big Sign Board, earthing pit Board & Single line diagram etc. as per instruction of IEC. Sticker of red, white, black Letters are to be utilized for various sign board.	Job	1	24957	24957.00	
	Earthing Pit Board Size:- 6" x 6" -30 Nos.					
	Safety Slogan Board, Hard Sheet board size 2' x 2'and 4mm thick (Gujarati Language)- 2 Nos.					
	Safety Slogan Board, Hard Sheet board size 3' x 2'and 4mm thick (Gujarati Language) with red and Yellow colour.-03 Nos.					
	Single line diagram size 5' x 3' Digital with Aluminum frame with fitting and as per approved diagram given by IEC.-01 No.					
Sign & Stamp of Contractor						
Regd. Corporate office: Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007. Corporate Identity No. (CIN): U40100GJ1999SG036018 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcoqujarat.com						



GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



	Big sign board size 5' x 4' and 2mm thickness indicating sub station name digital with S.S. rod with hole & as per approved symbol with fitting charge.- 01 No.				
	Switch yard sign Board 12" X 6" with 2 mm Thickness black & white Gujarati language.-25 Nos.				
	Safety Slogan Board size 2" x 6" in side control room.- 05 Nos.				
	Various type of control room equipment sticker size-24 cms x 5cms.--18 Nos.				
	Safety picture board size :- 3' x 3' (Laminated for O/D use)-03 Nos.				
	Name plate board of transformer size :- 2' x 1'- 04 Nos.				
	Cable marker size:- 6" x 6", Radium, fixed on 750mm long M.S.Rod for fixing arrangement.- 30 Nos.				
8	Providing and Fixing of fire stand made from 75mm dia GI pipe A class ISI mark heavy duty having 5ft width and 4ft height as per inst of Engr. In charge 1) Work includes cutting, drilling, welding of pipe as required. Fabrication and supply of 16mm dia meter hook size required for hanging the buckets. 2) 4 Nos.of fire buckets are to be provided by the contractor. 3) Fire stand should grouted with excavation of pit size 300mm x 300mm-2 Nos. of 600mm depth with 1:3:6 mix mulling 300mm in height including leveling of stand. 4) The fire stand is to be painted with post box red colour of approval quality as per instruction of EIC. 5) All required approved material including cement, sand, metal etc are to be provided by contractor.	Job	3	4992	14976.00
9	Providing & fixing of reputed make ISI mark Fire Extinguisher with latest amendment in standards as per following capacity Note: Contractor shall submit Test certificate for routine test as per relevant IS. Chemical powder 9 kg	No	4	6301	25204.00
10	- Do - but for CO2 type - 6.5Kg	No	4	7047	28188.00
11	- Do - but for CO2 type - 22.5Kg	No	4	17817	71268.00
12	- Do - but for Mechanical foam type - 50Ltr	No	2	14499	28998.00
TOTAL - 1 (SCHEDULE B - 1)					313939.25
SCHEDULE B - 2 : YARD LIGHTING					
Sr. No.	Description of work/Supply	Unit	Total Qty.	Rate	Amount
13	Providing & fixing of all weather proof, cold rolled sheet steel AC Panel - 2 for Yard-Light AC supply having (1) 63A 4P MCB : 01 No. (2) MCX-12A contactor : 01 No. (3) Digital Timer : 01 No. (4) 20A TPN MCB : 06 Nos (5) Indication lamp " 03 Nos (6) Push Butten : 02 Nos (7) Terminal Connector as per site requirement and other detail as per drawing enclosed including grouting & Necessary fabrication of GI Angle or fixing on GI Structure, including earthing with main grid as per instruction of EIC.	No	2	24732	49464.00

Sign & Stamp of Contractor

Regd. Corporate office:

Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.

Corporate Identity No. (CIN): U40100GJ1999SG036018

Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

	GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gmail.com				
14	Providing & fixing of all weather proof, cold rolled steel sheet floor mounted fixed type single door grey color Main AC Dist box having size 900x600x250 MM with door closing arrangement and necessary rubber gasket. Contractor has to supply following materials with box along with necessary mounting and wiring. (1) L&T/Anchor/Havells Make 100A,4P MCCB - 1 No. (2) L&T/Anchor/Havells Make 63A,4P MCB - 2 Nos. (3) 100 A Copper Bus-Bar Link - length 6 inch size & 25 x 3 MM - 4 Nos. (4) Tinned Earth Bus 25 x 3 MM Length - 32 Inch - 1No. (5) 25 & 16 sqmm Cu. flexible cable - 4 & 8 Meter respectively. (6) Required Nos. of Cu. Lugs , etc. as per instruction of EIC.	No	1	20650	20650.00
15	Supplying & laying of following size Control/ L.T. power cable in readymade cable trench or by excavating in any type of soil cable trench size 300mm wide 600mm depth and refilling the same as per the direction of EIC. Item Includes the cable laying upto termination box with clamps & proper clamping of cable on gantries by GI pipe & glands as per direction. Item includes providing & supply of bircks, sand as per requirement. The L.T power cable to be provided by contractor as under :As per ISI 1554 (Part-I). 3.5 Core x 50 mm2 Alluminium cable -Armoured, from distribution X'mer to Main AC Distribution box near dist. X'mer - both 2 runs.	Mtr	50	292	14600.00
16	Supplying & laying of following size Control/L.T power cable of FINOLEX or equivalent ISI make in readymade cable trench or by excavating in any type of soil cable trench size 300mm wide and 600mm depth and refilling the same as per the direction of EIC. Item Includes the cable laying up to termination box with clamps & proper clamping of cable on gantries by GI pipe & glands as per direction. Item includes providing & fixing of bricks, sand as per requirement to protect cables . The L.T power cable to be provided by contractor as under :As per ISI 1554 (Part-I). 4 Core x 25 mm2 Aluminum cable -Armored, from Main AC Dist box to Yard Light AC MK (AC Panel-2), AC Panel 1 in storerooms (Godowns) and yard AC Box	Mtr	245	175	42875.00
17	- - do - - as per item no. 16, but 4C x 4mm2 Copper cable - Armoured, from yard-light AC MK (AC panel-2) to all yard-light fixture junction boxes on LM & street light light pole & Station transformer to Colony & LT panel to watchman cabin. Note: Cable Laying work either in ready made cable Trench or by excvating in any type of soil if required.(Only laying. Cable will be supplied by GETCO)	Mtr	705	19	13395.00
18	- - do - - as per item no. 16, but 4C x 2.5mm2 Copper cable - Armoured, from yard-light AC MK (AC panel-2) to all junction boxes on post top lantern. Note: Cable Laying work either in ready made cable Trench or by excavating in any type of soil if required.(Only laying. Cable will be supplied by GETCO)	Mtr	95	19	1805.00

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



19	Providing & fixing of 'B' class ISI marked GI. Pipe of 32/40mm dia for cable looping & road crossing with necessary elbow/ bend for each pole & J.Box for yard lighting & for control-room flood light wiring work with fixing on wall with shadles if required as per inst. Of EIC.	Mtr	75	180	13500.00
20	Providing & erection of 7.0 Mtr. long swaged type welded GI tubular street light pole on the foundation in any type of soil as per inst. of E.I.C. confirming to relevant IS and as per attached Drawing No. GETCO/E/STD/LTG.POLE -R2, DT-24-12-2019	No	11	9983	109813.00
21	Supply and fixing of Pole/Wall/Structure mounted FRP junction box of any standard reputed make of required size with clamp, providing 1 SPN MCB, of 16 A having short ckt breaking capacity of 10kA peak of standard ISI make like L&T/ANCHOR/MDS /HAVELLS & 2 Nos. of stud type connector of standard make like Connectwell. The cable glands & lugs are also included for both incoming & out going cables Amp. of standard make like MDS/HAVELLS.	No	58	748	43384.00
22	Earthing to tubular pole/luminaries, by coil type earthing at 10 SWG, GI wire in earth pit of 1.5 mtr. Depth in any type of soil by using salt/ coke (charcole) 16 kgs each & remaining filling with yellow/ Normal soil & clamping the earth wire with pole & Junction box.	No	28	400	11200.00
23	Providing and fixing of 1 x 250-Watt LED luminaries - Energy Efficient flood light with complete allied accessories having features like powder coated, aluminium housing, heat resistant toughened glass provided with gasket (Philips / CGL/ Bajaj / GE/ Osram / Wipro make). Luminaries to be fixed on swaged pole / GI structure by providing required fabrications & 4 core 2.5 sqmm double insulated flexible stranded wire should be used from fittings to approved SMC type junction box as per inst. of E.I.C.	No	43	11576	497768.00
24	Providing & Fixing of LED Street Light Fixtures (1X120W) (CGL Cat No. LSTO120/CDL 120W or equivalent under Cat-II or above as per R&B SOR), 4-core 2.5mm2 double insulated flexible stranded wire should be used from control gear fittings to approved SMC type junction box as per inst. of E.I.C.	No	13	9593	124709.00
25	Providing & fixing of 1x40W LED Post Top Lantern fixtures (CGL Cat No. LPTO-40/CDL 40W or equivalent under Cat-II or above as per R&B SOR) complete fitting in all respect and 4 core x 2.5 mm2 double insulated PVC flexible copper cable from control gear fitting to SMC junction box as per instruction of E.I.C. (4 No. are to be provided on Main gate & 3 No. are to be provided on 4.5Mtr Tubular pole)	No	4	7556	30224.00
TOTAL - 2 (SCHEDULE B - 2)					973387.00

Sign & Stamp of Contractor

Regd. Corporate office:

Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.

Corporate Identity No. (CIN): U40100GJ1999SG036018

Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

		GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gmail.com				
SCHEDULE B - 3 : CONTROL ROOM INDUSTRIAL ELECTRIFICATION						
Sr No	Description of work/Supply	Unit	Total Qty.	Rate	Amount	
26	Providing and fixing of DBS as AC Panel - 1 for CR of ISI marked Powder coated Pearl DBS of ivory color , wall mounting, Double door Distribution board of L&T, Heggarr or higher make fitted with 63Amp Phase Bus bar, Earth / Neutral Bars and inter connecting wires with removable bottom gland plates for all power cable entry from bottom with DIN Channel ,incoming contact and 1No. - 63Amp TPN MCB 'C' Series, 6Nos. - 20A SP MCB 'C' Series and 13Nos. -10A SP MCB 'C' Series All MCBs are L&T, Anchor or Higher make only. Complete in all respect and as per instruction of EIC.	No	9	6738	60642.00	
27	Supplying & laying of following size Control/L.T power cable of FINOLEX or equivalent ISI make in readymade cable trench or by excavating in any type of soil cable trench size 300mm wide and 600mm depth and refilling the same as per the direction of EIC. Item Includes the cable laying up to termination box with clamps & proper clamping of cable on gantries by GI pipe & glands as per direction. Item includes providing & fixing of bricks, sand as per requirement to protect cables . The L.T power cable to be provided by contractor as under :As per ISI 1554 (Part-I). 4 Core x 25 mm2 Aluminum cable -Armored, from LT panel board (LTPB) to Yard Light AC MK (AC Panel-2)., AC Panel 1 in C.R. and yard AC Box	Mtr	695	175	121625.00	
28	Supplying & Laying Sub-main lines of 3X2.5 mm2 (two for P & N and one for Earthing) copper PVC insulated wire of ISI brand in suitable standard make steel conduit pipe having minimum 1.5 mm thickness of approved brand with ISI brand with clamps with it's associated accessories for various circuits emanating from AC panel 1.as per inst. of E.I.C.	Rmtr	600	125	75000.00	
29	Point wiring for control room tube lights, fans, exhaust fans, fancy lights, water tight bulk head lights with PVC insulated 660 V grade standard copper wire in ISI make GI conduct pipe 20 mm dia and 1.6 mm wall thickness size fitted with saddles on the wall/ceiling. Size of wire shall be with 3C x 1.5 sq.mm PVC insulated copper wire for phase and neutral and earth wire [Green] and 5 Amp Anchor/Roma or any equivalent switch as per specification with 16 gauge M.S. box. The box shall be covered with 3 mm thick decorative mat finish hilum sheet. The work is all inclusive of supply and fixing of required materials as afore said [like GI conduct pipe , saddles , switches , Steel box , ceiling Rose , flexible copper wire etc] to complete point wiring with each fixture to be earthed by SWG-12 stranded copper conductor having green color as per direction and instructions of E.I.C.	Point	226	1298	293348.00	

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebm.com



30	Providing and Fixing points wiring in GI. Conduit size 20 mm dia and 1.6 mm wall thickness with single PVC insulated 2.5 Sqmm. copper wire of ISI standard good quality using 1.5mm thick suitable size ISI mark Anchor brand 15 Amp. 250 Volt, 5-pin plug socket as separate plug point with shock proof accessories incl. indication lamp; erected on separate decorative mat finish hylum sheet board on wall with providing adequate green earthing wire as per specification and instruction of Engineer Incharge.	Point	15	1213	18195.00
31	---- Do ---- as above but with single PVC insulated 3Cx1.5 sq. mm.copper wire of ISI mark plug socket for 5A domestic use separate plug points per direction and instruction of E.I.C.	Point	18	814	14652.00
32	---- Do ---- as above but looped on same board i.e. No separate board, plug socket for 5A domestic use as per direction and instruction of E.I.C.	Point	50	199	9950.00
33	Providing and fixing of 1200mm ceiling fan CGL/ORIENT/USHA make white colour with all required accessories. Fan is to be purchased from authorised dealer. Flexible wiring using twin core double PVC 48/0.2 mm copper flexible cord of suitable & approved make and size from ceiling rose upto fan terminal & supply and fixing of energy saver regulators, extra GI pipe of required size and length for lowering of fan if required as per instruction of EIC.	No	47	1597	75059.00
34	Providing & Fixing of 50 W LED Lighting Fixture (CGL Cat No. LCTLR-50-FO-CDL 50W or equivalent under Cat-II or above as per R&B SOR), 4-core 2.5mm ² double insulated flexible stranded wire should be used from control gear fittings to approved SMC type junction box as per inst. of EIC.	No	98	5059	495782.00
35	Providing and fixing of 41.5W LED Lighting Fixture (CGL Cat No. LPFC-36-CDL 41.5W or equivalent under Cat-II or above as per R&B SOR) as per instruction of EIC.	No	0	3154	0.00
36	Providing and fixing of 40W (1X4) LED Lighting fixtures as per drawing (in office area & Porch Area) (CGL Cat No. LCTLSN-40-CDL (1X4) 40W or equivalent under Cat-II or above as per R&B SOR) as per instruction of EIC.	No	20	3417	68340.00
37	Providing & fixing of 30W LED Street Light Bulkhead (CGL Cat No. LSTO-30-CDL 30W or equivalent under Cat-II or above as per R&B SOR) on out side C/R building and inside cable trench in C/R including wiring from ceiling rose to fixture with suitable size of PVC insulated ISI marked copper wire only as per Instruction of EIC.	No	0	2678	0.00
38	Providing and fixing of heavy duty exhaust fan in battery room size 18" of Make GEC/KHAITAN/ CROMPTON/ BAJAJ incl. M.S. louver shutter of Fan & necessary wall finishing works and applying bird proof net on outside wall with required arrangement for rain water sealing and necessary connection from ceiling rose as per Direction and instruction of EIC.	No	8	3494	27952.00

Sign & Stamp of Contractor

Regd. Corporate office:

Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.

Corporate Identity No. (CIN): U40100GJ1999SG036018

Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

	GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gmail.com				
39	Providing & Fixing of Electric bell with bell switch near officer's table. All materials must be ISI mark and approved by EIC.	No	1	149	149.00
40	Providing and fixing of 18W LED Lighting Fixture (CGL Cat No. LCTL-18-CDL 18W or equivalent under Cat-II or above as per R&B SOR) as per instruction of EIC	No	23	1281	29463.00
41	Providing earthing to quarter with 10SWG copper earth wire connecting to required installations. This work include preparation of earth pit of size 0.5M x 0.5M x 1.5M depth and back filling by using Solt, Charcoal 16 Kg. Each, 2Mtr. Long heavy duty 19mm PVC pipe and yellow/ Normal soil with C.I. earthing plate of 10Kg weight. as per Inst. of EIC. Required all material to be supplied by contractor.	No.	15	499	7485.00
42	Providing & fixing of Wall Mounted Fan Crompton / Orient/ PSPO / Usha / Cinni (must be ISI approved). including wiring from ceiling rose to Fan terminals of by using twin core flexible PVC to PVC 48 / 0.2 mm copper cord of suitable & approved size & fixing of Fan regulator.	No.	1	1597	1597.00
TOTAL - 3 (SCHEDULE B - 3)					1299239.00
SCHEDULE B - 4 : SUPPLY, INSTALLATION AND COMMISSIONING OF CCTV CAMERA SURVEILLANCE SYSTEM					
Sr No	Description of work/Supply	Unit	Total Qty.	Rate	Amount
43	Supply of IP Bullet Camera (2MP) with bracket & mounting accessories, as per technical specification and tender terms and conditions.	No	22	8395.35	184697.70
44	Supply of IP PTZ Camera (2MP) with bracket & mounting accessories, as per technical specification and tender terms and conditions.	No	4	68488.78	273955.12
45	Supply of Network Video Recorder (16 Ch) in built 12 TB SURVEILLANCE HDD , as per technical specification and tender terms and condition	No	2	48898.95	97797.90
46	Supply of POE SWITCH 4 Port with 01 nos SFP port, as per technical specification and tender terms and condition.	No	0	33952.48	0.00
47	Supply of POE SWITCH 8 Port with 02 nos SFP port with 02 SFP module, as per technical specification and tender terms and condition.	No	6	34198.51	205191.06
48	Supply of 32" LED Monitor With Wall Mount Bracket, as per technical specification and tender terms and condition	No	2	33152.87	66305.74
49	Supply of 1 KVA UPS, as per technical specification and tender terms and condition	No	2	24258.40	48516.80
50	Supply of Powder coated 9 U RACK, as per technical specification and tender terms and condition	No	2	10874.84	21749.68
51	Supply of CAT-6 (4 Pair), Armoured cable, as per technical specification and tender terms and condition.	Mtr.	1490	80.66	120183.40
52	Supply of un-armored 3 core, 2.5 sq.mm with standard copper conductors power cable, as per technical specification and tender terms and condition.	Mtr.	775	96.80	75020.00

Sign & Stamp of Contractor

Regd. Corporate office:
 Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
 Corporate Identity No. (CIN): U40100GJ1999SG036018
 Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com



GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED
TRANSMISSION CIRCLE OFFICE, JUNAGADH.

66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road,
Zanzarda Junagadh-362 015
e-mail : setrjunagadh.getco@gebmil.com



53	Supply of Standard ISI marked weather proof Junction box, as per technical specification and tender terms and condition	No	16	529.37	8469.92
54	Supply of HDPE pipe, as per technical specification and tender terms and condition	Mtr.	1490	50.42	75125.80
55	Supply of 3 mtr Long GI Tubular Pole, as per technical specification and tender terms and condition	No	4	13285.75	53143.00
56	Laying of CAT-6, armour cable and Power Cable in PVC / HDPE pipe with all necessary accessories as per technical specification and tender terms and condition	Mtr.	1490	14.12	21038.80
57	Digging suitable width upto 450 mm and back filling in any type of soil for laying of surveillance system cable.	Mtr.	1490	148.22	220847.80
58	Installation and commissioning charges for CCTV surveillance system including providing & Mounting Stand for LED and brackets for IP Bullet/PTZ camera, Patch cord, LIU, power adopter, HDMI cable, connectors, required splicing of cable etc. as per tender terms and condition.	No	1	3690.49	3690.49
TOTAL - 4 (SCHEDULE B - 4)					1475733.21

SCHEDULE B - 5 : FURNITURE ITEMS

Sr No	Description of work/Supply	Unit	Total Qty.	Rate	Amount
59	Supply of Steel Chair 'S' type, overhanging arm with cushion with cane seat/ 1" x 16" gauge round pipe frame complete as per instruction of EIC & procurement from Adult training center for the blind, Ahmedabad	No.	3.00	3555.00	10665.00
60	Supply of Office Chair 'A' type, cushion tapestry with handle as per instruction of EIC & procurement from Adult training center for the blind, Ahmedabad	No.	3.00	3900.00	11700.00
61	Supply of Steel Rack of medium size 36" x 14.4" x 54" with four partitions, prepared with 20 gauges as per instruction of EIC & procurement from Adult training center for the blind, Ahmedabad	No.	3.00	4900.00	14700.00
62	Supply of Steel Table of size 60" x 36" x 30" one side three drawers, one side full drawer with Nova PAN Pre-laminated top complete with locking arrangement to drawers & self as per instruction of EIC & procurement from Adult training center for the blind, Ahmedabad	No.	3.00	16050.00	48150.00
63	Supply of Computer Table from pre-laminated board with Key board facility and drawer with locking facility with continuous printer out facility & mouse tray and also with special tray for CPU & UPS having size 42" x 24" x 30" complete as per instruction of EIC & procurement from Adult training center for the blind, Ahmedabad	No.	3.00	8580.00	25740.00
64	Supply of Steel revolving Chair, revolving & tilting, low back high type seat with foam rubber 3" in seat 2" in back with good quality raxine cover, five legs. Chromium plated frame complete as per instruction of EIC & procurement from Adult training center for the blind, Ahmedabad	No.	3.00	9300.00	27900.00

Sign & Stamp of Contractor

Regd. Corporate office:

Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.

Corporate Identity No. (CIN): U40100GJ1999SG036018

Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com

	GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED TRANSMISSION CIRCLE OFFICE, JUNAGADH. 66KV Substation Compound, Opp Nandbava Gaushala, Dhandhusar Road, Zanzarda Junagadh-362 015 e-mail : setrjunagadh.getco@gmail.com				
65	Supply of Steel Cupboard, of size 78" x 36" x 18" four partition, door & Shelves 20 gauge complete as per instruction of EIC & procurement from Adult training center for the blind, Ahmedabad	No.	2.00	14200.00	28400.00
TOTAL - 5 (SCHEDULE B - 5)					167255.00
SUMMARY					
SUB TOTAL-1 (SCHEDULE B-1)					313939.25
SUB TOTAL-2 (SCHEDULE B-2)					973387.00
SUB TOTAL-3 (SCHEDULE B-3)					1299239.00
SUB TOTAL-4 (SCHEDULE B-4)					1475733.21
SUB TOTAL-5 (SCHEDULE B-5)					167255.00
ESTIMATE TOTAL AMOUNT (1+2+3+4+5)					4229553.46
Applicable GST (CGST+SGST) 18%					761319.62
GRAND TOTAL AMOUNT IN RUPEES					4990873.08
IN WORDS AMOUNT: RUPEES FORTY-NINE LACS NINETY THOUSAND EIGHT HUNDRED SEVENTY-THREE AND EIGHT PAISA ONLY					

Note:

- Quantity of works will be as per actual work executed for erection, testing & commissioning work of 66kV equipments, structures, control wiring, earthing, yard lighting etc. for new 66kv Sub-stations and Line. Earthing work will be as per approval of Earthing Design.
- All erection work is to be carried out as per the manual of OEM (Original equipment manufacturer) and instruction of Engineer-in-charge.
- All equipment erection charges are inclusive of shifting dragging handling of the respective equipment up to S/S erection site from its S/S site store but exclusive of service tax.
- Contractor has to ensure safe shifting dragging erection of all equipments to comply with labour laws I.E. rules etc.
- All erection charges are inclusive of fixing of clamp connectors, all necessary accessories to the respective equipment.
- Transformer erection charges cover shifting dragging, handling etc. for its bushings radiators conservator tank and allied accessories.
- All erection work includes marine cum erection insurance to be arranged by the contractor at his cost.
- All the required tools and tackles like conductor, earth wire compression, jointing machine, cutting machine, welding set etc. are to be arranged by the contractor at his cost.
- According to Head office letter no.: ACE(Proc)/V/Furniture/2016-17/2943 Date 01-03-2017, the furniture items should be purchased from 'M/s, Adult training center for blind - Ahmedabad (Andhjan Mandal)' only.
- Red oxide & zinc rich paint shall be applied after tack welding of nuts.
- The above rates are with supply of cement by the contractor.
- The rate indicated above included taking delivery of all stringing material from contractor's store / GETCO's store keeping them in safe custody and transporting the same to erection site.
- GST TDS 2% Deducted on basic amount If applicable (w.e.f from 01.10.2018.)
- GST & Welfare tax shall be reimbursed on production of proof of such payments made by the contractor to the appropriate department.

CERTIFICATE

I/We have read and clearly understood the terms, conditions, Schedule 'B' and Technical specifications & hereby accept all the conditions and specifications of this tender document and accordingly, I/We am/are ready to carry out the above work at _____ % above/ below (In word _____ % above/ below) of the estimated rates of GETCO. **(The price bid shall be submitted through n-Procure (ncode) only).**

Sign & Seal of Agency / Bidder

Superintending Engineer
GETCO, circle Office, Junagadh

Sign & Stamp of Contractor

Regd. Corporate office:
Gujarat Energy Transmission Corporation Limited, Sardar Patel Vidhyut Bhavan, Race Course, Vadodara-390007.
Corporate Identity No. (CIN): U40100GJ1999SG036018
Phone: (0265) 2310582 – 86, Fax: (0265) 2337918, 2338164 Web site: www.getcogujarat.com