



**PRASARBHARATI
INDIA'S PUBLIC SERVICE BROADCASTER
CIVIL CONSTRUCTION WING : ALL INDIA RADIO
OFFICE OF THE SUPERINTENDING ENGINEER (ELECTRICAL)
DOORDARSHAN BHAWAN : GOLF GREEN
KOLKATA : 700095**

APPROVED NIT

Name of work :- S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala.

NIT No :- SE(E)/CCW/AIR/Kol/NIT/05 of 2026-27; Date : 31.07.2026 (2ND RECALL)

Estimated cost :- Rs. 30,46,890.00

Earnest money :- Rs. 60,938.00

Period of completion :- 02 (Two) Months.

Executive Engineer (E)
CCW :: AKASHVANI :: Guwahati

-2-
I N D E X

Name of work : - “S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala.”

SL.NO.	DETAILS	PAGE NO.
1.	COVER PAGE	1
2.	INDEX	2
3.	NOTICE	3
4.	INFORMATION AND INSTRUCTIONS FOR CONTRACTORS FOR E-TENDERING	4 - 9
5.	C.P.W.D. 6 (NIT)	10 - 15
6.	INTEGRITY PACT	16 - 21
7.	C.P.W.D. 8 (Item / Percentage rate tender form)	22 - 28
8.	COMMERCIAL TERMS AND CONDITIONS	29
9.	TERMINATION OF CONTRACT ON DEATH	30
10.	SPECIFICATION FOT AIR-CONDITIONING WORK	31 - 35
11.	RECOMMENDED MAKE OF MATERIALS	36
12.	SCHEDULE OF WORK	37 - 39

Certified that this N.I.T contains pages 01 to 39 pages including schedule of work and has been approved for Rs. 30,46,890.00 (Rupees Thirty Lakh Forty Six Thousand Eight Hundred Ninety) only.

Executive Engineer (E)
CCW :: AKASHVANI :: Guwahati



PRASAR BHARATI
(INDIA'S PUBLIC SERVICE BROADCASTER)
OFFICE OF THE EXECUTIVE ENGINEER (ELECT)
CIVIL CONSTRUCTION WING: AKASHVANI
Akashvani Staff Colony, Chandmari, P.O. Silpukhuri Guwahati – 781003
e-mail : eeelccwghy@yahoo.in, eeelairghy-as@gov.in

NO.: - GHY-EE(E)/4(17)/2026-27/

Dated : - 09.09.2026

NOTICE INVITING e-TENDER

The Executive Engineer (Electrical), Civil Construction Wing, Akashvani, Guwahati on behalf of President of India invites online e-tender in two envelope system online item rate bids from approved and eligible contractors of appropriate list of C.P.W.D / M.E.S / B.S.N.L / Railways / Dept.of Posts and NE states PWD and OEM or their authorized agencies / firms for the following work :

Name of work :- "S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala."

NIT No :- SE(E)/CCW/AIR/Kol/NIT/05 of 2026-27; Date : 31.07.2026 (2ND RECALL)

Estimated cost	:-	Rs. 30,46,890.00
Earnest money	:-	Rs. 60,938.00
Period of completion	:-	02 (Two) Months.
e-Tender processing fee	:-	Rs. 925.00 + 18% GST.
Last date and time of submission of bid	:-	Upto 03:00 PM on 14.09.2026.
Time & date of opening of Eligibility bid	:-	At 03:30 PM on 14.09.2026.

The bid form and other details can be obtained from the website <https://prasarbharati.eproc.in>

Executive Engineer (E)
CCW :: AKASHVANI :: Guwahati

Copy forwarded to :-

- 1) The Superintending Engineer (Elect.) / (Civil), CCW, AIR, Kolkata / Guwahati by e-mail.
- 2) The Executive Engineer (El.), CCW, AIR, Kolkata / Patna by e-mail.
- 3) The Executive Engineer (Civil), CCW, AIR, Guwahati by e-mail.
- 4) The Assistant Engineer (El.), CCW, AIR, Guwahati by e-mail.
- 5) The AAO, CCW, AIR, Guwahati
- 6) Notice Board.

Executive Engineer (E)

INFORMATION AND INSTRUCTIONS FOR CONTRACTORS FOR e-BIDING FORMING PART OF NIT AND TO BE POSTED ON WEBSITE

The Executive Engineer (Electrical), Civil Construction Wing, Akashvani, Guwahati-783001 on behalf of the President of India invites e-tender in two envelop system [Stage I : Pre-qualification of agencies as per eligibility criteria & stage II : Price bid] online item rate bids from approved and eligible contractors of appropriate list of C.P.W.D. / M.E.S. / B.S.N.L./ Deptt. Of posts / Railways and NE State P.W.D. and OEM or their authorized agencies / firms working in the relevant field for the work :

“S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala.”

NIT No.	Name of work & Location	Estimated Cost put to tender	Earnest Money	Period of Completion	Last date & time of submission of Tender (ON LINE)	Time & Date of opening of Tender
1	2	3	4	5	6	7
NIT No : SE(E)/CCW/AIR/KoI/NIT/05 of 2026-27; Date : 31.07.2026 (2ND RECALL)	S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala.	Rs. 30,46,890.00	Rs. 60,938.00	02 (Two) months	Upto 03:00 PM on 14.09.2026	At 03:30 PM on 14.09.2026

- Intending bidders Should have satisfactorily completed the works as mentioned below during the last seven years ending last day of the month previous to the one in which the tender is invited. **The work should have been done in some Central or State Govt. / Autonomous body / Undertaking.**
 - Three similar work each of value not less than 40 % of the estimated cost put to tender.
Or
 - Two similar work each of value not less than 60 % of the estimated cost put to tender.
Or
 - One similar work of value not less than 80 % of the estimated cost put to tender.
(at least one of them should be in Central Govt./ Central Autonomous body/State Govt./State Govt. Undertakings)

The value of executed works shall be brought to current costing level by enhancing the actual value of work at simple rate of 7 % per annum, calculated from the date of completion to the last date of receipt of application for tender.

Similar work shall mean work of – “S.I.T.C of air cooled package type air conditioner.”

2. The intending bidder must read the terms and conditions of CPWD-6 carefully. He should only submit his bid if he considers himself eligible and he is in possession of all the documents required.
3. Information and Instructions for bidders posted on website shall form part of bid document.
4. The bid document consisting of plans, specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents can be seen and downloaded from website <https://prasarbharati.eproc.in> free of cost.
5. But the bid can only be submitted after uploading the mandatory scanned documents such as certificate of work experience/credential, Receipt of deposition of original EMD in favour of **Executive Engineer (E), Civil Construction Wing, Akashvani, Guwahati Payable at Guwahati**, Goods & Service Tax registration and other documents as specified.

INSTRUCTIONS TO BIDDER – ONLINE MODE

DEFINITIONS:

- **C1 India Pvt. Ltd.** : Service provider to provide the e-Tendering Software.
- **Prasar Bharati e-Procurement Portal** : An e-tendering portal of Prasar Bharati introduced for the process of e-tendering which can be accessed on <https://prasarbharati.eproc.in>.

I. ACCESSING / PURCHASING OF BID DOCUMENTS:

- It is mandatory for all the bidders to have Class-III Digital Signature Certificate (With Both DSC Components, i.e. Signing & Encryption) from any of the licensed Certifying Agency under CCA, Ministry of Electronics and Information Technology, Government of India to participate in e-tendering portal of Prasar Bharati. Bidder can see the list of licensed CA's from the link www.cca.gov.in C1 India Pvt. Ltd. also facilitate Class III Digital Signature Certificate (With Both DSC Components, i.e. Signing & Encryption) to the bidders. Bidder may contact C1 India Pvt. Ltd. at mobile no. **+91- 8130606629** for DSC related queries or can email at **vikas.kumar@c1india.com**
- To participate in the e-bid, it is mandatory for the Applicants to get themselves registered with the Prasar Bharati e-Tendering Portal (<https://prasarbharati.eproc.in>) to have a user ID & Password which has to be obtained by submitting a non-refundable annual registration charges of Rs. 450/- plus 18% GST through **online** mode (net banking / debit card / credit card). Validity of Registration is 1 year.
- The amendments / clarifications to the tender, if any, will be posted on the Prasar Bharati e- Tendering Portal (<https://prasarbharati.eproc.in>).
- To participate in bidding, bidders have to pay Tender Processing Fee according to the Tender Value per Tender per Bid through online mode viz.

Estimated Value	Processing Fees per Tender per Bidder
Less than or Equal to Rs.10 Lakhs	Rs.475.00+18%GST
More than 10 Lakhs but Less than or equals to 50 Lakhs	Rs.925.00+18%GST
More than 50Lakhs	Rs.1150.00+18% GST
Annual Charges for online Bidder	

If incase, for any particular Tender, Estimated Cost is unknown to Prasar Bharati, the Processing Fee would Rs. 1150.00 + 18% GST

- The Bidder may modify or withdraw their bid after submission prior to the Bid Due Date. No Bid shall be modified or withdrawn by the Bidder after the Bid Due Date and Time.
- Both 'EMD' and 'Tender Document Fee', if any, are mentioned in individual tender document published at Prasar Bharati e-Tendering Portal (<https://prasarbharati.eproc.in>).
- For helpdesk, please contact e-Tendering Cell and Help Desk Support Monday to Friday Ph : **0124-4302033/36/37**, prasarbharatisupport@c1india.com.
- It is highly recommended that the bidders should not wait till the last date of bid submission to avoid complications like internet connectivity issue, network problems, system crash down, power failure, browser compatibility issue, system compatibility issue, improper digital signature certificate problem etc. In view of this context, neither Prasar Bharati nor C1 India Pvt. Ltd will be responsible for such eventualities.

A part of earnest money is acceptable in the form of bank guarantee also. In such case, minimum 50% of earnest money or Rs.20 lakhs, which ever is less, shall have to be deposited in shape prescribed above, and balance may be deposited in shape of Bank Guarantee of any scheduled bank having validity for 6 months or more from the last date of receipt of bids should be deposited either in the office of Executive Engineer inviting bids or division office of any Executive Engineer, CCW, AIR within the period of bid submission. The same should also be scanned and uploaded by the intending bidders. (The bank guarantee as EMD should only be issued from the place in which the office of receiving division office is situated). The EMD receiving Executive Engineer shall issue a receipt of deposition of EMD to the bidder in a prescribed format uploaded by tender inviting EE in the NIT.

This receipt of deposition of EMD shall also be uploaded to the <https://prasarbharati.eproc.in> by the intending bidder upto the specified bid submission date and time.

Copy of Enlistment Order and Certificate of work experience and other documents as specified in the notice shall be scanned and uploaded to the e-tendering website within the period of bid submission. However, certified copy of all the scanned and uploaded documents as specified in notice shall have to be submitted by the lowest bidder only with in a week physically in the office of tender opening authority.

Receipt of Deposition of Original EMD (Receipt No...../date)	
Name of work : “S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala.” 1. NIT. No. : SE(E)/CCW/AIR/KoI/NIT/05 of 2026-27(2ND RECALL) 2. Estimated cost : Rs. 30,46,890.00 3. Amount of Earnest Money Deposit : Rs. 60,938.00 4. Last date of submission of bid : Upto 03:00 PM on 14.09.2026	
1. Name of Contractor # 2. Form of Earnest Money Deposit..... # 3. Amount of Earnest Money Deposit # 4. Date of submission of EMD #	
Signature, Name and Designation of EMD Receiving officer [EE / AE/AE(C/E)(P)/ AAO] Along with Office stamp (#To be filled by EMD receiving EE//AE AE(C/E)(P) /AAO)	

5. The “Eligibility documents” shall be opened first on due date and time as mentioned above.
The time and date of opening of financial bid of contractors fulfilling the eligibility criteria shall be communicated to them at a later date.
6. Those contractors not registered on the website mentioned above, are required to get registered beforehand. If needed they can be imparted training on online bidding process as per details available on the website.
7. The intending bidder must have valid class-III digital signature to submit the bid.
8. On opening date, the contractor can login and see the bid opening process. After opening of bids he will receive the competitor bid sheets.
9. Contractor can upload documents in the form of JPG or PDF format.
10. Contractor must ensure to quote rate of each item. If any cell is left blank and no rate is quoted by the bidder, rate of such item shall be treated as **“0” (ZERO)**.

11. Tender processing fee is chargeable as per norms of **C1 India Pvt. Ltd.**
12. Online bid documents shall be opened only of those bidders, whose Earnest Money Deposit, e- Bid Processing Fee and other documents are found in order.
13. The department reserves the right to reject any prospective application with out assigning any reason and to restrict the list of qualified contractors to any number deemed suitable by it, if too many bids are received satisfying the laid down criterion.
- ~~14. The system of uploading the scanned documents for financial instrument such as Demand Draft or Pay Order or Banker's Cheque or Deposit at call receipt or Fixed Deposit receipts and Bank Guarantee of any Scheduled Bank towards EMD in favour of respective Executive Engineer and processing fee in favour of ITI Limited is dispensed with immediate effect, since the available menu for financial instruments has been modified.~~
- ~~15. The intending bidder has to fill all the details of Demand Draft / Fixed Deposit Receipt / Pay Order / Bankers Cheque (banker's name, amount, number and date) against bid processing fee.~~

List of Documents to be scanned and uploaded with in the period of bid submission :

1. Authorization letter from the OEM for all agencies except OEM to perform the work.
2. Receipt of deposition of EMD from the Executive Engineer inviting bids or from Division office of any Executive Engineer, CCW, Akashvani.
3. Valid trade license of OEM working in the relevant field for similar work. Certificate of work experience in case of OEM's authorized service provider.

Completion certificate for similar work to be submitted shall be signed by the authority not below the rank of Executive Engineer or equivalent of the department.

4. Any other Document as specified in the Notice.
5. Certificate of Registration for Goods & Service Tax and acknowledgement of upto date return if required.
6. Affidavit mentioning **N.I.T. No. / Name of work** on non-judicial stamp paper of Rs.100/- duly notarized as:

“The certified copies of all the scanned and uploaded documents specified in the tender notice shall be deposited by me/us with the Executive Engineer calling the tender in case I/We become the lowest tenderer with in a week of the opening of the financial bid otherwise the department (CCW, AKASHVANI) may reject the Tender and take the action to debar me/us from Tendering in CCW, AKASHVANI, for a period of three years and can write to the Competent Authority for cancellation of my / our enlistment (Original papers of the uploaded documents shall be shown for verification”).

17. NIT CONDITIONS:

- i. The GST has been implemented by the Government of India with effect from 1st July 2017. The rates quoted by the tenderer shall be firm and inclusive of all taxes including GST and nothing extra shall be payable.
- ii. Tenderer shall examine the various provisions of CGST Act, 2017, IGST Act, 2017/ UGST Act 2017, SGST Act 2017 of the respective state and upto date amendments issued from time to time and other applicable taxes before bidding/tendering. The tenderer shall also confirm to the rules made under these Acts.
- iii. The tenderer shall ensure that benefit of input tax credit (ITC) likely to be availed by them is duly considered by them while quoting rates.
- iv. The contractor shall submit the invoice of the work executed as per Rule 46 of CGST rules. The taxes will be calculated as per Rule 35 of CGST Rules 2017.
- v. As contractor's rates are inclusive of all taxes, no reimbursement of any tax shall be made to the contractor. The **clauses 37** of GCC of NIT / contract stands modified accordingly.
- vi. TDS on income tax, labour cess and other statutory deductions shall be made at source as per prevalent laws. TDS on GST as applicable will also be deducted as per relevant GST Act / rules / notification.

Executive Engineer(Elect)
CCW : AKASHVANI : GUWAHATI

1. Item rate / ~~percentage rate~~ tender is invited on behalf of the President of India from approved and eligible contractors of appropriate list of C.P.W.D. / M.E.S./ B.S.N.L. / Railways / Dept. of Posts / NE State P.W.D. and OEM or their authorized agencies / firms working in the relevant field for the work :

Name of Work : “S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala.”

- 1.1 The work is estimated to cost for **Rs. 30,46,890.00**. This estimate, however, is given merely as a rough guide.

1.2.1 Conditions for CPWD / Non-CPWD contractors.

Bidders will be eligible provided they produce definite proof from the appropriate authority, which shall be to the satisfaction of the competent authority of magnitude specified below :

- (i) Should have satisfactorily completed the works as mentioned below during the last seven years ending last day of the month preceding the month of opening of the tender. **The work should have been done in some Central or State Govt. / Autonomous body / Undertaking.**

- (ii) Three similar work each of value not less than 40% of the estimated cost put to tender.

Or

- (iii) Two similar work each of value not less than 60 % of the estimated cost put to tender.

Or

- (iv) One similar work of value not less than 80% of the estimated cost put to tender.

The value of executed works shall be brought to current costing level by enhancing the actual value of work at simple rate of 7% per annum, calculated from the date of completion to the last date of receipt of application for tender.

“Similar work shall mean the work of – **S.I.T.C of air cooled package type air conditioner.**

1.2.2 Criteria of eligibility for CPWD as well as non-CPWD contractors.

The value of executed works shall be brought to current costing level by enhancing the actual value of work at simple rate of 7% per annum, calculated from the date of completion to the previous day of last date of submission of tender. **This is applicable for 1.2.1 as well 1.2.2.**

2. Agreement shall be drawn with the successful tenderer on prescribed Form No. CPWD- 7/8 (or other Standard Form as mentioned) which is available as a Govt. of India Publication. Tenderer shall quote his rates as per various terms and conditions of the said form which will form part of the agreement.
3. The time allowed for carrying out the work will be **02 (Two) months** from the date of start as defined in schedule ‘F’ or from the first date of handing over of the site, whichever is later, in accordance with the phasing, if any, indicated in the tender documents.

4. The site for the work is available.
5. The tender document consisting of specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents except standard General Conditions of Contract Form can be seen from website <https://prasarbharati.eproc.in>. free of cost.
6. After submission of the bid the contractor can re-submit revised bid any number of times but before last time and date of submission of tender as notified.
7. While submitting the revised bid, contractor can revise the rate of one or more item(s) any number of times (he need not re-enter rate of all the items) but before last time and date of submission of tender as notified.
8. When tenders are invited in two stage system and if it is desired to submit revised financial bid then it shall be mandatory to submit revised financial bid. If not submitted then the tender submitted earlier shall become invalid.
9. Earnest Money **Rs. 60,938.00** in the form of Treasury Challan or Demand Draft or Pay order or Banker's Cheque or Deposit at Call Receipt or fixed deposit receipt (drawn in favour of **Executive Engineer (E), Civil Construction Wing, Akashvani, Guwahati**, Payable at Guwahati shall be scanned and uploaded <https://prasarbharati.eproc.in>. with in the period of bid submission.

A part of earnest money is acceptable in the form of bank guarantee also. In such case, minimum 50% of earnest money or Rs. 20 lacs, whichever is less, shall have to be deposited in shape prescribed above, and balance may be deposited in shape of Bank Guarantee of any scheduled bank having validity for 6 months or more from the last date of receipt of bids should be deposited either in the office of Executive Engineer inviting bids or division office of any Executive Engineer, CCW,AIR with in the period of bid submission. The same should also be scanned and uploaded by the intending bidders. (The bank guarantee as EMD should only be issued from the place in which the office of receiving division office is situated). The EMD receiving Executive Engineer shall issue a receipt of deposition of EMD to the bidder in a prescribed format uploaded by tender inviting EE in the NIT.

This receipt of deposition of bank guarantee shall also be uploaded to the e-tendering shall also be uploaded to the e-tendering website by the intending bidder up to the specified bid submission date and time.

Copy of Enlistment Order and Certificate of work experience and other documents as specified in the notice shall be scanned and uploaded <https://prasarbharati.eproc.in>. within the period of bid submission. However, certified copy of all the scanned and uploaded documents as specified in notice shall have to be submitted by the lowest bidder only within a week physically in the office of tender opening authority.

Receipt of Deposition of Original EMD (Receipt No...../date.....)	
Name of work : "S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala." 1. NIT. No. SE(E)/CCW/AIR/KoI/NIT/05 of 2026-27(2ND RECALL) 2. Estimated cost : Rs. 30,46,890.00 3. Amount of Earnest Money Deposit : Rs. 60,938.00 4. Last date of submission of bid : Upto 03:00 PM on 14.09.2026	
1. Name of Contractor# 2. Form of Earnest Money Deposit.....# 3. Amount of Earnest Money Deposit# 4. Date of submission of EMD #	
Signature, Name and Designation of EMD Receiving officer [EE /AE(C/E)(P)/AE/ AAO] Along with Office stamp (#To be filled by EMD receiving EE/AE(C/E)(P)/AE/AAO)	

To participate in bidding, bidders have to pay Tender Processing Fee according to the Tender Value per Tender per Bid through online mode viz.

Estimated Value	Processing Fees per Tender per Bidder
Less than or Equal to Rs.10Lakhs	Rs.475.00+18%GST
More than 10 Lakhs but Less than or equals to 50 Lakhs	Rs.925.00+18%GST
More than 50 Lakhs	Rs.1150.00+18% GST
Annual Charges for online Bidder	

The following affidavit mentioning **N.I.T. No. / Name of work** shall also be uploaded by the intending bidders on non-judicial stamp paper of Rs.100/-duly notarized.

"The certified copy of all the scanned and uploaded documents specified in the tender notice shall be deposited by me / us with the Executive Engineer calling the tender in case I / We become the lowest tenderer with a week of the opening of the financial bid otherwise the department (CCW, AKASHVANI) may reject the Tender and take the action to Debar me/us from Tendering in (CCW, AKASHVANI) ,for a period of three years and can write to the Competent Authority for cancellation of my/our enlistment (Original papers of the uploaded documents shall be shown for verification.

10. The "Eligibility documents" shall be opened first on due date and time as mentioned above. The time and date of opening of financial bid of contractors fulfilling the eligibility criteria shall be communicated to them at a later date.

The eligibility document submitted shall be opened at **At 03:30 PM on 14.09.2026.**

11. The bid submitted shall become invalid if :

- i. The bidder is found ineligible.
- ii. The bidder does not upload all the documents (including Goods and service tax registration) as stipulated in the bid document including Pro-forma for earnest money deposit declaration.
- iii. If any discrepancy is noticed between the documents as uploaded at the time of submission of bid and hard copies as submitted **physically by the lowest bidder** in the office of tender opening authority.
- iv. The contractor, whose tender is accepted, will be required to furnish **performance guarantee of 5% (Five Percent)** of the bid amount within the period specified in Schedule 'F'. This guarantee may be in the form of cash (in case guarantee amount is less than Rs. 10,000/-) or Deposit at Call receipt of any scheduled bank / Banker's cheque of any scheduled bank/Demand Draft of any scheduled bank/Pay order of any Scheduled Bank of any scheduled bank (in case guarantee amount is less than Rs. 1,00,000/-) or Government Securities or Fixed Deposit Receipts or Guarantee Bonds of any Scheduled Bank or the State Bank of India in accordance with the prescribed form. In case the contractor fails to deposit the said performance guarantee within the period as indicated in Schedule 'F' including the extended period if any, such agency shall be suspended for one year and shall not be eligible to bid for Civil Construction Wing, All India Radio tenders from date of issue of suspension order.
- v. The contractor whose bid accepted will also be required to furnish either copy of applicable licenses / registrations or proof of applying for obtaining labour licenses, registration with EPFO, ESIC and BOCW Welfare Board including Provident Fund Code No. if applicable and also ensure the compliance of aforesaid provisions by the sub contractors, if any engaged by the contractor for the said work.

12. Intending Tenderers are advised to inspect and examine the site and its surroundings and satisfy themselves before submitting their tenders as to the nature of the ground and sub-soil (so far as is practicable), the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their tender. **A tenderer shall be deemed to have full knowledge of the site whether he inspects it or not and no extra charge consequent on any misunderstanding or otherwise shall be allowed.** The tenderer shall be responsible for arranging and maintaining at his own cost all materials, tools & plants, water, electricity access, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a tender by a tenderer implies that he has read this notice and all other contract documents and has made himself aware of the scope and specifications of the work to be done and of conditions and rates at which stores, tools and plant, etc. will be issued to him by the Government and local conditions and other factors having a bearing on the execution of the work.

13. The competent authority on behalf of the President of India does not bind itself to accept the lowest or any other tender and reserves to it self the authority to reject any or all the tenders received without the assignment of any reason. All tenders in which any of the prescribed condition is not fulfilled or any condition including that of conditional rebate is put forth by the tenderer shall be summarily rejected.
14. Canvassing whether directly or indirectly, in connection with tenderers is strictly prohibited and the tenders submitted by the contractors who resort to canvassing will be liable to rejection.
15. The competent authority on behalf of President of India reserves to himself the right of accepting the whole or any part of the tender and the tenderer shall be bound to perform the same at the rate quoted.
16. The contractor shall not be permitted to tender for works in the C.C.W, AKASHVANI, Circle (Division in case of contractors of Horticulture / Nursery category) responsible for award and execution of contracts, in which his near relative is posted a Divisional Accountant or as an officer in any capacity between the grades of Superintending Engineer and Junior Engineer (both inclusive). He shall also intimate the names of persons who are working with him in any capacity or are subsequently employed by him and who are near relatives to any gazette officer in the Civil Construction Wing, All India Radio or in the Ministry of Information & B' casting. Any breach of this condition by the contractor would render him liable to be removed from the approved list of contractors of this Department.
17. No Engineer of Gazetted rank or other Gazetted Officer employed in Engineering or Administrative duties in an Engineering Department of the Government of India is allowed to work as a contractor for a period of one year after his retirement from Government service, without the previous permission of the Government of India in writing. This contract is liable to be cancelled if either the contractor or any of his employees is found any time to be such a person who had not obtained the permission of the Government of India as aforesaid before submission of the tender or engagement in the contractor's service.
18. The bid for the works shall remain open for acceptance for a period of ~~Ten/Fifteen/thirty/forty five/Sixty/Seventy five~~ (10/15/30/45/**60**/75) days from the date of opening of bids in case of single bid system/~~sixty (60) days for the date of opening of technical bid in case bids are invited on 2 or 3 bid/envelop system (strike out as the case may be).~~ If any bidder withdraws his bid before the said period or issue of letter of acceptance, which ever is earlier, or makes any modifications in the terms and conditions of the bid which are not acceptable to the department, then the Government shall without prejudice to any other right or remedy, beat liberty to forfeit 50% of the said earnest money as aforesaid. Further the bidders shall not be allowed to participate in any work in Civil Construction Wing, All India radio tenders for one year from date of issue of suspension order.

19. This notice inviting Tender shall form a part of the contract document. The successful tenderer / contractor, on acceptance of his tender by the Accepting Authority shall within 15 days from the stipulated date of start of the work, sign the contract consisting of :-
- a) The Notice Inviting Tender, all the documents including additional conditions. specifications and drawings, if any, forming part of the tender as uploaded at the time of invitation of tender and the rates quoted online at the time of submission of bid and acceptance thereof together with any correspondence leading thereto.
 - b) Standard C.P.W.D. Form 7/8 ~~or other Standard C.P.W.D. Form as mentioned.~~
20. In case any discrepancy is noticed between the documents as uploaded at the time of submission of the bid online and hard copies as submitted physically in the office of Executive Engineer, then the bid submitted shall be come invalid and the Government shall, without prejudice to any other right or remedy, be at liberty to suspend the defaulter agency for one year and shall not be eligible to bid for Civil Construction Wing, All India radio tenders from date of issue of suspension order.
21. Tax applicable in respect of this contract shall be payable by the Contractor and Government will not entertain any claim whatsoever in respect of the same. However, "Deduction, if any, can be effected from bill as per GST Act 2017"

Executive Engineer (Elect.)
CCW :: AKASHVANI :: GUWAHATI.

INTEGRITY PACT

INTEGRITY PACT

This Integrity Pact is made at.....on this.....Day of2025

BETWEEN

The President of India represented through **Executive Engineer (Elect), Civil Construction Wing, Akashvani, Guwahati** (Hereinafter referred as the '**Principal / Owner**', which expression shall unless repugnant to the meaning or context hereof include its successors and permitted assigns)

AND

.....
(Name and Address of the Individual / firm / Company) through (Hereinafter referred to as the "**Bidder / Contractor**" and which expression shall unless repugnant to the meaning or context hereof include its successors and permitted assigns)

PREAMBLE

WHEREAS the Principal/Owner has floated the Tender (**NIT No. SE(E)/CCW/AIR/Kol/NIT/05 of 2026-27, Date : 31.07.2026 (2ND RECALL)**) (here in after referred to as "**Tender/Bid**") and intends to award, under laid down organizational procedure, contract for the Work :

"S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala."

Here in after referred to as the "**Contract**".

AND WHEREAS the Principal/Owner values full compliance with all relevant laws of the land, rules, regulations, economic use of resources and of fairness/transparency in its relation with its Bidder(s) and Contractor(s).

AND WHEREAS to meet the purpose aforesaid both the parties have agreed to enter into this Integrity Agreement (hereinafter referred to as "**Integrity Pact**" or "**Pact**"), the terms and conditions of which shall also be read as integral part and parcel of the Tender/Bid documents and Contract between the parties.

In order to achieve these goals, the principal will appoint Independent External Monitors (IEMs), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned hereunder.

NOW, THEREFORE, in consideration of mutual covenants contained in this Pact, the parties hereby agree as follows and this Pact witnesses as under

ARTICLES

Article1 : Commitment of the Principal/Owner

- 1) The Principal/Owner commits itself to take all measures necessary to prevent corruption and to observe the following principles:
 - (a) No employee of the Principal/Owner, personally or through any of his/her family members, will in connection with the Tender, or the execution of the Contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.
 - (b) The Principal/Owner will, during the Tender process, treat all Bidder(s) with equity and reason.
The Principal/Owner will, in particular, before and during the Tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential/additional information through which the Bidder(s) could obtain an advantage in relation to the Tender process or the Contract execution.
 - (c) The Principal/Owner shall Endeavour to exclude from the Tender process any person, whose conduct in the past has been of biased nature.

INTEGRITY PACT

- 2) If the Principal/Owner obtains information on the conduct of any of its employees which is a criminal offence under the Indian Penal code (IPC)/Prevention of Corruption Act, 1988 (PC Act) or is in violation of the principles herein mentioned or if there be a substantive suspicion in this regard, the Principal/Owner will inform the Chief Vigilance Officer and in addition can also initiate disciplinary actions as per its internal laid down policies and procedures.

Article 2 : Commitment of the Bidder(s)/Contractor(s)

- 1) It is required that each Bidder/Contractor (including their respective officers, employees and agents) adhere to the highest ethical standards, and report to the Government / Department all suspected acts of **fraud or corruption or Coercion or Collusion** of which it has knowledge or becomes aware, during the tendering process and throughout the negotiation or award of a contract.
- 2) The Bidder(s)/Contractor(s) commits himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the Tender process and during the Contract execution:
 - a) The Bidder(s)/Contractor(s) will not, directly or through any other person or firm, offer, promise or give to any of the Principal/Owner's employees involved in the Tender process or execution of the Contract or to any third person any material or other benefit which he/she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the Tender process or during the execution of the Contract.
 - b) The Bidder(s)/Contractor(s) will not enter with other Bidder(s) into any undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to cartelize in the bidding process.
 - c) The Bidder(s)/Contractor(s) will not commit any offence under the relevant IPC/PC Act. Further the Bidder(s)/Contractor(s) will not use improperly, (for the purpose of competition or personal gain), or pass onto others, any information or documents provided by the Principal/Owner as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
 - d) The Bidder(s)/Contractor(s) of foreign origin shall disclose the names and addresses of agents/representatives in India, if any. Similarly, Bidder(s)/Contractor(s) of Indian Nationality shall disclose names and addresses of foreign agents/representatives, if any. Either the Indian agent on behalf of the foreign principal or the foreign principal directly could bid in a tender but not both. Further, in cases where an agent participate in a tender on behalf of one manufacturer, he shall not be allowed to quote on behalf of another manufacturer along with the first manufacturer in a subsequent/parallel tender for the same item.
 - e) The Bidder(s) / Contractor(s) will, when presenting his bid, disclose (with each tender as per proforma enclosed) any and all payments he has made, is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the Contract.
 - f) The Bidder(s) / Contractor(s) who have signed the Integrity pact shall not approach the courts while representing the matter to IEMs and shall wait for their decision in the matter.
- 3) The Bidder(s) / Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.
- 4) The Bidder(s) / Contractor(s) will not, directly or through any other person or firm indulge in fraudulent practice **means a willful misrepresentation or omission of facts or submission of fake / forged documents in order to induce public official to act in reliance thereof, with the purpose of obtaining unjust advantage by or causing damage to justified interest of others and/or to influence the procurement process to the detriment of the Government interests.**
- 5) The Bidder(s) / Contractor(s) will not, directly or through any other person or firm use Coercive Practices (which shall include the act of obtaining something, compelling an action or influencing a decision through intimidation, threat or the use of force directly or indirectly, where potential or actual injury may be fall upon a person, his/her reputation or property to influence their participation in the tendering process).

INTEGRITY PACT

Article 3 : Consequences of Breach

Without prejudice to any rights that may be available to the Principal/Owner under law or the Contract or its established policies and laid down procedures, the Principal/Owner shall have the following rights in case of breach of this Integrity Pact by the Bidder(s)/Contractor(s) and the Bidder/Contractor accepts and undertakes to respect and uphold the Principal/Owner's absolute right:

- 1) If the Bidder(s)/Contractor(s), either before award or during execution of Contract has committed a transgression through a violation of Article 2 above or in any other form, such as to put his reliability or credibility in question, the Principal/Owner after giving 14 days' notice to the contractor shall have powers to disqualify the Bidder(s)/Contractor(s) from the Tender process or terminate/determine the Contract, if already executed or exclude the Bidder/Contractor from future contract award processes. The imposition and duration of the exclusion will be determined by the severity of transgression and determined by the Principal/Owner. Such exclusion may be forever or for a limited period as decided by the Principal/Owner.
- 2) **Forfeiture of EMD/Performance Guarantee/Security Deposit** : If the Principal/Owner has disqualified the Bidder(s) from the Tender process prior to the award of the Contract or terminated/determined the Contract or has accrued the right to terminate/determine the Contract according to Article 3(1), the Principal/Owner apart from exercising any legal rights that may have accrued to the Principal/Owner, may in its considered opinion forfeit the entire amount of Earnest Money Deposit, Performance Guarantee and Security Deposit of the Bidder/Contractor.
- 3) **Criminal Liability**: If the Principal/Owner obtains knowledge of conduct of a Bidder or Contractor, or of an employee or a representative or an associate of a Bidder or Contractor which constitutes corruption within the meaning of Indian Penal code (IPC)/Prevention of Corruption Act, or if the Principal/Owner has substantive suspicion in this regard, the Principal/Owner will inform the same to law enforcing agencies for further investigation.

Article 4 : Previous Transgression

- 1) The Bidder declares that no previous transgressions occurred in the last 5 years with any other Company in any country confirming to the anticorruption approach or with Central Government or State Government or any other Central/State Public Sector Enterprises in India that could justify his exclusion from the Tender process.
- 2) If the Bidder makes incorrect statement on this subject, he can be disqualified from the Tender process or action can be taken for banning of business dealings/ holiday listing of the Bidder/Contractor as deemed fit by the Principal/Owner.
- 3) If the Bidder/Contractor can prove that he has resorted / recouped the damage caused by him and has installed a suitable corruption prevention system, the Principal/Owner may, at its own discretion, revoke the exclusion prematurely.

Article 5 : Equal Treatment of all Bidders/Contractors/Subcontractors

- 1) The Bidder(s)/Contractor(s) undertake(s) to demand from all subcontractors a commitment in conformity with this Integrity Pact. The Bidder/Contractor shall be responsible for any violation(s) of the principles laid down in this agreement/Pact by any of its Subcontractors/ sub vendors.
- 2) The Principal/Owner will enter into Pacts on identical terms as this one with all Bidders and Contractors.
- 3) The Principal/Owner will disqualify Bidders, who do not submit, the duly signed Pact between the Principal/Owner and the bidder, along with the Tender or violate its provisions at any stage of the Tender process, from the Tender process.

Article 6: Duration of the Pact

This Pact begins when both the parties have legally signed it. It expires for the Contractor/Vendor 12 months after the completion of work under the contractor till the continuation of defect liability period, whichever is more and for all other bidders, till the Contract has been awarded.

If any claim is made/lodged during the time, the same shall be binding and continue to be valid despite the lapse of this Pacts as specified above, unless it is discharged/ determined by the Competent Authority, Prasar Bharati.

INTEGRITY PACT

Article 7 : Other Provisions

- 1) This Pact is subject to Indian Law, place of performance and jurisdiction is the **Headquarters of the Division** of the Principal/Owner, who has floated the Tender.
- 2) Changes and supplements need to be made in writing.
- 3) If the Contractor is a partnership or a consortium, this Pact must be signed by all the partners or by one or more partner holding power of attorney signed by all partners and consortium members. In case of a Company, the Pact must be signed by a representative duly authorized by board resolution.
- 4) Should one or several provisions of this Pact turn out to be invalid; the remainder of this Pact remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- 5) Issues like Warranty/Guarantee etc. shall be outside the purview of IEMs.
- 6) It is agreed term and condition that any dispute or difference arising between the parties with regard to the terms of this Integrity Agreement/Pact, any action taken by the Owner/Principal in accordance with this **Integrity Agreement/Pact or interpretation thereof shall not be subject to arbitration.**
- 7) In view of the nature of integrity pact, the Integrity pact is irrevocable and shall remain valid even if the main tender/contract is terminated till the currency of the Integrity pact.
- 8) If any complaint regarding violation of IP is received directly by the Principal in respect of the contract, the same shall be referred to the IEM for comments/recommendations.

Article 8: Independent External Monitor (IEM)

- (1) The principal appoints competent and credible independent External Monitor for this pact after approval by Central Vigilance Commission (Names and address of IEMs are as mentioned in Schedule-F). The task of the Monitor is to review independently and objectively, whether and to what extent the parties comply with the obligations under this agreement.
- (2) The Monitor is not subject to instructions by the representatives of the parties and performs his/her functions neutrally and independently. The Monitor would have access to all contract documents, whenever required. It will be obligatory for him/her to treat the information and documents of the Bidders/Contractors as confidential.
- (3) The Bidder(s) / Contractor(s) accepts that the IEM has the right to access without restriction to all project documentation of the Principal including that provided by the Contractor. The Contractor will also grant the IEM, upon his/her request and demonstration of a valid interest, unrestricted and unconditional access to their project documentation. The same is applicable to sub-contractors.
- (4) The IEM is under contractual obligation to treat the information and documents of the Bidder(s) / Contractor(s) / Sub-Contractor(s) with confidentiality. The IEM has also signed 'Non-Disclosure of Confidential Information' and 'Absence of Conflict of Interest'. In case if any conflict of interest arising at a later date, the IEM shall inform the Engineer-in-Charge and recues himself / herself from that case.
- (5) As soon as the IEM notices, or believes to notice, a violation of the agreement, he/she will so inform the Management of the Principal and request the Management to discontinue or take corrective action, or to take other relevant action. The IEM can in this regard submit non-binding recommendations. Beyond this, the IEM has no right to demand from the parties that thy act in a specific manner, refrain from action or tolerate action.
- (6) The IEM will submit a written report to the SDG/ADG concerned within 8 to 10 weeks from the date of reference or intimation to him by the Principal and should the occasion arise, submit proposals for correcting problematic situations.
- (7) If the IEM has reported to the ADG/SDG concerned, a substantiated suspicion of an offence under relevant IPC/PC Act, and the ADG/SDG concerned has, within a reasonable time, not taken visible action to proceed against such offence or reported it to the Chief Vigilance Officer, the IEM may also transmit this information directly to the Central Vigilance Commissioner.

INTEGRITY PACT

- (8) The Principal will provide to the IEM sufficient information about all meetings among the parties related to the project provided such meetings could have impact on contractual relations between the Principal and the contractor. The parties will offer to the IEM the option to participate in such meetings.
- (9) The work IEM or monitor would include both singular and plural.

Article 9: LEGAL AND PRIOR RIGHTS

All rights and remedies of the parties hereto shall be in addition to all the other legal rights and remedies belonging to such parties under the Contract and/or law and the same shall be deemed to be cumulative and not alternative to such legal rights and remedies aforesaid. For the sake of brevity, both the Parties agree that this Integrity Pact will have precedence over the Tender/Contact documents with regard any of the provisions covered under this Integrity Pact.

IN WITNESS WHEREOF the parties have signed and executed this Integrity Pact at the place and date first above mentioned in the presence of following witnesses:

.....
(For and on behalf of Principal/Owner)

.....
(For and on behalf of Bidder/Contractor)

WITNESSES:

1.....
(Signature, name and address)

2.....
(Signature, name and address)

Place:

Dated:

Note: To be signed by the bidder and the Engineer-in-Charge

N.B: As advise by the CVC & as directed by Prasar Bharati for implementation of Integrity Pact, the following are the particulars of the independent External monitors (IEM):

Sl. No	Name of IEM	e-mail id
1	Smt. Meenakshi Mishra, IA & AS (Retd.)	pcmishra@hotmail.com
2	Shri Alope Prasad, IPS (retd.)	alokewa@gmail.com

To,

.....,
.....,
.....

Name of Work : -“ S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala.”

Dear Sir,

It is hereby declared that CCW, AKASHVANI is committed to follow the principle of transparency, equity and competitiveness in public procurement.

The subject Notice Inviting Tender (NIT) is an invitation to offer made on the condition that the Bidder will sign the integrity Agreement, which is an integral part of tender/bid documents, failing which the tenderer / bidder will stand disqualified from the tendering process and the bid of the bidder would be summarily rejected.

This declaration shall form part and parcel of the Integrity Agreement and signing of the same shall be deemed as acceptance and signing of the Integrity Agreement on behalf of the CCW, AKASHVANI.

Yours faithfully

Executive Engineer (E),
CCW : Akashvani : Guwahati

.....
To,

The Executive Engineer (E)
CCW : Akashvani : Guwahati

Sub : Submission of Tender for the work of “S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala.”

Dear Sir,

I/We acknowledge that CCW : AKASHVANI is committed to follow the principles thereof as enumerated in the Integrity Agreement enclosed with the tender/bid document.

I/We agree that the Notice Inviting Tender (NIT) is an invitation to offer made on the condition that I/We will sign the enclosed integrity Agreement, which is an integral part of tender documents, failing which I/We will stand disqualified from the tendering process. I/We acknowledge that THE MAKING OF THE BID SHALL BE REGARDED AS AN UNCONDITIONAL AND ABSOLUTE ACCEPTANCE of this condition of the NIT.

I/We confirm acceptance and compliance with the Integrity Agreement in letter and spirit and further agree that execution of the said Integrity Agreement shall be separate and distinct from the main contract, which will come into existence when tender/bid is finally accepted by CCW : AKASHVANI. I/We acknowledge and accept the duration of the Integrity Agreement, which shall be in the line with Article 1 of the enclosed Integrity Agreement.

I/We acknowledge that in the event of my/our failure to sign and accept the Integrity Agreement, while submitting the tender/bid, CCW : AKASHVANI shall have unqualified, absolute and unfettered right to disqualify the tenderer/bidder and reject the tender/bid in accordance with terms and conditions of the tender/bid.

Yours faithfully
(Duly authorized signatory of the Bidder)

PRASAR BHARATI
CIVIL CONSTRUCTION WING : AKASHVANI

STATE	:	TRIPURA.	CIRCLE	:	KOLKATA
BRANCH	:	E & M	DIVISION	:	GUWAHATI
ZONE	:	NEZ	SUB-DIVISION	:	GUWAHATI

This draft N.I.T. has been approved for Rs. 30,46,890.00 (Rupees Thirty Lakh Forty Six Thousand Eight Hundred Ninety) only.

Item Rate Tender & Contract for Works

Tender for the work of :- **"S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala."**

- (i) **To be submitted 15:00 hours on 14.09.2026 to the Executive Engineer (E), Civil Construction Wing, Akashvani, AIR Staff Quarter Campus, Chandmari, Guwahati-781003.**
- (ii) **To be opened in presence of tenderers who may be present at 15:30 hours on 14.09.2026 in the office of the Executive Engineer (E), Civil Construction Wing, Akashvani, AIR Staff Quarter Campus, Chandmari, Guwahati-781003.**

Issued to :
(Contractor)

Signature of officer issuing the documents
 Designation

**Executive Engineer (E),
 Civil Construction Wing,
 Akashvani, Guwahati.**

Date of Issue

T E N D E R

I/We have read and examined the notice inviting tender, schedule, A, B, C, D, E & F, Specifications applicable, Drawings & Designs, General Rules and Directions, Conditions of Contract, clauses of contract, Special conditions, Schedule of Rate & other documents and Rules referred to in the conditions of contract and all other contents in the tender document for the work.

I/We hereby tender for the execution of the work specified for the President of India as per time schedule of mile stone(s) and within the time specified in Schedule 'F', viz., schedule of quantities and in accordance in all respects with the specifications, designs, drawings and instructions in writing referred to in Rule-1 of General Rules and Directions and in clause 11 of the Conditions of contract and with such materials as are provided for, by, and in respects in accordance with, such conditions so far as applicable.

We agree to keep the tender open for **60 (Sixty)** days from the due date of its opening/~~ninety~~ days from the date of opening of financial bid in case tenders are invited on 2/3 envelope system (Strike out as the case may be) and not to make any modifications in its terms and conditions.

A sum of **Rs. 60,938.00** is hereby forwarded in cash/receipt treasure Challan /deposit at call receipt of a scheduled bank/ fixed deposit receipt of scheduled bank/demand draft of a scheduled bank/~~bank guarantee~~ issued by a scheduled bank as earnest money. If I/we, fail to furnish the prescribed performance-

guarantee within prescribed period, I/we agree that the said President of India or his successors in office shall without prejudice to any other right or remedy, be at liberty to forfeit the said earnest money absolutely. Further, if I/we fail to commence work as specified, I/we agree that President of India or his successors in office shall without prejudice to any other right or remedy available in law, be at liberty to forfeit the said earnest money and the performance guarantee absolutely, otherwise the said earnest money shall be retained by him towards security deposit to execute all the works referred to in the tender documents upon the terms and conditions contained or referred to therein and to carry out such deviations as may be ordered, up to maximum of the percentage mentioned in Schedule 'F' and those in excess of that limit at the rates to be determined in accordance with the provision contained in Clause 12.2 and 12.3 of tender form. Further, I/we agree that in case of forfeiture of earnest money or both Earnest Money & Performance Guarantee as aforesaid, I/We shall be debarred for participation in the re-tendering process of the work.

I/We undertake and confirm that eligible similar works (s) has/have not been got executed through another contractor on back to back basis. Further that, if such a violation comes to the notice of Department, then I/we shall be debarred for tendering in CCW, AKASHVANI in future forever. Also, if such a violation comes to the notice of Department before date of start of work, the Engineer-in-Charge shall be free to forfeit the entire amount of Earnest Money Deposit/Performance Guarantee"

I/We hereby declare that /We shall treat the tender documents, drawings and other records connected with the work as secret/confidential documents and shall not communicate information/derived there from to any person other than a person to whom I/We am/are authorized to communicate the same or use the information in any manner prejudicial to the safety of the state.

Dated

Signature of Contractor

Postal Address

Witness : Address:

Occupation:

ACCEPTANCE

The above tender (as modified by you as provided in the letters mentioned hereunder) is accepted by me for and on behalf of the President of India for a sum of Rs. (Rupees)

The letters referred to below shall form part of this contract Agreement:-

i)

.....

ii)

iii)

For & on behalf of the President of India.

Signature.....

Designation

Dated.....

SCHEDULES

SCHEDULE 'A'

Schedule of quantities (Enclosed) (as per PWD-3) at page No. 37 - 39

SCHEDULE 'B'

Schedule of materials to be issued to the contractor.

Sl.No.	Description of item	Quantity	Rates in figures & words at which the material will be charged to the contractor	Place of Issue
1	2	3	4	5
-----NIL-----				

SCHEDULE 'C'

Tools and plants to be hired to the contractor.

Sl. No.	Description	Hire charges per day	Place of Issue
1	2	3	4
-----NIL-----			

SCHEDULE 'D'

Extra schedule for specific requirements/documents for the work, if any. NIL

SCHEDULE 'E'

Reference to General Conditions of contract.

Name of work :- "S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala."

Estimated cost of work: **Rs. 30,46,890.00**

Earnest money: **Rs. 60,938.00**

Performance Guarantee: 5% of Tendered Value.

Security Deposit: 2.5% of Tendered Value.

or

2.5% of tendered value plus 50% of PG for contracts involving maintenance of the building and services/other work after construction of same building and services/other work.

SCHEDULE 'F'

General Rules & Directions:

Officer inviting tender

**Executive Engineer(E),
CCW : AKASHVANI : Guwahati**

Maximum percentage for quantity of items of work to be executed beyond which rates are to be determined in accordance with Clauses 12.2 & 12.3
Definitions :

see under Clause 12

2(v)	Engineer-in-Charge	Executive Engineer(E), C.C.W : AKASHVANI : Guwahati
2(viii)	Accepting Authority	Executive Engineer(E), C.C.W : AKASHVANI : Guwahati
2(x)	Percentage on cost of materials and labour to cover all overheads and profits	15%
2(xi)	Standard schedule of Rates	DSR-2025 & Market Rates
2(xii)	Department	Prasar Bharati, C.C.W, A.I.R.
9(ii)	Standard CPWD contract form	CPWD 8 Form modified & corrected upto date.
Clause 1		
i)	Time allowed for Submission of performance guarantee from the date of issue of letter of acceptance	07 Days.
ii)	Maximum allowable extension with Late fee @ 1 % per day of performance Guarantee amount beyond the period as provided in (i) above.	07 Days.
Clause 2		
	Authority for fixing compensation under clause 2.	Superintending Engineer (E), C.C.W : AIR : Kolkata
Clause 2A		
	Whether clause 2A shall be applicable	No
Clause 5		
	Number of days from the date of issue of letter of acceptance for reckoning date of start	14 Days.....

Mile stone (s) as per table given below:-

TABLE OF MILE STONE(S)

S.LNO.	DESCRIPTION OF MILESTONE (PHYSICAL)	TIME ALLOWED IN DAYS (FROM THE DATE OF START)	AMOUNT TO BE WITH-HELD IN CASE OF NON-ACHIEVEMENT OF MILESTONE.
	----- NA -----		

Time allowed for execution of work : **02 (TWO) Months.**

Authority to Decide:

Extension of time

**Executive Engineer (E),
C.C.W : AKASHVANI : Guwahati**

CPWD - 8

NA

Rescheduling of mile stones

Clause 6, 6A

Clause applicable – (6 or 6A)

Clause 6

Clause 7

Gross work to be done together with net payment/adjustment of advances for material collected, if any, since the last such payment for being eligible to interim payment.

Clause 10A

List of testing equipment to be Provided by the contractor at site lab

1. Refrigerant Charging Equipment
2. Manifold gauge
5. Pressure gauge
6. Insulation testing Megger.

3. Leak tester for refrigerant
4. Temp. meter (digital)
7. Line tester
8. Multimeter

Clause 10B

N.A.

Clause 10C

Component of labour expressed as percent of value of work

20 %

Clause 10CA

Whether clause 10CA shall be Applicable.

No

Materials covered under this clause

Nearest material for which All India Wholesale Price Index is to be followed
-----Nil-----

Base price of all material covered under Clause 10 CA

-----Nil-----

Clause 10CC

Clause 10CC to be applicable in contracts with stipulated period of completion exceeding the period shown in next column :

-----Nil -----

Not Applicable.

Note: No escalation under clause 10CC will be paid to the contractor even if the extension of time is allowed without leavy of compensation by competent authority beyond stipulated period. Therefore clause 10CC shall be deemed to have been deleted from this contract

Clause 11

CPWD General specifications for Electrical works Part – I & II, 2023, CPWD Gen. Spec. for HVAC, 2017 as amended upto date and additional condition, additional specifications as attached in the tender, relevant I.E. Rules, ISS & BIS as applicable.

Clause 12

12.2 & 12.3

Deviation limit beyond which clauses 12.2 & 12.3 shall apply

30% on individual items.

12.5 for electrical work.
Deviation limit beyond which clauses 12.2 and 12.3 shall apply or foundation work.

100%

Clause 16 Competent Authority for deciding reduced rates.

**Superintending Engineer(E),
C.C.W : AKASHVANI : Kolkata**

Clause 18 List of mandatory machinery, tools & plants to be deployed by the contractor at site.

As required for timely execution of work

Clause 32 (i) Requirement of Technical Representative (S) and Recovery Rate.

SL. No	Minimum Qualification of Technical Representative.	Discipline	Designation (Principal Technical / Technical representative)	Minimum experience (years)	Number	Rate at which recovery shall be made from the contractor in the event of not fulfilling provision of clause 36(i)	
						Figures	Words.
1.	Graduate Engineer or Diploma Engineer	Electrical/ Mechanical	Project manager cum planning / quality /site / billing Engineer	2 or 5 yrs. Respectively.	1	Rs. 15000/- per month per person.	Rupees Fifteen Thousand only.

Assistant Engineers retired from Government services that are holding Diploma will be treated at par with Graduate Engineers.

Clause 42

i) (a) ~~Schedule/statement for determining theoretical quantity of cement & bitumen on the basis of Delhi Schedule of Rates 2007 printed by C.P.W.D.~~

ii) ~~Variations permissible on theoretical quantities.~~

a) ~~Cement for works with estimated cost put to tender not more than Rs.5 lakhs~~ ~~for works with estimated cost put to 2% plus/minus tender more than Rs.5 Lakhs.~~ ~~NIL.~~

b) ~~Bitumen for all works.~~ ~~5% plus only & nil on minus side.~~

c) ~~Steel Reinforcement and structural steel sections for each diameter, section and category.~~ ~~2% plus/minus.~~

d) ~~All other materials.~~ ~~Nil.~~

RECOVERY RATES FOR QUANTITIES BEYOND PERMISSIBLE VARIATION

Sl. No.	Description of Item	Rates in figures and words at which recovery shall be made from the Contractor.
Excess beyond permissible variation.	Less use beyond permissible variation	the

	Cement	Nil	Not Allowed
2.	Steel reinforcement	Nil	Not Allowed

Executive Engineer (Elect),
CCW : AKASHVANI : Guwahati

COMMERCIAL TERMS AND CONDITIONS

Submission of Tenders :

- i) Complete tender document as purchased, duly filled & signed. The price part of the tender shall be indicated only in the tender schedule of work.
- ii) The tenderer shall furnish along with tender any other supplementary details, detailed Technical Literature/ catalogues, pamphlets and performance data, drawings for appraisal and as may require for evaluation of the offer.

Rates :

- i) The work shall be treated as on works contract basis and the rate quoted by the tenderer shall be firm and inclusive of GST i/c Cess, charges for items contingent to the work, such as packing, forwarding, insurance and delivery at site for the materials to be supplied by the contractor, watch & ward of all materials for the work at site etc. and nothing is payable on above.
- ii) The works contract tax shall be deducted from the bills of the contractor as applicable, at the time of payments.
- iii) Deduction, if any, can be effected from agency's payment as per GST Act 2017.
- iv) The contractor has to carry out maintenance as per manufacturer's standards for a period of 12 months from the date of handing over. Nothing extra shall be paid on this account.
- v) **GCC 2023 for Project works with up to date amendments shall be the part of the agreement.**

For Specialized E&M Original works and other original E&M works :

The lowest tenderer is to be submit an undertaking from the OEM, along with the performance guarantee after the acceptance of tender regarding.

- a). Authorization certificate.
- b). The OEM should unconditionally support the lowest tenderer technically throughout the execution of contract as well as for Maintenance/Comprehensive maintenance contract for the useful life of the system, and
- c). OEM should provide all the spares required for healthy functioning of the equipment for at least seven years from the date of supply of equipment.

Executive Engineer (E)
CCW :Akashvani : Guwahati

TERMINATION OF CONTRACT ON DEATH

Without prejudice to any of the rights or remedies under this contract if the contractor dies the Divisional Officer on behalf of the President of India shall have the option of terminating the contract without compensation to the contractor.

Whenever any claim, against the contractor from the payment of sum money arises out or under the contractor, Government shall be entitled to recover such by appropriating. In part or whole, the security deposit of the contractor and he shall any Government promise notes etc. forming the whole or part of such security. In the event of the security being insufficient or if no sum recoverable as the case may be shall be deducted from any sum then due which at any time where after may become due from the contractor under this or any other contract with Government should this sum be not sufficient to cover the full amount recoverable the contractor shall be to Government on demand the balance remaining due.

Government shall have the right to cause any audit and technical examination of the works and the bill of the contractor including all supporting vouchers, abstracts etc. to be made after payment of the final bill and if as a result of such audit and technical examination any sum is found to have been overpaid in respect of any work done by him under contract and found not to have been executed the contractor shall be liable to refund the amount cover the same from him the manner prescribed in sub-clause(1)of this clause or in any manner legally permissible and if as result of audit and technical examination it is found that the contractor was paid less than that was due to him under if the amount of such under payment shall be fully paid by the Government to the contractor.

Provided the Government shall not entitled to recover any such overpaid, nor the contractor shall be entitled to payment of any such paid short where as payment has been agreed upon between the Superintending Engineer or Executive Engineer on the one hand and the contractor on the other hand any term of the contract permitting payment of work after assessment by the Superintending Engineer or the Executive Engineer.

Executive Engineer (E)
CCW : AKASHVANI : Guwahati

SPECIFICATION FOR AIR-CONDITIONING WORK

1. OBJECTIVE OF THE SPECIFICATION

This specification is intended to cover the design, manufacture, testing and delivery of ODU, IDU duly packed for transport to site, for complete Air-conditioning work.

The scope of the specification also includes the complete replacement of existing 4X11 TR CAC plant and erection of new CAC plant, final check-up, testing and commissioning at the site of the entire equipment to be supplied under this specification.

2. GENERAL INFORMATION

CCW, Akashvani intends to install 3 X 16.5/17 TR air cooled package air-conditioning plant (as a replacement of existing 4 X 11 TR worn - out outlived package A.C. setup) for Akashvani Agartala.

2.1 REQUIRMENT OF AIR FLOW

The required air flow for each unit of the system having a total of three units should not be less than 11200 CMH.

2.2 BASIS OF DESIGN

Actual quantity of the supplied air by the new system by installing 3 X 16.5/17 TR ductable type packaged ACs shall be matched with the existing ducting arrangement consisting of 4 x 11 TR out lived ACs. Designing of volume control damper and necessary sizes of duct from new machine to existing Plenum chamber to be done.

3. SCOPE OF WORK

This specification, for SITC of Air-cooled packaged 3 X 16.5/17 TR Air conditioning plants, covers supply at site, installation, testing and commissioning of complete equipment at Akashvani, Guwahati as a replacement of existing 4 x 11 TR AC Plant. The plant shall work on non-ODS refrigerant. The plants shall deliver the specified tonnage, both in summer and monsoon seasons. The AC plants are to run 20 hours a day, 365 days in a year.

4. AIR COOLED PACKAGED TYPE SYSTEM

4.1 Type

An air-cooled packaged unit is in two portions-Indoor unit and outdoor unit. Compressor, Evaporator, Expansion Valve, SA blower & filters are in indoor unit & condenser along with condenser fan is in outdoor unit. Here condenser is cooled by a propeller fan.

4.2 General

Indoor & outdoor units shall be factory assembled, tested and filled with factory charged acceptable refrigerant as per relevant norms considering ODP & GWP etc. only before delivering at site & should be suitable for operation on 380V- 415V, 3 Phase, 50 Hz AC electric supply system. Outdoor units should be air cooled type.

5. Outdoor Unit

The outdoor unit shall be factory assembled unit housed in a sturdy weather proof casing constructed from rust-proof mild steel panels coated with a baked enamel finish. The unit should be completely factory wired and tested with all necessary controls. It should be Air Cooled type.

The System must have the following features :

- 5.01 Indoor units shall have non-inverter scroll compressors and be able to operate even in case one compressor is out of order.
- 5.02 The COP at AHRI conditions shall not be less than 3.1 and IEER not less than 6.5
- 5.03 All out door unit must have pump out and pump down feature so that in case of failure, refrigerant can be accommodated in indoor and outdoor unit respectively.
- 5.04 The unit shall be provided with its own microprocessor control panel.
- 5.05 All out door unit must have Anti Corrosive Fins for better life.
- 5.06 The outdoor unit should have acceptable noise level as per relevant norms during normal operation.

6. Compressor

The compressor shall be of highly efficient hermetic scroll type.

7. Heat Exchanger

The heat exchanger shall be constructed with copper tubes mechanically bonded to aluminum fins to form a cross fin coil. The aluminum fins shall be covered by anti corrosion resin film.

8. Refrigerant Circuit

The refrigerant circuit shall include an accumulator, liquid and gas shut off valves and a solenoid valve. All necessary safety devices shall be provided to ensure the safe operation of the system.

9. Safety Devices

The following safety devices shall be part of the outdoor unit; High Pressure Switch, Low Pressure Switch, Fan Motor Safety Thermostat, Over Current Relay, Fusible Plugs, Fuses.

10. Oil Recovery System

Each unit shall be equipped with an oil separator to ensure stable operation with long refrigerant piping.

11. DRAIN PIPING

G.I./PVC condensate drain pipe in the drain point shall be provided.

12. PAINTING

All the equipments, mounting frames, stands etc. shall be painted with 2 coats of suitable paints of approved color over the priming paint to prevent corrosion of the equipment.

13. Works to be carried out by the department

Unless otherwise specified in the tender documents, following shall be arranged by the department.

- (i) Space for storing all the equipments and components involved in the work.

14. Works to be done by the tenderer

In addition to supply, installation, testing and commissioning of all the equipment as per schedule of work and specifications the following works shall be deemed to be included 32 within the scope of work to be executed by the tenderer for which nothing will be paid as extra.

- i) Minor building work for the installation such as cutting in the floor/ wall trench for cable and making good the same.
- ii) Installation of the equipment on the CC foundation, including providing necessary anti vibration mounting. Modification, if any, likely to be required in foundation shall be done by the contractor.
- iii) Provision of all accessories required for the installation of all equipment i/c pipe work for refrigeration & water pipe etc. and control cable between control panels. The layout of the control panel, laying of copper pipe etc. shall be got approved from the Engineer in charge before execution and nothing extra shall be paid over the quoted rate due to any change in the layout.
- iv) Tools & plants required for handling and installation of equipment.
- v) All tools & plants required for unloading/handling of equipment and materials at site, their assembly & erection.
- vi) Necessary equipment for commissioning and testing.
- vii) The contractor at the site for his own use will arrange water supply. Unless otherwise mentioned in the tender document, the following works also shall be done by the contractor and therefore their cost shall be deemed to be included in their tendered cost whether specifically indicated in the schedule of work or not.
 - a) Foundation for equipments i/c foundation bolts and vibration isolation spring /pads.
 - b) Support columns and beams for piping work.
 - c) Suspenders for hanging ducts and/or cable trays for laying the cables.
 - d) Excavation and refilling of trenches in soil wherever the pipes are to be laid directly in ground, i/c necessary base treatment and supports.
 - e) Sealing of all floor slab/wall openings provided by the department or contractor for pipes and cables from fire safety point of view after laying of the same.
 - f) Painting of all exposed metal surfaces of equipments and components with appropriate color as per relevant specifications.
 - g) Making openings in the walls/floors/slabs or modification in the existing openings wherever provided for carrying pipe line, ducts, cables etc.
 - h) Providing wooden/metallic frames for fixing grills/diffusers.
 - i) Making good all the damages caused to the structure during installation and restoring to their original finish.
 - j) Scaffolding work.

15. Inspection and testing :- Copies of all documents of routine and type test certificate of the equipment's, carried out at the manufacturer's premises, shall be furnished to the Engineer-in-Charge and 33 consignee. After completion of the work in all respect, the contractor shall offer the installation for testing and operation.

16. Terms of payment :

The following percentage of contract rates for the various items included in the contract shall be payable against the stage of work shown herein.

- 16.1 50 % after initial inspection and delivery at site in good condition on pro-rata basis.
- 16.2 30 % after completion of installation in all respects.
- 16.3 Balance 20 % will be paid after testing, commissioning & handing over to the department for beneficial use.
- 16.4 Income Tax, GST, TDS on GST, labourcess & other statutory deduction etc. shall be deducted at source as per prevalent laws. The deductions of security deposit, income- tax, Goods and Service tax etc. shall be done after calculation of the above due payments as per clauses 22.1 to 22.3 and net payment shall be reduced accordingly.

17. Documents to be furnished on completion of installation

- (i) 3 Sets of Completion drawings.
- (ii) 3 Sets of Manufacturer's Technical catalogues of all equipment and accessories.
- (iii) Operation and maintenance manual of all major equipment, details of all adjustments, operation and maintenance procedure.

18. Electric Power Supply & Water Supply

- i) Electricity supply will be made available free of cost to the Contractor for testing purpose only.
- ii) The contractor at the site for his own use will arrange water supply.

19. Co-ordination

- i) The contractor shall agree with Engineer in charge & competent authority for carrying out the works on Saturdays, Sundays, before & after office hours, within & in predefined time where shut down of power supply is unavoidable.
- ii) The contractor shall be responsible to abide by the regulations or restrictions set in regard to entry into and movement within premises.

20. General requirements of components

All materials & equipment supplied by the contractor shall be new. They shall be of such design, size & materials as to satisfactorily match & fit for replacement purposes as may require.

21. Refrigerant plumbing

The work shall include provision of suction line insulation as per manufactures standard. The refrigerant pipe/copper pipe linear measurement will be considered from outside wall of AC units but the inside refrigerant piping connection is to be considered as internal connection which is not payable, it will be considered as a part of AC units. The firms are advised to quote the rate of AC unit accordingly, after quoting the rate nothing will be paid on this account.

22. Workmanship

Good workmanship is an essential requirement to be complied with. The entire work shall conform to sound engineering practice. Contractor will take due care to ensure safety of existing electrical installations during execution of work.

23. After Sales Service

The contractor shall ensure adequate and prompt after sales service in the form of maintenance personnel and spares as and when required with a view to minimize the breakdown period. Particular attention shall be given to ensure that all spares are easily available during the normal life of the installation.

24. Commissioning on completion

After the work is completed, it shall be ensured that the installation is tested & commissioned and it meets up the inside Design condition i.e. $22 \pm 2^{\circ}\text{C}$ DBT and around $55 \pm 5\%$ RH.

25. Guarantee

The installation to be handed over to the department after necessary testing and commissioning. The installation shall be guaranteed against any defective workmanship. Similarly, the materials supplied by the contractor will be guaranteed against any manufacturing defect, inferior quality. The guarantee period will be for a period of 12 months from the date of commissioning/handing over to the department. Installation/ equipments or components thereof shall be rectified/ repaired to the satisfaction of the Engineer in charge.

26. Indemnity

The Successful tenderer shall at all times indemnify the department, consequent on this contract. The successful tenderer shall be liable, in accordance with the Indian Law & Regulations for any accident occurring due to any cause and the contractor shall be responsible for any accident or damage incurred or claims arising there from during the period of installation, testing, commissioning, painting etc. and putting into operation, the equipments and auxiliary equipments under the supervision of successful tenderer in so far as the latter is responsible. The successful tenderer shall also provide all insurance including third party insurance as may be necessary to cover the risk. No extra payment will be made to the successful tenderer on account of the above.

Executive Engineer (E)
CCW : Akashvani : Guwahati

SL. No.	Equipment	Approved Manufacturer
1.	Air Cooled package Ductable A.C Units	Voltas/Blue Star/Carrier/Daikin/Fujitsu General make
2.	Hard Drawn Copper refrigerant pipe	Rajco/Mandev/Shree Shyam/Nippon make
3.	Vibration isolator	Resisto flex/Emareld/Dunlop make
4.	Control Cable	RR Kable/Finolex/Polycab/Havells/Incab/KEI or as approved by OEM
5.	Drain Pipe	Supreme/Karan/Oriplast make
6.	PVC insulated and sheathed / XLPE insulated armoured aluminium / copper conductor cable	Finolex/V-guard/Polycab/Havells/KEI make
7.	PVC conduit	Precession/AKG make/Astrale Make

Executive Engineer (E)
CCW :Akashvani : Guwahati

SCHEDULE OF QUANTITY

Name of Work :- S.I.T.C of 3X16.5/17 Ton, Air cooled packaged type AC plant for replacement of existing old unserviceable 4X11 TR package units at Akashvani, Agartala.

Sl.No.	Description	Qty	Unit	Rate	Amount
1	S.I.T.C of 16.5/17.0 TR microprocessor controlled, Package type, air cooled ductable type air conditioner unit with factory charged refrigerant acceptable as per norms considering ODP & GWP etc, suitable for operation on 3 phase, 415 Volt 50 Hz. A.C. Supplying, with twin scroll compressors and consisting with the followings, i) Hermetically Sealed Scroll Compressor unit, ii) Air cooled condenser unit, iii) Blowers, iv) Cooling coil , including P/L specified size control cables, hard/soft drawn copper refrigerant piping system (approx distance from IDU to ODU=15 mtrs) etc. complete as required. (Voltas /Bluestar /carrier/Daikin/Fujitsu General or similar superior make as to be approved by the Engineer-in Charge)(Two nos running & One no.spare)	3.00	Sets		
2	Supplying & Fixing of following sizes of medium class PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.(for control cable protection)				
a	25 mm	15.00	Mtrs.		
3	Supplying & Fixing of following size MS Angle/ flat iron frame for fixing outdoor units including cutting, welding, painting etc complete as required.(ODU protective cage & rack) including grouting in cement concrete(1:3:6), excavation refilling etc as required.				
a	40 mm X 40 mm X 5mm (ODU rack)	150.00	Kg		
4	Supplying, installation, balancing & commissioning of Site fabricated GSS sheet metal rectangular ducting complete with neoprene rubber gaskets, elbows, splitter dampers, vanes, hangers, supports etc as per approved drawing & specifications of following sheet thickness complete as required.(existing duct modification & return duct)				
a	24 SWG (Thickness 0.63 mm sheet)	20.00	Sqmt		
5	Supplying, Installation, Testing & Commissioning of GI volume control duct damper complete with neoprene rubber gaskets, nuts, bolts, screws, linkages, flanges etc, as per specification.	1.20	Sqmt		
6	Supplying and fixing of following thickness duly laminated aluminium foil of mat finish closed cell Nitrile rubber (Class "O") insulation on existing duct after applying suitable adhesive for Nitrile rubber. The joints shall be sealed with 50 mm wide and 3 mm thick self adhesive nitrile rubber tape insulation complete as per specifications and as required.				
a	25 mm	20.00	Sqm		
7	Providing & installation of 40 mm thick double skin construction continuous PUF insulated aluminium chamber made of 20 SWG aluminium sheet inside AC plant room to cover from floor to main ceiling approximate height 5.00 meters as required. [Width-4.00 mtrsX height - 3.5mtrs x 1sides + length-6.00 X height-3.5 X 2 sides - (Door- 6.4 Sqmtrs.)]	49.60	Sqm		

Sl.No.	Description	Qty	Unit	Rate	Amount
8	Providing & installation of 40 mm thick double skin construction continuous PUF insulated aluminium chamber door made of 20 SWG aluminium sheet of (approximate size 1.2 mtr wide x 2.00 mtrs height) along with frame etc as required.	1.00	Nos		
9	Supplying of 4X25 sqmm XLPE insulated UG armoured Aluminium conductor cable of 1.1 KV grade including Laying and fixing the same on cable tray as required.(AC Plant panel to individual Plant PCB)	40.00	Mtrs.		
10	Supplying and making of end termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed / XLPE aluminium conductor cable of 1.1 KV grade as required.				
a	4X25 Sqmm (28mm)	6.00	Sets		
11	Supplying and installing of following size perforated Hot Dipped Galvanised Iron cable tray (Galvanisation thickness not less than 50 microns) with perforation not more than 17.5%, in convenient sections, joined with connectors, suspended from the ceiling with G.I. suspenders including G.I. bolts & nuts, etc. as required.				
a	100 mm width X 50 mm depth X 1.6 mm thickness	3.00	Mtrs.		
b	300 mm width X 50 mm depth X 1.6 mm thickness	2.75	Mtrs.		
12	Supplying, Fixing, installation, testing and commissioning of Supply air diffusers of powder coated aluminium with aluminium volume control vdampers with anti smudge ring & removable core in confirmation to SMACNA/IS and as per specifications complete etc. as required.	4.00	Sqmt		
13	Supplying, Fixing, installation, testing and commissioning of Return air diffusers of powder coated aluminium without volume control dampers with anti smudge ring & removable core in confirmation to SMACNA/IS and as per specifications complete etc. as required.	4.00	Sqmt		
14	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable and 1.5 sq.mm FRLS PVC insulated copper conductor single core cable as earth wire in existing surface/ recessed steel/PVC conduit including dismantling as required.				
a	Group C	12.00	Pts		
15	S.I.T.C of IP20 recessed LED Down lighter made of pressure die cast aluminum housing with PC diffuser, Fixture should have minimum efficiency at System level (Not Chip Level) >=110 lumens/watt with Minimum system Lumens 2000 with maximum system wattage of 18W. (Philips cat no-Philips DN296B LED 20S or similar superior make)	12.00	Nos.		
16	Earthing with copper earth plate 600 mm X 600 mm X 3 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of	2.00	Sets.		

Sl.No.	Description	Qty	Unit	Rate	Amount
	2.7 metre long etc. with charcoal/ coke and salt as required				
17	Providing and fixing of 25 mm X 5 mm copper strip in 40 mm dia G.I. pipe from earth electrode including connection with brass nut, bolt, spring, washer excavation and re-filling etc. as required.	12.00	Mtrs.		
18	Providing and fixing of 25 mm X 5 mm copper strip on surface or in recess for connections etc. as required.	16.00	Mtrs.		
19	Providing and fixing of tiled false ceiling of specified materials of size 595x595 mm in true horizontal level, suspended on inter locking metal grid of powder coated consisting of main "T" runner with suitably spaced joints to get required length and of size 24x38 mm made from 0.30 mm thick (minimum) sheet, spaced at 1200 mm center to center and cross "T" of size 24x25 mm made of 0.30 mm thick (minimum) sheet, 1200 mm long spaced between main "T" at 600 mm center to center to form a grid of 1200x600 mm and secondary cross "T" of length 600 mm and size 24x25 mm made of 0.30 mm thick (minimum) sheet to be interlocked at middle of the 1200x600 mm panel to form grids of 600x600 mm and wall angle of size 24x24x0.3 mm and laying false ceiling tiles of approved texture in the grid including, required cutting/making, opening for services like diffusers, grills, light fittings, fixtures, smoke detectors etc. Main "T" runners to be suspended from ceiling using GI slotted cleats of size 27 x 37 x 25 x1.6 mm fixed to ceiling with 12.5 mm dia and 50 mm long dash fasteners, 4 mm GI adjustable rods with 959 SUB HEAD : 12-ROOFING galvanized butterfly level clips of size 85 x 30 x 0.8 mm spaced at 1200 mm center to center along main T, bottom exposed width of 24 mm of all T-sections shall be pre-painted with polyester paint, all complete for all heights as per specifications, drawings and as directed by Engineer-in-charge.	49.50	Sqm		
20	Dismantling of 4 units 11TR. Air cooled Package Unit including all accessories etc as required.	1.00	Job		
21	SITC of 40 mm dia.(nominal) U- PVC drain water piping complete with fittings, such as elbow, tees, reducers, sockets , supports, jointing & any other item required to make the system complete etc. as required.	15.00	Mtrs.		
22	Buy-back of old unserviceable 11 TR capacity package A/c units including copper pipe, old communication service cable etc. complete as required.	4.00	Sets.		